

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Failure Incident

Document Information

Document UUID	73C16628
Document Number	INC_EVT-042
Event ID	EVT-042
Chain ID	CH-014
Equipment ID	CV-101
Department	Operations
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-042
Issue Date	09-May-2026
Revision	Rev-1.0
Prepared By	Arjun Singh
Approved By	Arun Nair
Status	Approved

Incident Information

Incident Number	INC_-042
Event ID	EVT-042
Date	2026-05-09
Department	Operations
Area	Reactor Area
Shift	Evening
Reported By	Tank Farm
Status	Closed

Equipment Details

Equipment ID	CV-101
Equipment Name	Control Valve

Area	Reactor Area
Department	Operations
Shift	Evening
Reported From	Tank Farm
Asset Criticality	High
Failure Category	Mechanical
Downtime	6 Hours

Incident Description

Equipment

Control Valve

experienced an operational failure.

Reported Problem:

Abnormal vibration

Impact Assessment

Severity	Low
Priority	Low
Downtime	6 Hours
Asset Criticality	High

Root Cause Analysis

Asset Criticality:

High

Root Cause:

Bearing wear

Immediate Action Taken

Corrective maintenance performed.

Action Details:

Bearing replaced

Safety Classification

Failure Category	Mechanical
Severity	Low
Follow-up Required	No

Safety Requirements

Equipment was electrically isolated before repair.

Recommendations

Conduct thermography inspection next month.

Previous Equipment History

Event	Date	Failure	Status
EVT-027	2026-03-25	Scheduled	Closed
EVT-042	2026-05-09	Bearing wear	Closed

Linked Documents

- WO_EVT-042.docx
- MNT_EVT-042.docx
- INS_EVT-042.docx
- EMAIL_EVT-042.txt

Approval

Prepared By	Arjun Singh
Approved By	Arun Nair