

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Failure Incident

Document Information

Document UUID	5B8938BE
Document Number	INC_EVT-044
Event ID	EVT-044
Chain ID	CH-015
Equipment ID	TG-101
Department	Maintenance
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-044
Issue Date	15-May-2026
Revision	Rev-1.0
Prepared By	Rahul Sharma
Approved By	Suresh Kumar
Status	Approved

Incident Information

Incident Number	INC_-044
Event ID	EVT-044
Date	2026-05-15
Department	Maintenance
Area	Reactor Area
Shift	Evening
Reported By	CCR
Status	Closed

Equipment Details

Equipment ID	TG-101
Equipment Name	Temperature Gauge

Area	Reactor Area
Department	Maintenance
Shift	Evening
Reported From	CCR
Asset Criticality	Medium
Failure Category	Instrumentation
Downtime	3 Hours

Incident Description

Equipment

Temperature Gauge

experienced an operational failure.

Reported Problem:

Parameter deviation

Impact Assessment

Severity	Medium
Priority	Medium
Downtime	3 Hours
Asset Criticality	Medium

Root Cause Analysis

Asset Criticality:

Medium

Root Cause:

Calibration drift

Immediate Action Taken

Corrective maintenance performed.

Action Details:

Recalibrated

Safety Classification

Failure Category	Instrumentation
Severity	Medium
Follow-up Required	No

Safety Requirements

All PPE requirements were complied with.

Recommendations

Conduct thermography inspection next month.

Previous Equipment History

Event	Date	Failure	Status
EVT-029	2026-03-31	Routine	Closed
EVT-044	2026-05-15	Calibration drift	Closed

Linked Documents

- EMAIL_EVT-044.txt

Approval

Prepared By	Rahul Sharma
Approved By	Suresh Kumar