

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Operational Incident Report

Document Information

Document UUID	E8F26CB1
Document Number	INC_EVT-050
Event ID	EVT-050
Chain ID	CH-017
Equipment ID	B-101
Department	Quality
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-050
Issue Date	02-Jun-2026
Revision	Rev-1.0
Prepared By	Suresh Kumar
Approved By	Neha Singh
Status	Approved

Incident Information

Incident Number	INC_-050
Event ID	EVT-050
Date	2026-06-02
Department	Quality
Area	Utility
Shift	Evening
Reported By	Production Floor
Status	Closed

Equipment Details

Equipment ID	B-101
Equipment Name	Steam Boiler

Area	Utility
Department	Quality
Shift	Evening
Reported From	Production Floor
Asset Criticality	Critical
Failure Category	Mechanical
Downtime	3 Hours

Incident Description

During routine plant operation an incident occurred involving equipment

B-101

Issue Reported:

Abnormal vibration

Impact Assessment

Severity	Medium
Priority	High
Downtime	3 Hours
Asset Criticality	Critical

Root Cause Analysis

Under Investigation

Immediate Action Taken

Operations team responded immediately.

Corrective Action:

Bearing replaced

Safety Classification

Failure Category	Mechanical
Severity	Medium
Follow-up Required	No

Safety Requirements

All PPE requirements were complied with.

Recommendations

Conduct thermography inspection next month.

Previous Equipment History

Event	Date	Failure	Status
EVT-011	2026-02-05	Scale buildup	Closed
EVT-012	2026-02-08	Follow-up	Closed
EVT-013	2026-02-11	Routine	Closed
EVT-014	2026-02-14	Follow-up	Closed
EVT-015	2026-02-17	Scheduled	Closed
EVT-020	2026-03-04	Calibration drift	Closed
EVT-035	2026-04-18	Scheduled	Closed
EVT-050	2026-06-02	Bearing wear	Closed

Linked Documents

- WO_EVT-050.docx
- MNT_EVT-050.docx
- INS_EVT-050.docx
- EMAIL_EVT-050.txt

Approval

Prepared By	Suresh Kumar
Approved By	Neha Singh