

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Failure Incident

Document Information

Document UUID	F9F44375
Document Number	INC_EVT-058
Event ID	EVT-058
Chain ID	CH-020
Equipment ID	PG-101
Department	Quality
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-058
Issue Date	26-Jun-2026
Revision	Rev-1.0
Prepared By	Arjun Singh
Approved By	Neha Singh
Status	Approved

Incident Information

Incident Number	INC_-058
Event ID	EVT-058
Date	2026-06-26
Department	Quality
Area	Reactor Area
Shift	Morning
Reported By	Control Room
Status	Closed

Equipment Details

Equipment ID	PG-101
Equipment Name	Pressure Gauge

Area	Reactor Area
Department	Quality
Shift	Morning
Reported From	Control Room
Asset Criticality	Medium
Failure Category	Mechanical
Downtime	3 Hours

Incident Description

Equipment

Pressure Gauge

experienced an operational failure.

Reported Problem:

Abnormal vibration

Impact Assessment

Severity	High
Priority	Low
Downtime	3 Hours
Asset Criticality	Medium

Root Cause Analysis

Asset Criticality:

Medium

Root Cause:

Bearing wear

Immediate Action Taken

Corrective maintenance performed.

Action Details:

Bearing replaced

Safety Classification

Failure Category	Mechanical
Severity	High
Follow-up Required	No

Safety Requirements

Equipment was electrically isolated before repair.

Recommendations

Conduct thermography inspection next month.

Previous Equipment History

Event	Date	Failure	Status
EVT-028	2026-03-28	Calibration drift	Closed
EVT-043	2026-05-12	Scheduled	Closed
EVT-058	2026-06-26	Bearing wear	Closed

Linked Documents

- WO_EVT-058.docx
- MNT_EVT-058.docx
- INS_EVT-058.docx
- EMAIL_EVT-058.txt

Approval

Prepared By	Arjun Singh
Approved By	Neha Singh

