

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Incident Report

Document Information

Document UUID	A39DC252
Document Number	INC_EVT-062
Event ID	EVT-062
Chain ID	CH-021
Equipment ID	P-102
Department	Engineering
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-062
Issue Date	08-Jul-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Amit Verma
Status	Approved

Incident Information

Incident Number	INC_-062
Event ID	EVT-062
Date	2026-07-08
Department	Engineering
Area	Production
Shift	Evening
Reported By	Maintenance Workshop
Status	Closed

Equipment Details

Equipment ID	P-102
Equipment Name	Transfer Pump

Area	Production
Department	Engineering
Shift	Evening
Reported From	Maintenance Workshop
Asset Criticality	High
Failure Category	Instrumentation
Downtime	1 Hours

Incident Description

An incident was reported involving

Transfer Pump

Description:

Minor spill

Impact Assessment

Severity	Low
Priority	Medium
Downtime	1 Hours
Asset Criticality	High

Root Cause Analysis

Initial investigation indicates:

Loose flange

Immediate Action Taken

Immediate corrective action taken:

Flange tightened

Safety Classification

Failure Category	Instrumentation
Severity	Low
Follow-up Required	No

Safety Requirements

Equipment was electrically isolated before repair.

Recommendations

Continue weekly inspection.

Previous Equipment History

Event	Date	Failure	Status
EVT-017	2026-02-23	Routine schedule	Closed
EVT-032	2026-04-09	Seal failure	Closed
EVT-047	2026-05-24	Scheduled	Closed
EVT-062	2026-07-08	Loose flange	Closed

Linked Documents

- WO_EVT-062.docx
- MNT_EVT-062.docx
- INS_EVT-062.docx
- EMAIL_EVT-062.txt

Approval

Prepared By	Pooja Mehta
Approved By	Amit Verma