

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Failure Incident

Document Information

Document UUID	7B9E5D8F
Document Number	INC_EVT-066
Event ID	EVT-066
Chain ID	CH-022
Equipment ID	C-101
Department	Inspection
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-066
Issue Date	20-Jul-2026
Revision	Rev-1.0
Prepared By	Neha Singh
Approved By	Anjali Desai
Status	Approved

Incident Information

Incident Number	INC_-066
Event ID	EVT-066
Date	2026-07-20
Department	Inspection
Area	Utility
Shift	Evening
Reported By	Production Floor
Status	Closed

Equipment Details

Equipment ID	C-101
Equipment Name	Air Compressor

Area	Utility
Department	Inspection
Shift	Evening
Reported From	Production Floor
Asset Criticality	High
Failure Category	Mechanical
Downtime	6 Hours

Incident Description

Equipment

Air Compressor

experienced an operational failure.

Reported Problem:

Abnormal vibration

Impact Assessment

Severity	Medium
Priority	High
Downtime	6 Hours
Asset Criticality	High

Root Cause Analysis

Asset Criticality:

High

Root Cause:

Bearing wear

Immediate Action Taken

Corrective maintenance performed.

Action Details:

Bearing replaced

Safety Classification

Failure Category	Mechanical
Severity	Medium
Follow-up Required	No

Safety Requirements

Area was barricaded before maintenance work.

Recommendations

Schedule detailed equipment health assessment.

Previous Equipment History

Event	Date	Failure	Status
EVT-021	2026-03-07	Routine	Closed
EVT-036	2026-04-21	Calibration drift	Closed
EVT-051	2026-06-05	Scheduled	Closed
EVT-066	2026-07-20	Bearing wear	Closed

Linked Documents

- WO_EVT-066.docx
- MNT_EVT-066.docx
- INS_EVT-066.docx
- EMAIL_EVT-066.txt

Approval

Prepared By	Neha Singh
-------------	------------

Approved By	Anjali Desai
-------------	--------------