

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Safety Incident Report

Document Information

Document UUID	31D2905D
Document Number	INC_EVT-068
Event ID	EVT-068
Chain ID	CH-023
Equipment ID	F-101
Department	Maintenance
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-068
Issue Date	26-Jul-2026
Revision	Rev-1.0
Prepared By	Rahul Sharma
Approved By	Suresh Kumar
Status	Approved

Incident Information

Incident Number	INC_-068
Event ID	EVT-068
Date	2026-07-26
Department	Maintenance
Area	Packaging
Shift	Evening
Reported By	Field Operator
Status	Closed

Equipment Details

Equipment ID	F-101
Equipment Name	Pressure Filter

Area	Packaging
Department	Maintenance
Shift	Evening
Reported From	Field Operator
Asset Criticality	Medium
Failure Category	Instrumentation
Downtime	3 Hours

Incident Description

An operational abnormality was observed during the Evening shift.

Observation:

Parameter deviation

Impact Assessment

Severity	Medium
Priority	Medium
Downtime	3 Hours
Asset Criticality	Medium

Root Cause Analysis

Severity:

Medium

Priority:

Medium

Root Cause:

Calibration drift

Immediate Action Taken

Maintenance team secured the equipment and carried out the following action:

Recalibrated

Safety Classification

Failure Category	Instrumentation
Severity	Medium
Follow-up Required	No

Safety Requirements

Permit To Work (PTW) was verified before maintenance.

Recommendations

Conduct thermography inspection next month.

Previous Equipment History

Event	Date	Failure	Status
EVT-023	2026-03-13	Scheduled	Closed
EVT-038	2026-04-27	Loose flange	Closed
EVT-053	2026-06-11	Routine	Closed
EVT-068	2026-07-26	Calibration drift	Closed

Linked Documents

- EMAIL_EVT-068.txt

Approval

Prepared By	Rahul Sharma
Approved By	Suresh Kumar

