

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Safety Incident Report

Document Information

Document UUID	7F9C753F
Document Number	INC_EVT-072
Event ID	EVT-072
Chain ID	CH-024
Equipment ID	CV-101
Department	Inspection
Generated On	15-Jul-2026 13:06
Confidentiality	Internal Use Only

Document Control

Document Number	INC_EVT-072
Issue Date	07-Aug-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Anjali Desai
Status	Approved

Incident Information

Incident Number	INC_-072
Event ID	EVT-072
Date	2026-08-07
Department	Inspection
Area	Reactor Area
Shift	Night
Reported By	Utilities Area
Status	Open

Equipment Details

Equipment ID	CV-101
Equipment Name	Control Valve

Area	Reactor Area
Department	Inspection
Shift	Night
Reported From	Utilities Area
Asset Criticality	High
Failure Category	Mechanical
Downtime	0 Hours

Incident Description

An operational abnormality was observed during the Night shift.

Observation:

Leakage detected

Impact Assessment

Severity	High
Priority	Medium
Downtime	0 Hours
Asset Criticality	High

Root Cause Analysis

Severity:

High

Priority:

Medium

Root Cause:

Seal failure

Immediate Action Taken

Maintenance team secured the equipment and carried out the following action:

Seal replaced

Safety Classification

Failure Category	Mechanical
Severity	High
Follow-up Required	No

Safety Requirements

Permit To Work (PTW) was verified before maintenance.

Recommendations

Increase preventive maintenance frequency.

Previous Equipment History

Event	Date	Failure	Status
EVT-027	2026-03-25	Scheduled	Closed
EVT-042	2026-05-09	Bearing wear	Closed
EVT-057	2026-06-23	Routine schedule	Closed
EVT-072	2026-08-07	Seal failure	Open

Linked Documents

- WO_EVT-072.docx
- MNT_EVT-072.docx
- INS_EVT-072.docx
- EMAIL_EVT-072.txt

Approval

Prepared By	Pooja Mehta
Approved By	Anjali Desai