

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Routine Inspection Report

Document Information

Document UUID	8DEAB38D
Document Number	INS_EVT-001
Event ID	EVT-001
Chain ID	CH-001
Equipment ID	P-101
Department	Operations
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-001
Issue Date	06-Jan-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Arun Nair
Status	Approved

Equipment Details

Equipment ID	P-101
Equipment Name	Feed Pump
Area	Tank Farm
Department	Operations
Shift	Morning
Reported From	Control Room
Asset Criticality	High
Failure Category	Mechanical
Downtime	1 Hours

Inspection Objective

Routine inspection was conducted on Feed Pump to evaluate its operating condition and identify any abnormalities.

Inspection Findings

Inspection completed successfully.

Failure Category :
Mechanical

Severity :
Low

Equipment condition appears satisfactory.

Observed Defects

Observed condition:

High vibration detected

Risk Assessment

Risk Level : Low

Inspector Remarks

Preventive maintenance interval should be reduced.

Safety Observation

Gas detector readings were within permissible limits.

Inspection Tools

Dial Gauge

Inspection Summary

Priority	High
Severity	Low
Status	Closed
Downtime	1 Hours
Follow-up Required	Yes
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-001	2026-01-06	Bearing wear	Closed

Root Cause

Bearing wear

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Conduct thermography inspection next month.

Linked Documents

- WO_EVT-001.docx
- MNT_EVT-001.docx
- INS_EVT-001.docx
- EMAIL_EVT-001.txt

Approval

Prepared By	Pooja Mehta
Approved By	Arun Nair