

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Condition Inspection

Document Information

Document UUID	A3984F3F
Document Number	INS_EVT-004
Event ID	EVT-004
Chain ID	CH-002
Equipment ID	P-101
Department	Maintenance
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-004
Issue Date	15-Jan-2026
Revision	Rev-1.0
Prepared By	Karan Gupta
Approved By	Suresh Kumar
Status	Approved

Equipment Details

Equipment ID	P-101
Equipment Name	Feed Pump
Area	Tank Farm
Department	Maintenance
Shift	Morning
Reported From	Tank Farm
Asset Criticality	High
Failure Category	Mechanical
Downtime	2 Hours

Inspection Objective

Inspection initiated following an operational complaint from Maintenance.

Inspection Findings

Equipment checked for vibration, temperature, leakage and alignment.

Status :

Closed

Observed Defects

Inspector observed:

Mechanical seal leakage

Risk Assessment

Risk Level : Medium

Inspector Remarks

Equipment restored to normal operating condition.

Safety Observation

Area was barricaded before maintenance work.

Inspection Tools

Insulation Tester

Inspection Summary

Priority	Low
Severity	Low
Status	Closed

Downtime	2 Hours
Follow-up Required	Yes
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-001	2026-01-06	Bearing wear	Closed
EVT-002	2026-01-09	Follow-up	Closed
EVT-003	2026-01-12	Routine PM	Closed
EVT-004	2026-01-15	Seal wear	Closed

Root Cause

Seal wear

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Perform vibration analysis after one week.

Linked Documents

- WO_EVT-004.docx
- MNT_EVT-004.docx
- INS_EVT-004.docx
- EMAIL_EVT-004.txt

Approval

Prepared By	Karan Gupta
Approved By	Suresh Kumar