

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Condition Inspection

Document Information

Document UUID	4470A696
Document Number	INS_EVT-016
Event ID	EVT-016
Chain ID	CH-006
Equipment ID	P-101
Department	Operations
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-016
Issue Date	20-Feb-2026
Revision	Rev-1.0
Prepared By	Neha Singh
Approved By	Arun Nair
Status	Approved

Equipment Details

Equipment ID	P-101
Equipment Name	Feed Pump
Area	Tank Farm
Department	Operations
Shift	Morning
Reported From	Control Room
Asset Criticality	High
Failure Category	Mechanical
Downtime	4 Hours

Inspection Objective

Inspection initiated following an operational complaint from Operations.

Inspection Findings

Equipment checked for vibration, temperature, leakage and alignment.

Status :

Closed

Observed Defects

Inspector observed:

Leakage detected

Risk Assessment

Risk Level : Medium

Inspector Remarks

Further monitoring is recommended before closing the case.

Safety Observation

Equipment was electrically isolated before repair.

Inspection Tools

Laser Alignment Kit

Inspection Summary

Priority	High
Severity	Low
Status	Closed

Downtime	4 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-001	2026-01-06	Bearing wear	Closed
EVT-002	2026-01-09	Follow-up	Closed
EVT-003	2026-01-12	Routine PM	Closed
EVT-004	2026-01-15	Seal wear	Closed
EVT-005	2026-01-18	Follow-up	Closed
EVT-016	2026-02-20	Seal failure	Closed

Root Cause

Seal failure

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Continue weekly inspection.

Linked Documents

- WO_EVT-016.docx
- MNT_EVT-016.docx
- INS_EVT-016.docx

- EMAIL_EVT-016.txt

Approval

Prepared By	Neha Singh
Approved By	Arun Nair