

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Preventive Inspection Report

Document Information

Document UUID	2A37E7DC
Document Number	INS_EVT-019
Event ID	EVT-019
Chain ID	CH-007
Equipment ID	HE-101
Department	Maintenance
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-019
Issue Date	01-Mar-2026
Revision	Rev-1.0
Prepared By	Arjun Singh
Approved By	Suresh Kumar
Status	Approved

Equipment Details

Equipment ID	HE-101
Equipment Name	Heat Exchanger
Area	Production
Department	Maintenance
Shift	Morning
Reported From	Production Floor
Asset Criticality	High
Failure Category	Instrumentation
Downtime	6 Hours

Inspection Objective

Preventive inspection performed before scheduled maintenance shutdown.

Inspection Findings

Minor abnormalities detected.

Priority :
High

Downtime :
6 Hours

Observed Defects

Inspection identified:

Scheduled

Risk Assessment

Risk Level : Medium

Inspector Remarks

Preventive maintenance interval should be reduced.

Safety Observation

LOTO procedure was followed throughout maintenance.

Inspection Tools

Insulation Tester

Inspection Summary

Priority	High
Severity	High

Status	Closed
Downtime	6 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-019	2026-03-01	Scheduled	Closed

Root Cause

Scheduled

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Monitor bearing temperature daily.

Linked Documents

- INS_EVT-019.docx

Approval

Prepared By	Arjun Singh
Approved By	Suresh Kumar

