

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Detailed Equipment Inspection

Document Information

Document UUID	842C3DC8
Document Number	INS_EVT-026
Event ID	EVT-026
Chain ID	CH-009
Equipment ID	M-101
Department	Maintenance
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-026
Issue Date	22-Mar-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Suresh Kumar
Status	Approved

Equipment Details

Equipment ID	M-101
Equipment Name	Agitator
Area	Reactor Area
Department	Maintenance
Shift	Evening
Reported From	Field Operator
Asset Criticality	High
Failure Category	Mechanical
Downtime	1 Hours

Inspection Objective

Detailed inspection performed after maintenance completion.

Inspection Findings

Inspection verified that corrective action has been completed.

Asset Criticality :

High

Observed Defects

Verification Remarks:

Bearing replaced

Risk Assessment

Risk Level : Low

Inspector Remarks

Operator advised to monitor pressure readings for 48 hours.

Safety Observation

All PPE requirements were complied with.

Inspection Tools

Laser Alignment Kit

Inspection Summary

Priority	High
Severity	Medium
Status	Closed

Downtime	1 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-026	2026-03-22	Bearing wear	Closed

Root Cause

Bearing wear

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Continue weekly inspection.

Linked Documents

- WO_EVT-026.docx
- MNT_EVT-026.docx
- INS_EVT-026.docx
- EMAIL_EVT-026.txt

Approval

Prepared By	Pooja Mehta
Approved By	Suresh Kumar