

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Routine Inspection Report

Document Information

Document UUID	0B08A816
Document Number	INS_EVT-032
Event ID	EVT-032
Chain ID	CH-011
Equipment ID	P-102
Department	Operations
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-032
Issue Date	09-Apr-2026
Revision	Rev-1.0
Prepared By	Arjun Singh
Approved By	Arun Nair
Status	Approved

Equipment Details

Equipment ID	P-102
Equipment Name	Transfer Pump
Area	Production
Department	Operations
Shift	Evening
Reported From	Field Operator
Asset Criticality	High
Failure Category	Mechanical
Downtime	3 Hours

Inspection Objective

Routine inspection was conducted on Transfer Pump to evaluate its operating condition and identify any abnormalities.

Inspection Findings

Under Investigation

Observed Defects

Observed condition:

Leakage detected

Risk Assessment

Risk Level : Low

Inspector Remarks

Preventive maintenance interval should be reduced.

Safety Observation

Gas detector readings were within permissible limits.

Inspection Tools

Laser Alignment Kit

Inspection Summary

Priority	Medium
Severity	Low
Status	Closed
Downtime	3 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-017	2026-02-23	Routine schedule	Closed
EVT-032	2026-04-09	Seal failure	Closed

Root Cause

Seal failure

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Conduct thermography inspection next month.

Linked Documents

- WO_EVT-032.docx
- MNT_EVT-032.docx
- INS_EVT-032.docx
- EMAIL_EVT-032.txt

Approval

Prepared By	Arjun Singh
Approved By	Arun Nair