

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Preventive Inspection Report

Document Information

Document UUID	0AF3581E
Document Number	INS_EVT-036
Event ID	EVT-036
Chain ID	CH-012
Equipment ID	C-101
Department	Maintenance
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-036
Issue Date	21-Apr-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Suresh Kumar
Status	Approved

Equipment Details

Equipment ID	C-101
Equipment Name	Air Compressor
Area	Utility
Department	Maintenance
Shift	Night
Reported From	Production Floor
Asset Criticality	High
Failure Category	Instrumentation
Downtime	3 Hours

Inspection Objective

Preventive inspection performed before scheduled maintenance shutdown.

Inspection Findings

Minor abnormalities detected.

Priority :
High

Downtime :
3 Hours

Observed Defects

Inspection identified:

Calibration drift

Risk Assessment

Risk Level : Medium

Inspector Remarks

Equipment performance is within acceptable limits.

Safety Observation

Equipment was electrically isolated before repair.

Inspection Tools

Hydraulic Jack

Inspection Summary

Priority	High
Severity	High

Status	Closed
Downtime	3 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-021	2026-03-07	Routine	Closed
EVT-036	2026-04-21	Calibration drift	Closed

Root Cause

Calibration drift

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Continue weekly inspection.

Linked Documents

- EMAIL_EVT-036.txt

Approval

Prepared By	Pooja Mehta
-------------	-------------

Approved By	Suresh Kumar
-------------	--------------