

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Detailed Equipment Inspection

Document Information

Document UUID	9CE9441D
Document Number	INS_EVT-041
Event ID	EVT-041
Chain ID	CH-014
Equipment ID	M-101
Department	Operations
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-041
Issue Date	06-May-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Arun Nair
Status	Approved

Equipment Details

Equipment ID	M-101
Equipment Name	Agitator
Area	Reactor Area
Department	Operations
Shift	Morning
Reported From	Utilities Area
Asset Criticality	High
Failure Category	Instrumentation
Downtime	3 Hours

Inspection Objective

Detailed inspection performed after maintenance completion.

Inspection Findings

Inspection verified that corrective action has been completed.

Asset Criticality :

High

Observed Defects

Verification Remarks:

Serviced

Risk Assessment

Risk Level : Low

Inspector Remarks

Further monitoring is recommended before closing the case.

Safety Observation

Equipment was electrically isolated before repair.

Inspection Tools

Hydraulic Jack

Inspection Summary

Priority	Low
Severity	High
Status	Closed

Downtime	3 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-026	2026-03-22	Bearing wear	Closed
EVT-041	2026-05-06	Routine schedule	Closed

Root Cause

Routine schedule

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Conduct thermography inspection next month.

Linked Documents

- WO_EVT-041.docx
- MNT_EVT-041.docx
- INS_EVT-041.docx
- EMAIL_EVT-041.txt

Approval

Prepared By	Pooja Mehta
Approved By	Arun Nair