

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Condition Inspection

Document Information

Document UUID	400D756F
Document Number	INS_EVT-042
Event ID	EVT-042
Chain ID	CH-014
Equipment ID	CV-101
Department	Operations
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-042
Issue Date	09-May-2026
Revision	Rev-1.0
Prepared By	Arjun Singh
Approved By	Arun Nair
Status	Approved

Equipment Details

Equipment ID	CV-101
Equipment Name	Control Valve
Area	Reactor Area
Department	Operations
Shift	Evening
Reported From	Tank Farm
Asset Criticality	High
Failure Category	Mechanical
Downtime	6 Hours

Inspection Objective

Inspection initiated following an operational complaint from Operations.

Inspection Findings

Under Investigation

Observed Defects

Inspector observed:

Abnormal vibration

Risk Assessment

Risk Level : Medium

Inspector Remarks

Recommend OEM inspection during annual shutdown.

Safety Observation

Permit To Work (PTW) was verified before maintenance.

Inspection Tools

Dial Gauge

Inspection Summary

Priority	Low
Severity	Low
Status	Closed
Downtime	6 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
-------	------	---------	--------

EVT-027	2026-03-25	Scheduled	Closed
EVT-042	2026-05-09	Bearing wear	Closed

Root Cause

Bearing wear

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Monitor bearing temperature daily.

Linked Documents

- WO_EVT-042.docx
- MNT_EVT-042.docx
- INS_EVT-042.docx
- EMAIL_EVT-042.txt

Approval

Prepared By	Arjun Singh
Approved By	Arun Nair