

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Detailed Equipment Inspection

Document Information

Document UUID	A3BBBA9A
Document Number	INS_EVT-044
Event ID	EVT-044
Chain ID	CH-015
Equipment ID	TG-101
Department	Maintenance
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-044
Issue Date	15-May-2026
Revision	Rev-1.0
Prepared By	Rahul Sharma
Approved By	Suresh Kumar
Status	Approved

Equipment Details

Equipment ID	TG-101
Equipment Name	Temperature Gauge
Area	Reactor Area
Department	Maintenance
Shift	Evening
Reported From	CCR
Asset Criticality	Medium
Failure Category	Instrumentation
Downtime	3 Hours

Inspection Objective

Detailed inspection performed after maintenance completion.

Inspection Findings

Inspection verified that corrective action has been completed.

Asset Criticality :

Medium

Observed Defects

Verification Remarks:

Recalibrated

Risk Assessment

Risk Level : Low

Inspector Remarks

Equipment restored to normal operating condition.

Safety Observation

Equipment was electrically isolated before repair.

Inspection Tools

Insulation Tester

Inspection Summary

Priority	Medium
Severity	Medium
Status	Closed

Downtime	3 Hours
Follow-up Required	No
Asset Criticality	Medium

Previous Equipment History

Event	Date	Failure	Status
EVT-029	2026-03-31	Routine	Closed
EVT-044	2026-05-15	Calibration drift	Closed

Root Cause

Calibration drift

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Replace similar components during annual shutdown.

Linked Documents

- EMAIL_EVT-044.txt

Approval

Prepared By	Rahul Sharma
Approved By	Suresh Kumar

