

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Routine Inspection Report

Document Information

Document UUID	B133230C
Document Number	INS_EVT-046
Event ID	EVT-046
Chain ID	CH-016
Equipment ID	P-101
Department	Maintenance
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-046
Issue Date	21-May-2026
Revision	Rev-1.0
Prepared By	Karan Gupta
Approved By	Suresh Kumar
Status	Approved

Equipment Details

Equipment ID	P-101
Equipment Name	Feed Pump
Area	Tank Farm
Department	Maintenance
Shift	Morning
Reported From	Control Room
Asset Criticality	High
Failure Category	Instrumentation
Downtime	4 Hours

Inspection Objective

Routine inspection was conducted on Feed Pump to evaluate its operating condition and identify any abnormalities.

Inspection Findings

Under Investigation

Observed Defects

Observed condition:

Minor spill

Risk Assessment

Risk Level : Low

Inspector Remarks

No abnormal noise observed after trial run.

Safety Observation

Equipment was electrically isolated before repair.

Inspection Tools

Bearing Puller

Inspection Summary

Priority	Low
Severity	High
Status	Closed
Downtime	4 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-001	2026-01-06	Bearing wear	Closed
EVT-002	2026-01-09	Follow-up	Closed
EVT-003	2026-01-12	Routine PM	Closed
EVT-004	2026-01-15	Seal wear	Closed
EVT-005	2026-01-18	Follow-up	Closed
EVT-016	2026-02-20	Seal failure	Closed
EVT-031	2026-04-06	Scheduled	Closed
EVT-046	2026-05-21	Loose flange	Closed

Root Cause

Loose flange

Inspection Checklist

☒ Lock Out / Tag Out (LOTO) Followed

☒ PPE Worn

☒ Visual Inspection Completed

☒ Lubrication Checked

☒ Leak Inspection Completed

☒ Alignment Verified

☒ Trial Run Successful

Recommendations

Increase preventive maintenance frequency.

Linked Documents

- WO_EVT-046.docx
- MNT_EVT-046.docx
- INS_EVT-046.docx
- EMAIL_EVT-046.txt

Approval

Prepared By	Karan Gupta
Approved By	Suresh Kumar