

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Equipment Condition Inspection

Document Information

Document UUID	F6D514FF
Document Number	INS_EVT-050
Event ID	EVT-050
Chain ID	CH-017
Equipment ID	B-101
Department	Quality
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-050
Issue Date	02-Jun-2026
Revision	Rev-1.0
Prepared By	Suresh Kumar
Approved By	Neha Singh
Status	Approved

Equipment Details

Equipment ID	B-101
Equipment Name	Steam Boiler
Area	Utility
Department	Quality
Shift	Evening
Reported From	Production Floor
Asset Criticality	Critical
Failure Category	Mechanical
Downtime	3 Hours

Inspection Objective

Inspection initiated following an operational complaint from Quality.

Inspection Findings

Under Investigation

Observed Defects

Inspector observed:

Abnormal vibration

Risk Assessment

Risk Level : Medium

Inspector Remarks

Recommend OEM inspection during annual shutdown.

Safety Observation

Equipment was electrically isolated before repair.

Inspection Tools

Hydraulic Jack

Inspection Summary

Priority	High
Severity	Medium
Status	Closed
Downtime	3 Hours
Follow-up Required	No
Asset Criticality	Critical

Previous Equipment History

Event	Date	Failure	Status
-------	------	---------	--------

EVT-011	2026-02-05	Scale buildup	Closed
EVT-012	2026-02-08	Follow-up	Closed
EVT-013	2026-02-11	Routine	Closed
EVT-014	2026-02-14	Follow-up	Closed
EVT-015	2026-02-17	Scheduled	Closed
EVT-020	2026-03-04	Calibration drift	Closed
EVT-035	2026-04-18	Scheduled	Closed
EVT-050	2026-06-02	Bearing wear	Closed

Root Cause

Bearing wear

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Monitor bearing temperature daily.

Linked Documents

- WO_EVT-050.docx
- MNT_EVT-050.docx
- INS_EVT-050.docx
- EMAIL_EVT-050.txt

Approval

Prepared By	Suresh Kumar
Approved By	Neha Singh