

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Detailed Equipment Inspection

Document Information

Document UUID	8246C549
Document Number	INS_EVT-056
Event ID	EVT-056
Chain ID	CH-019
Equipment ID	M-101
Department	Quality
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-056
Issue Date	20-Jun-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Neha Singh
Status	Approved

Equipment Details

Equipment ID	M-101
Equipment Name	Agitator
Area	Reactor Area
Department	Quality
Shift	Evening
Reported From	Utilities Area
Asset Criticality	High
Failure Category	Mechanical
Downtime	3 Hours

Inspection Objective

Detailed inspection performed after maintenance completion.

Inspection Findings

Inspection verified that corrective action has been completed.

Asset Criticality :

High

Observed Defects

Verification Remarks:

Seal replaced

Risk Assessment

Risk Level : Low

Inspector Remarks

Equipment restored to normal operating condition.

Safety Observation

Permit To Work (PTW) was verified before maintenance.

Inspection Tools

Dial Gauge

Inspection Summary

Priority	Low
Severity	Medium
Status	Closed

Downtime	3 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-026	2026-03-22	Bearing wear	Closed
EVT-041	2026-05-06	Routine schedule	Closed
EVT-056	2026-06-20	Seal failure	Closed

Root Cause

Seal failure

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Increase preventive maintenance frequency.

Linked Documents

- WO_EVT-056.docx
- MNT_EVT-056.docx
- INS_EVT-056.docx
- EMAIL_EVT-056.txt

Approval

Prepared By	Pooja Mehta
Approved By	Neha Singh