

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Detailed Equipment Inspection

Document Information

Document UUID	148C6927
Document Number	INS_EVT-062
Event ID	EVT-062
Chain ID	CH-021
Equipment ID	P-102
Department	Engineering
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-062
Issue Date	08-Jul-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Amit Verma
Status	Approved

Equipment Details

Equipment ID	P-102
Equipment Name	Transfer Pump
Area	Production
Department	Engineering
Shift	Evening
Reported From	Maintenance Workshop
Asset Criticality	High
Failure Category	Instrumentation
Downtime	1 Hours

Inspection Objective

Detailed inspection performed after maintenance completion.

Inspection Findings

Inspection verified that corrective action has been completed.

Asset Criticality :

High

Observed Defects

Verification Remarks:

Flange tightened

Risk Assessment

Risk Level : Low

Inspector Remarks

Further monitoring is recommended before closing the case.

Safety Observation

LOTO procedure was followed throughout maintenance.

Inspection Tools

Pressure Gauge

Inspection Summary

Priority	Medium
Severity	Low
Status	Closed

Downtime	1 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-017	2026-02-23	Routine schedule	Closed
EVT-032	2026-04-09	Seal failure	Closed
EVT-047	2026-05-24	Scheduled	Closed
EVT-062	2026-07-08	Loose flange	Closed

Root Cause

Loose flange

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Replace similar components during annual shutdown.

Linked Documents

- WO_EVT-062.docx
- MNT_EVT-062.docx
- INS_EVT-062.docx
- EMAIL_EVT-062.txt

Approval

Prepared By	Pooja Mehta
Approved By	Amit Verma