

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Preventive Inspection Report

Document Information

Document UUID	C39DC659
Document Number	INS_EVT-066
Event ID	EVT-066
Chain ID	CH-022
Equipment ID	C-101
Department	Inspection
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-066
Issue Date	20-Jul-2026
Revision	Rev-1.0
Prepared By	Neha Singh
Approved By	Anjali Desai
Status	Approved

Equipment Details

Equipment ID	C-101
Equipment Name	Air Compressor
Area	Utility
Department	Inspection
Shift	Evening
Reported From	Production Floor
Asset Criticality	High
Failure Category	Mechanical
Downtime	6 Hours

Inspection Objective

Preventive inspection performed before scheduled maintenance shutdown.

Inspection Findings

Minor abnormalities detected.

Priority :
High

Downtime :
6 Hours

Observed Defects

Inspection identified:

Bearing wear

Risk Assessment

Risk Level : Medium

Inspector Remarks

Recommend vibration monitoring during next inspection.

Safety Observation

Equipment was electrically isolated before repair.

Inspection Tools

Insulation Tester

Inspection Summary

Priority	High
Severity	Medium

Status	Closed
Downtime	6 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-021	2026-03-07	Routine	Closed
EVT-036	2026-04-21	Calibration drift	Closed
EVT-051	2026-06-05	Scheduled	Closed
EVT-066	2026-07-20	Bearing wear	Closed

Root Cause

Bearing wear

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Schedule detailed equipment health assessment.

Linked Documents

- WO_EVT-066.docx
- MNT_EVT-066.docx
- INS_EVT-066.docx
- EMAIL_EVT-066.txt

Approval

Prepared By	Neha Singh
Approved By	Anjali Desai