

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Routine Inspection Report

Document Information

Document UUID	1AA6A811
Document Number	INS_EVT-072
Event ID	EVT-072
Chain ID	CH-024
Equipment ID	CV-101
Department	Inspection
Generated On	15-Jul-2026 13:05
Confidentiality	Internal Use Only

Document Control

Document Number	INS_EVT-072
Issue Date	07-Aug-2026
Revision	Rev-1.0
Prepared By	Pooja Mehta
Approved By	Anjali Desai
Status	Approved

Equipment Details

Equipment ID	CV-101
Equipment Name	Control Valve
Area	Reactor Area
Department	Inspection
Shift	Night
Reported From	Utilities Area
Asset Criticality	High
Failure Category	Mechanical
Downtime	0 Hours

Inspection Objective

Routine inspection was conducted on Control Valve to evaluate its operating condition and identify any abnormalities.

Inspection Findings

Inspection completed successfully.

Failure Category :
Mechanical

Severity :
High

Equipment condition appears satisfactory.

Observed Defects

Observed condition:

Leakage detected

Risk Assessment

Risk Level : Low

Inspector Remarks

Recommend OEM inspection during annual shutdown.

Safety Observation

Gas detector readings were within permissible limits.

Inspection Tools

Torque Wrench

Inspection Summary

Priority	Medium
Severity	High
Status	Open
Downtime	0 Hours
Follow-up Required	No
Asset Criticality	High

Previous Equipment History

Event	Date	Failure	Status
EVT-027	2026-03-25	Scheduled	Closed
EVT-042	2026-05-09	Bearing wear	Closed
EVT-057	2026-06-23	Routine schedule	Closed
EVT-072	2026-08-07	Seal failure	Open

Root Cause

Seal failure

Inspection Checklist

- ☒ Lock Out / Tag Out (LOTO) Followed
- ☒ PPE Worn
- ☒ Visual Inspection Completed
- ☒ Lubrication Checked
- ☒ Leak Inspection Completed
- ☒ Alignment Verified
- ☒ Trial Run Successful

Recommendations

Continue weekly inspection.

Linked Documents

- WO_EVT-072.docx

- MNT_EVT-072.docx
- INS_EVT-072.docx
- EMAIL_EVT-072.txt

Approval

Prepared By	Pooja Mehta
Approved By	Anjali Desai