

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Safety Observation Report

Document Information

Document UUID	D5473849
Document Number	SAF_EVT-009
Event ID	EVT-009
Chain ID	CH-003
Equipment ID	R-101
Department	Inspection
Generated On	15-Jul-2026 14:01
Confidentiality	Internal Use Only

Document Control

Document Number	SAF_EVT-009
Issue Date	30-Jan-2026
Revision	Rev-1.0
Prepared By	Vikram Rao
Approved By	Anjali Desai
Status	Approved

Safety Information

Safety Report Number	SAF_-009
Event ID	EVT-009
Department	Inspection
Area	Reactor Area
Shift	Night
Reported By	CCR
Severity	Low
Status	Closed

Equipment Details

Equipment ID	R-101
Equipment Name	Chemical Reactor

Area	Reactor Area
Department	Inspection
Shift	Night
Reported From	CCR
Asset Criticality	Critical
Failure Category	Mechanical
Downtime	1 Hours

Safety Event Description

Safety observation recorded for:

Equipment Name:
Chemical Reactor

Observation:

Agitator noise

Hazard Identification

Potential hazard identified:

Failure Category:

Mechanical

Severity:

Low

Risk Assessment

Risk Level:

Low

Asset Criticality:

Critical

Immediate Action Taken

Immediate action taken:

Bearing replaced

Root Cause Analysis

Bearing wear

Corrective Action

Bearing replaced

Preventive Action

Conduct regular safety inspections
and ensure compliance with safety procedures.

Safety Officer Remarks

Recommend OEM inspection during annual shutdown.

Safety Compliance Checklist

☒ Lock Out / Tag Out (LOTO) Followed

☒ PPE Worn

☒ Visual Inspection Completed

☒ Lubrication Checked

☒ Leak Inspection Completed

☒ Alignment Verified

☒ Trial Run Successful

Previous Equipment History

Event	Date	Failure	Status
EVT-006	2026-01-21	Control tuning	Closed
EVT-007	2026-01-24	Routine	Closed
EVT-008	2026-01-27	Follow-up	Closed
EVT-009	2026-01-30	Bearing wear	Closed

Recommendations

Conduct thermography inspection next month.

Linked Documents

- WO_EVT-009.docx
- MNT_EVT-009.docx
- INS_EVT-009.docx
- EMAIL_EVT-009.txt

Approval

Prepared By	Vikram Rao
Approved By	Anjali Desai