

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Safety Observation Report

Document Information

Document UUID	8DE4F1CC
Document Number	SAF_EVT-011
Event ID	EVT-011
Chain ID	CH-004
Equipment ID	B-101
Department	Inspection
Generated On	15-Jul-2026 14:01
Confidentiality	Internal Use Only

Document Control

Document Number	SAF_EVT-011
Issue Date	05-Feb-2026
Revision	Rev-1.0
Prepared By	Vikram Rao
Approved By	Anjali Desai
Status	Approved

Safety Information

Safety Report Number	SAF_-011
Event ID	EVT-011
Department	Inspection
Area	Utility
Shift	Evening
Reported By	Control Room
Severity	Medium
Status	Closed

Equipment Details

Equipment ID	B-101
Equipment Name	Steam Boiler

Area	Utility
Department	Inspection
Shift	Evening
Reported From	Control Room
Asset Criticality	Critical
Failure Category	Process
Downtime	6 Hours

Safety Event Description

Safety observation recorded for:

Equipment Name:
Steam Boiler

Observation:

Low steam pressure

Hazard Identification

Potential hazard identified:

Failure Category:

Process

Severity:

Medium

Risk Assessment

Risk Level:

Medium

Asset Criticality:

Critical

Immediate Action Taken

Immediate action taken:

Chemical cleaning

Root Cause Analysis

Scale buildup

Corrective Action

Chemical cleaning

Preventive Action

Conduct regular safety inspections
and ensure compliance with safety procedures.

Safety Officer Remarks

Equipment performance is within acceptable limits.

Safety Compliance Checklist

☒ Lock Out / Tag Out (LOTO) Followed

☒ PPE Worn

☒ Visual Inspection Completed

☒ Lubrication Checked

☒ Leak Inspection Completed

☒ Alignment Verified

☒ Trial Run Successful

Previous Equipment History

Event	Date	Failure	Status
EVT-011	2026-02-05	Scale buildup	Closed

Recommendations

Monitor bearing temperature daily.

Linked Documents

- WO_EVT-011.docx
- MNT_EVT-011.docx
- INS_EVT-011.docx
- EMAIL_EVT-011.txt

Approval

Prepared By	Vikram Rao
Approved By	Anjali Desai