

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Safety Incident Investigation

Document Information

Document UUID	E92EB7D1
Document Number	SAF_EVT-032
Event ID	EVT-032
Chain ID	CH-011
Equipment ID	P-102
Department	Operations
Generated On	15-Jul-2026 14:01
Confidentiality	Internal Use Only

Document Control

Document Number	SAF_EVT-032
Issue Date	09-Apr-2026
Revision	Rev-1.0
Prepared By	Arjun Singh
Approved By	Arun Nair
Status	Approved

Safety Information

Safety Report Number	SAF_-032
Event ID	EVT-032
Department	Operations
Area	Production
Shift	Evening
Reported By	Field Operator
Severity	Low
Status	Closed

Equipment Details

Equipment ID	P-102
Equipment Name	Transfer Pump

Area	Production
Department	Operations
Shift	Evening
Reported From	Field Operator
Asset Criticality	High
Failure Category	Mechanical
Downtime	3 Hours

Safety Event Description

Safety incident occurred during:

Evening shift.

Incident Details:

Leakage detected

Hazard Identification

Hazard category:

Mechanical

Root Cause:

Seal failure

Risk Assessment

Risk Priority:

Medium

Severity:

Low

Immediate Action Taken

Immediate corrective action:

Seal replaced

Root Cause Analysis

Seal failure

Corrective Action

Seal replaced

Preventive Action

Provide safety awareness training
and improve preventive monitoring.

Safety Officer Remarks

Preventive maintenance interval should be reduced.

Safety Compliance Checklist

☒ Lock Out / Tag Out (LOTO) Followed

☒ PPE Worn

☒ Visual Inspection Completed

☒ Lubrication Checked

☒ Leak Inspection Completed

☐ Alignment Verified — Pending

☒ Trial Run Successful

Previous Equipment History

Event	Date	Failure	Status
EVT-017	2026-02-23	Routine schedule	Closed
EVT-032	2026-04-09	Seal failure	Closed

Recommendations

Increase preventive maintenance frequency.

Linked Documents

- WO_EVT-032.docx
- MNT_EVT-032.docx
- INS_EVT-032.docx
- EMAIL_EVT-032.txt

Approval

Prepared By	Arjun Singh
Approved By	Arun Nair