

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Safety Observation Report

Document Information

Document UUID	6BCBBDCB
Document Number	SAF_EVT-044
Event ID	EVT-044
Chain ID	CH-015
Equipment ID	TG-101
Department	Maintenance
Generated On	15-Jul-2026 14:01
Confidentiality	Internal Use Only

Document Control

Document Number	SAF_EVT-044
Issue Date	15-May-2026
Revision	Rev-1.0
Prepared By	Rahul Sharma
Approved By	Suresh Kumar
Status	Approved

Safety Information

Safety Report Number	SAF_-044
Event ID	EVT-044
Department	Maintenance
Area	Reactor Area
Shift	Evening
Reported By	CCR
Severity	Medium
Status	Closed

Equipment Details

Equipment ID	TG-101
Equipment Name	Temperature Gauge

Area	Reactor Area
Department	Maintenance
Shift	Evening
Reported From	CCR
Asset Criticality	Medium
Failure Category	Instrumentation
Downtime	3 Hours

Safety Event Description

Safety observation recorded for:

Equipment Name:
Temperature Gauge

Observation:

Parameter deviation

Hazard Identification

Potential hazard identified:

Failure Category:

Instrumentation

Severity:

Medium

Risk Assessment

Risk Level:

Medium

Asset Criticality:

Medium

Immediate Action Taken

Immediate action taken:

Recalibrated

Root Cause Analysis

Calibration drift

Corrective Action

Recalibrated

Preventive Action

Conduct regular safety inspections
and ensure compliance with safety procedures.

Safety Officer Remarks

Equipment restored to normal operating condition.

Safety Compliance Checklist

☒ Lock Out / Tag Out (LOTO) Followed

☒ PPE Worn

☒ Visual Inspection Completed

☒ Lubrication Checked

☒ Leak Inspection Completed

☒ Alignment Verified

☐ Trial Run Successful — Pending

Previous Equipment History

Event	Date	Failure	Status
EVT-029	2026-03-31	Routine	Closed
EVT-044	2026-05-15	Calibration drift	Closed

Recommendations

Conduct thermography inspection next month.

Linked Documents

- EMAIL_EVT-044.txt

Approval

Prepared By	Rahul Sharma
Approved By	Suresh Kumar