

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Safety Observation Report

Document Information

Document UUID	C68D8F77
Document Number	SAF_EVT-048
Event ID	EVT-048
Chain ID	CH-016
Equipment ID	R-101
Department	Safety
Generated On	15-Jul-2026 14:01
Confidentiality	Internal Use Only

Document Control

Document Number	SAF_EVT-048
Issue Date	27-May-2026
Revision	Rev-1.0
Prepared By	Neha Singh
Approved By	Karan Gupta
Status	Approved

Safety Information

Safety Report Number	SAF_-048
Event ID	EVT-048
Department	Safety
Area	Reactor Area
Shift	Night
Reported By	Utilities Area
Severity	Low
Status	Closed

Equipment Details

Equipment ID	R-101
Equipment Name	Chemical Reactor

Area	Reactor Area
Department	Safety
Shift	Night
Reported From	Utilities Area
Asset Criticality	Critical
Failure Category	Mechanical
Downtime	6 Hours

Safety Event Description

Safety observation recorded for:

Equipment Name:
Chemical Reactor

Observation:

Leakage detected

Hazard Identification

Potential hazard identified:

Failure Category:

Mechanical

Severity:

Low

Risk Assessment

Risk Level:

Low

Asset Criticality:

Critical

Immediate Action Taken

Immediate action taken:

Seal replaced

Root Cause Analysis

Seal failure

Corrective Action

Seal replaced

Preventive Action

Conduct regular safety inspections
and ensure compliance with safety procedures.

Safety Officer Remarks

Equipment restored to normal operating condition.

Safety Compliance Checklist

☒ Lock Out / Tag Out (LOTO) Followed

☒ PPE Worn

☒ Visual Inspection Completed

☐ Lubrication Checked — Pending

☒ Leak Inspection Completed

☒ Alignment Verified

☒ Trial Run Successful

Previous Equipment History

Event	Date	Failure	Status
EVT-006	2026-01-21	Control tuning	Closed
EVT-007	2026-01-24	Routine	Closed
EVT-008	2026-01-27	Follow-up	Closed
EVT-009	2026-01-30	Bearing wear	Closed
EVT-010	2026-02-02	Follow-up	Closed
EVT-018	2026-02-26	Bearing wear	Closed
EVT-033	2026-04-12	Routine schedule	Closed
EVT-048	2026-05-27	Seal failure	Closed

Recommendations

Continue weekly inspection.

Linked Documents

- WO_EVT-048.docx
- MNT_EVT-048.docx
- INS_EVT-048.docx
- EMAIL_EVT-048.txt

Approval

Prepared By	Neha Singh
Approved By	Karan Gupta