

NovaChem Chemicals Pvt. Ltd.

NovaChem Industrial Plant

Plot No. 18, GIDC Industrial Estate,
Vadodara, Gujarat - 390010

Safety Observation Report

Document Information

Document UUID	A0EFA668
Document Number	SAF_EVT-052
Event ID	EVT-052
Chain ID	CH-018
Equipment ID	CT-101
Department	Operations
Generated On	15-Jul-2026 14:01
Confidentiality	Internal Use Only

Document Control

Document Number	SAF_EVT-052
Issue Date	08-Jun-2026
Revision	Rev-1.0
Prepared By	Karan Gupta
Approved By	Arun Nair
Status	Approved

Safety Information

Safety Report Number	SAF_-052
Event ID	EVT-052
Department	Operations
Area	Utility
Shift	Morning
Reported By	CCR
Severity	Medium
Status	Closed

Equipment Details

Equipment ID	CT-101
Equipment Name	Cooling Tower

Area	Utility
Department	Operations
Shift	Morning
Reported From	CCR
Asset Criticality	Medium
Failure Category	Instrumentation
Downtime	3 Hours

Safety Event Description

Safety observation recorded for:

Equipment Name:
Cooling Tower

Observation:

Parameter deviation

Hazard Identification

Potential hazard identified:

Failure Category:

Instrumentation

Severity:

Medium

Risk Assessment

Risk Level:

Medium

Asset Criticality:

Medium

Immediate Action Taken

Immediate action taken:

Recalibrated

Root Cause Analysis

Calibration drift

Corrective Action

Recalibrated

Preventive Action

Conduct regular safety inspections
and ensure compliance with safety procedures.

Safety Officer Remarks

No abnormal noise observed after trial run.

Safety Compliance Checklist

☒ Lock Out / Tag Out (LOTO) Followed

☒ PPE Worn

☒ Visual Inspection Completed

☒ Lubrication Checked

☒ Leak Inspection Completed

☒ Alignment Verified

☒ Trial Run Successful

Previous Equipment History

Event	Date	Failure	Status
EVT-022	2026-03-10	Loose flange	Closed
EVT-037	2026-04-24	Routine	Closed
EVT-052	2026-06-08	Calibration drift	Closed

Recommendations

Continue weekly inspection.

Linked Documents

- EMAIL_EVT-052.txt

Approval

Prepared By	Karan Gupta
Approved By	Arun Nair