



DEVBHOOMI TESTING LABORATORY DEHRADUN

NABL Accredited, Govt. Approved, MSME Registered, & ISO : 9001:2015 & 14001: 2015 Certified Laboratory

Neelkanth Enclave, Harbhajwala, Telpur Chowk, Shimla By Pass Road, Dehradun 248171

Mob: +91-7217360360, +91-7579118238, 8859392493, 9760764229

Email: devbhoomilab@gmail.com

TEST REPORT

Description of Sample: Surface Water	Report No.: DTL/DDN/2025/0804/21
Sample Id: 08042025/21	Date of Report: 16/04/2025
Sample Quantity: As per requirement	Date of Sampling: 08/04/2025
Sample Condition: Receipt as OK	Start Date of Testing: 12/04/2025
Sample Plan & Sampling Method: NA	Date of Completion: 16/04/2025
Environment Condition (Temp. & Humidity): As per requirement	Page 1 of 1
Addition to, Deviation or Exclusion from the Method: NA	
N.O.W : "Construction of 30M Span Intermediate Lane Motor Bridge & its approach in Km-2 of Ujjawalpur to Gwad Dungri Jaspur Motor Road in District Chamoli."	
Issued to: Mr.Umashankar Singh Rawat, Tharali Chamoli, Uttarakhand	

Sample: 01

S. No.	Characteristics	Test Value	Max. Permissible Limit as per IS: 456-2000 (Clause 5.4)	Method of test ref to:
1.	Requirement of 0.02 N-Noah to neutralize 100ml. of water sample using Phenolphthalein indicator	0.4	5.0 ml.	IS-3025 (P-22) 1986 RA:2019
2.	Requirement of 0.02 N-H ₂ SO ₄ to neutralize 100ml of water sample using mixed indicator	6.2	25.0 ml.	IS-3025 (P-23) 1986 RA:2019
3.	Organics, mg/l.	78	200	IS: 3025 (P-18) 2022
4.	Inorganic, mg/l.	110	3000	IS: 3025 (P-18) 2022
5.	Sulphate as SO ₃ , mg/l.	25	400	IS: 3025(P-24)1986 RA:2019
6.	Chloride as Cl, mg/l	28	500 mg /l for RCC & 200mg/l for concrete without embedded steel.	IS: 3025 (P-32) 1988 RA:2019
7.	pH	7.90	Not less than 6.0	IS: 3025 (P-11) 2022
8.	Suspended matter, mg/l	1.78	2000	IS: 3025 (P-17) 2022

*****End of Report***



Checked & Issued by
Authorised Signatory

1. The result Listed refer only to the tested sample & applicable parameters endorsement of products is neither inferred nor implied.
2. Total liability of our lab is limited to the invoiced amount.
3. Sample not drawn by lab and sample will be destroyed after 30 days from the date of issue of test report.
4. This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.



DEVBHOOMI TESTING LABORATORY DEHRADUN

NABL Accredited, Govt. Approved, MSME Registered, & ISO : 9001:2015 & 14001: 2015 Certified Laboratory

Neelkanth Enclave, Harbhajwala, Telpur Chowk, Shimla By Pass Road, Dehradun 248171

Mob: +91-7217360360, +91-7579118238, 8859392493, 9760764229

Email: devbhoomilab@gmail.com

TEST REPORT

Description of Sample: Surface Water	Report No.: DTL/DDN/2025/0704/75
Sample Id: 07042025/75	Date of Report: 16/04/2025
Sample Quantity: As per requirement	Date of Sampling: 07/04/2025
Sample Condition: Receipt as OK	Start Date of Testing: 12/04/2025
Sample Plan & Sampling Method: NA	Date of Completion: 16/04/2025
Environment Condition (Temp. & Humidity): NA	Page 1 of 1
Addition to, Deviation or Exclusion from the Method: NA	
N.O.W : "Construction of 54M Span Intermediate Lane Motor Bridge in& its approach over Meeng Gadera Km-1 of Gadhani Motor Road in District Chamoli.	
Issued to: Mr.Umashankar Singh Rawat, Tharali Chamoli, Uttarakhand	

Sample: 01

S. No.	Characteristics	Test Value	Max. Permissible Limit as per IS: 456-2000 (Clause 5.4)	Method of test ref to:
1.	Requirement of 0.02 N-Noah to neutralize 100ml. of water sample using Phenolphthalein indicator	0.6	5.0 ml.	IS-3025 (P-22) 1986RA:2019
2.	Requirement of 0.02 N-H ₂ SO ₄ to neutralize 100ml of water sample using mixed indicator	7.5	25.0 ml.	IS-3025 (P-23) 1986RA:2019
3.	Organics, mg/l.	80	200	IS: 3025 (P-18) 2022
4.	Inorganic, mg/l.	110	3000	IS: 3025 (P-18) 2022
5.	Sulphate as SO ₃ , mg/l.	27	400	IS: 3025(P-24)1986 RA:2019
6.	Chloride as Cl, mg/l	32	500 mg /l for RCC & 200mg/l for concrete without embedded steel.	IS: 3025 (P-32) 1988RA:2019
7.	pH	7.70	Not less than 6.0	IS: 3025 (P-11) 2022
8.	Suspended matter, mg/l	160	2000	IS: 3025 (P-17) 2022

*****End of Report***


Technical Manager
Devbhoomi Testing Laboratory
Dehradun

Checked & Issued by
Authorised Signatory

1. The result Listed refer only to the tested sample & applicable parameters endorsement of products is neither inferred nor implied.
2. Total liability of our lab is limited to the invoiced amount.
3. Sample not drawn by lab and sample will be destroyed after 30 days from the date of issue of test report.
4. This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.



DEVBHOOMI TESTING LABORATORY DEHRADUN

NABL Accredited, Govt. Approved, MSME Registered, & ISO : 9001:2015 & 14001: 2015 Certified Laboratory

Neelkanth Enclave, Harbhajwala, Telpur Chowk, Shimla By Pass Road, Dehradun 248171

Mob: +91-7217360360, +91-7579118238, 8859392493, 9760764229

Email: devbhoomilab@gmail.com

TEST REPORT

Description of Sample: Surface Water	Report No.: DTL/DDN/2025/0804/16
Sample Id: 08042025/16	Date of Report: 16/04/2025
Sample Quantity: As per requirement	Date of Sampling: 08/04/2025
Sample Condition: Receipt as OK	Start Date of Testing: 12/04/2025
Sample Plan & Sampling Method: NA	Date of Completion: 16/04/2025
Environment Condition (Temp. & Humidity): NA	Page 1 of 1
Addition to, Deviation or Exclusion from the Method: NA	
N.O.W : "Construction of 36M Span Intermediate Lane Motor Bridge & its approach in Km-2 of Gairsain to village Devalkot Motor Road in District Chamoli.	
Issued to: Mr.Umashankar Singh Rawat, Tharali Chamoli, Uttarakhand	

Sample: 01

S. No.	Characteristics	Test Value	Max. Permissible Limit as per IS: 456-2000 (Clause 5.4)	Method of test ref to:
1.	Requirement of 0.02 N-Noah to neutralize 100ml. of water sample using Phenolphthalein indicator	0.22	5.0 ml.	IS-3025 (P-22) 1986RA:2019
2.	Requirement of 0.02 N-H ₂ SO ₄ to neutralize 100ml of water sample using mixed indicator	5.82	25.0 ml.	IS-3025 (P-23) 1986RA:2019
3.	Organics, mg/l.	78	200	IS: 3025 (P-18) 2022
4.	Inorganic, mg/l.	115	3000	IS: 3025 (P-18) 2022
5.	Sulphate as SO ₃ , mg/l.	24	400	IS: 3025(P-24)1986 RA:2019
6.	Chloride as Cl, mg/l	30	500 mg /l for RCC & 200mg/l for concrete without embedded steel.	IS: 3025 (P-32) 1988RA:2019
7.	pH	7.72	Not less than 6.0	IS: 3025 (P-11) 2022
8.	Suspended matter, mg/l	165	2000	IS: 3025 (P-17) 2022

*****End of Report***



Checked & Issued by
Authorised Signatory

1. The result Listed refer only to the tested sample & applicable parameters endorsement of products is neither inferred nor implied.
2. Total liability of our lab is limited to the invoiced amount.
3. Sample not drawn by lab and sample will be destroyed after 30 days from the date of issue of test report.
4. This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.