



DEVBHOOMI TESTING LABORATORY DEHRADUN

NABL Accredited, Govt. Approved, MSME Registered, & ISO : 9001:2015 & 14001: 2015 Certified Laboratory

Neelkanth Enclave, Harbhajwala, Telpur Chowk, Shimla By Pass Road, Dehradun 248171

Mob: +91-7217360360, +91-7579118238, 8859392493, 9760764229

Email: devbhoomilab@gmail.com

TEST REPORT

Description of Sample: Drinking Water	Report No.: DTL/DDN/2025/0604/05
Sample Id: 07042025/05	Date of Report: 14/04/2025
Sample Quantity: 1 Ltr.	Date of Sampling: 06/04/2025
Sample Condition: Receipt as OK	Start Date of Testing: 07/04/2025
Sample Plan & Sampling Method: NA	Date of Completion: 13/04/2025
Environment Condition (Temp. & Humidity): NA	Page 1 of 1
Addition to, Deviation or Exclusion from the Method: NA	
N.O.W : "Construction of 125M Span Single Suspension Pedestrian Bridge over Pinda River for Odar village in District Chamoli"	
Issued to: M/S KGL Infrastructures. 33-A Aam Bagh, Garhi Cantt, Dehradun - 248003	

Requirement as per IS: 10500-2012 RA:2018

S. No.	Characteristics	Test-Value	Acceptable Limit	Permissible Limit in Absence of alternate source	Method of Test
1.	Colour, Hazen unit Max.	≤5	5	15	IS-3025(P-4)-1983 RA:2021
2.	Odour	Agreeable	Agreeable	Agreeable	IS-3025(P-5)-1983 RA:2018
3.	Turbidity, NTU. Max.	Nil	1	5	IS-3025(P-10)-1984 RA:2017
4.	pH Value	7.72	6.5-8.5	No Relaxation	IS-3025(P-11)-1983 RA:2022
5.	Total Hardness, (as CaCO ₃), mg/l Max.	25	200	600	IS-3025(P-21)-2009 RA:2019
6.	Iron (as Fe), mg/l Max.	0.26	0.3	No Relaxation	IS-3025(P-53)-2012 RA:2019
7.	Chloride (as Cl), mg/l Max.	18	250	1000	IS-3025(P-32)-1988 RA:2019
8.	Total Dissolved Solid mg/L Max.	110	500	2000	IS-3025(P-16)-1984 RA:2017
9.	Bacteriological Test				IS:1622-1981 RA:2019
	a) E-Coli	ND	Shall not be detectable		
	b) Total coliform bacteria	ND			

*****End of Report*****

Adh
NARESH CHAMOLI
Environment Expert
FPIU PWD (U-PREPARE)
Dehradun

Adh
J.E



Checked & Issued by
Signature