



DEVBHOOMI TESTING LABORATORY DEHRADUN

NABL Accredited, Govt. Approved, MSME Registered, & ISO : 9001:2015 & 14001: 2015 Certified Laboratory

Neelkanth Enclave, Harbhajwala, Telpur Chowk, Shimla By Pass Road, Dehradun 248171

Mob: +91-7217360360, +91-7579118238, 8859392493, 9760764229

Email: devbhoomilab@gmail.com

TEST REPORT

Description of Sample: R.C.C Cube Abutment “M-30”	Report No.: DTL/DDN/2025/0426/01
Sample Id.: 04262025/01	Date of Report: 27/06/2025
Sample Quantity: 3 Nos.	Date of Casting: 20/06/2025
Sample Condition: Receipt as OK	Date of Receipt: 27/06/2025
Sample Plan & Sampling Method: NA	Start Date of Testing: 27/06/2025
Environment Condition (Temp. & Humidity): NA	Date of Completion: 27/06/2025
Addition to, Deviation or Exclusion from the Method: NA	Page 1 of 1
Agg. No:09/BR/RFB-EPC/UGRIDP/2023	
N.O.W: Construction of 36 M. Motor Bridge at Gairsain to Village Devalkot in Chamoli.	
Contractor: M/s Umashankar Singh Rawat Construction	
Issued to: Umashankar Singh Rawat, Tharali Chamoli, Uttarakhand.	

COMPRESSIVE STRENGTH After 07 Days				
S.No.	Weight of Cube, Kg	Method of test Ref to:	Compressive Strength, N/mm ²	Average Comp. Strength, N/mm ²
1.	8.273	IS-516-1959 RA: 2018	25.45	24.84
2.	8.260		24.60	
3.	8.312		24.47	

*****End of Report*****



Checked & Issued by
Authorised Signatory

1. The result Listed refer only to the tested sample & applicable parameters endorsement of products is neither inferred nor implied.
2. Total liability of our lab is limited to the invoiced amount.
3. Sample not drawn by lab and sample will be destroyed after 30 days from the date of issue of test report.
4. This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.



DEVBHOOMI TESTING LABORATORY DEHRADUN

NABL Accredited, Govt. Approved, MSME Registered, & ISO : 9001:2015 & 14001: 2015 Certified Laboratory

Neelkanth Enclave, Harbhajwala, Telpur Chowk, Shimla By Pass Road, Dehradun 248171

Mob: +91-7217360360, +91-7579118238, 8859392493, 9760764229

Email: devbhoomilab@gmail.com

TEST REPORT

Description of Sample: R.C.C Cube Abutment “M-30”	Report No.: DTL/DDN/2025/0427/02
Sample Id.: 04272025/02	Date of Report: 18/07/2025
Sample Quantity: 3 Nos.	Date of Casting: 20/06/2025
Sample Condition: Receipt as OK	Date of Receipt: 27/06/2025
Sample Plan & Sampling Method: NA	Start Date of Testing: 18/07/2025
Environment Condition (Temp. & Humidity): NA	Date of Completion: 18/07/2025
Addition to, Deviation or Exclusion from the Method: NA	Page 1 of 1
Agg. No: 09/BR/RFB-EPC/UGRIDP/2023	
N.O.W: Construction of 36 M. Motor Bridge at Gairsain to Village Devalkot in Chamoli.	
Contractor: M/s Umashankar Singh Rawat Construction	
Issued to: Umashankar Singh Rawat, Tharali Chamoli, Uttarakhand.	

COMPRESSIVE STRENGTH After 28 Days				
S.No.	Weight of Cube, Kg	Method of test Ref to:	Compressive Strength, N/mm ²	Average Comp. Strength, N/mm ²
1.	8.122	IS-516-1959 RA: 2018	34.28	34.45
2.	8.296		33.40	
3.	8.224		35.68	

*****End of Report*****


Technical Manager
Dehradun

Checked & Issued by
Authorised Signatory

1. The result Listed refer only to the tested sample & applicable parameters endorsement of products is neither inferred nor implied.
2. Total liability of our lab is limited to the invoiced amount.
3. Sample not drawn by lab and sample will be destroyed after 30 days from the date of issue of test report.
4. This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.