



# SHREE TEST HOUSE

ISO 9001:2015 ISO 45001:2018 ISO 14001:2015  
Certified Testing Laboratory



Searching For A Better Solution

Office: Khata No. 1631, Khasra No. 80, Mi. Village- Saheed Dwar, Post-Athoorwala, Doiwala, Distt.- Dehradun, Uttarakhand-248140  
Tel:- 0135-4083260, 9650902576, 9910725840, 9870333136 Email : shreetesthouse@gmail.com, Website: www.shreetesthouse.com

## TEST REPORT

Job ID No./Job Card No.- STH2900012025	Report No. – STH20250081024 -001
Name & Address of Customer- Executive Engineer, Provincial Division, PWD, Pithoragarh.	Sample Name – Soil
	Make Grade – N/A
Letter Reference No.- 16/UPREPARE/02A/BR/RFB-EPC/UPREPARE/2024 Dated 21/04/2025	Date of Letter – 21/04/2025
	Date of Receipt – 17/10/2025
Name of Work- Construction of 100m intermediate Lane Steel Truss Moter Bridge Over Dholi River at Sela Village in District Pithoragarh.	Date of Start – 17/10/2025
	Date of Completion – 24/10/2025
Name of Agency/Contractor- Lisha Engineers Private Limited.	Date of Issue Report – 24/10/2025
	Page No. – 1 of 1

Sr. No.	TEST PARAMETERS	UNIT	TEST RESULT	TEST METHOD
1.	Grain Size Analysis			
	a) Gravels	%	0	
	b) Sand		36.3	IS:2720 (P-4)RA-2010
	c) Silt		53.7	
	d) Clay		10.0	
2.	Optimum Moisture Content	%	10.83	IS:2720 (P-2)-1973
3.	pH	%	20.22	IS:2720 (P-26)-1973
4.	Conductivity	µs/cm	575	IS:14767
5.	Sodium	ppm	248	SVTL/SOP
6.	Total Nitrogen	%	1.20	SVTL/SOP
7.	Boron	mg/kg	1.15	SVTL/SOP

\*\*\*End of Report\*\*\*

  
Director Signature



Terms & Conditions: 1 Test Reports Are Valid Only For The Sample Tested In Our Laboratory. 2 Sample Will Be Stored/kept In Our Stores For 30 Days Form The Date Of Testing And Shall Be Destroyed Thereafter Without Any Intimation. 3. Samples Tested Are Non-returnable If The Specific Duration Of 30 Days Are Over 4 This Report Will Not Be Valid For Judicial Purpose. 5. Total Liability Of Our Test House Is Limited To Invoiced Amount only.