



# DEVBHOOMI TESTING LABORATORY DEHRADUN

NABL Accredited, Govt. Approved, MSME Registered, & ISO : 9001:2015 & 14001: 2015 Certified Laboratory

Neelkanth Enclave, Harbhajwala, Telpur Chowk, Shimla By Pass Road, Dehradun 248171

Mob: +91-7217360360, +91-7579118238, 8859392493, 9760764229

Email: devbhoomilab@gmail.com

## TEST REPORT

Description of Sample: Noise Level Monitoring	Report No.: DTL/DDN/2024/0411/18
Sample Id: 04112024/18	Date of Report: 10/11/2024
Sample Quantity: As per requirement	Date of Sampling: 04/11/2024
Sample Condition: Receipt as OK	Start Date of Testing: 07/11/2024
Sample Plan & Sampling Method: NA	Date of Completion: 10/11/2024
Environment Condition (Temp. & Humidity): NA	Page 1 of 1
Addition to, Deviation or Exclusion from the Method: NA	
N.O.W : "Construction of 48M Span Intermediate Lane Motor Bridge & its approach in Km-2 of Gairsain to village Devalkot Motor Road in District Chamoli."	
Issued to: Mr. Umashankar Singh Rawat, Tharali Chamoli, Uttarakhand	

### Location: L.H.S

Parameters			Test Value	Ambient Air Quality Standards in respect of Noise Limits in dB(A) Leq, (the Noise Pollution Regulation & Control) RULES-2000			
				Industrial	Commercial	Residential	Silence
Noise Level (Day)dB(A)	Leq	Day	43.1	75	65	55	50
	Lmax.	Day	44.8	-	-	-	-
	Lmin.	Day	40.2	-	-	-	-

\*\*\*\*\*End of Report\*\*\*\*\*

  
Devbhoomi Testing Laboratory  
Technical Manager

Checked & Issued by  
Authorised Signatory

1. The result Listed refer only to the tested sample & applicable parameters endorsement of products is neither inferred nor implied.
2. Total liability of our lab is limited to the invoiced amount.
3. Sample not drawn by lab and sample will be destroyed after 30 days from the date of issue of test report.
4. This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.





# DEVBHOOMI TESTING LABORATORY DEHRADUN

NABL Accredited, Govt. Approved, MSME Registered, & ISO : 9001:2015 & 14001: 2015 Certified Laboratory

Neelkanth Enclave, Harbhajwala, Telpur Chowk, Shimla By Pass Road, Dehradun 248171

Mob: +91-7217360360, +91-7579118238, 8859392493, 9760764229

Email: devbhoomilab@gmail.com

## TEST REPORT

Description of Sample: Noise Level Monitoring	Report No.: DTL/DDN/2024/0411/19
Sample Id: 04112024/19	Date of Report: 10/11/2024
Sample Quantity: As per requirement	Date of Sampling: 04/11/2024
Sample Condition: Receipt as OK	Start Date of Testing: 07/11/2024
Sample Plan & Sampling Method: NA	Date of Completion: 10/11/2024
Environment Condition (Temp. & Humidity): NA	Page 1 of 1
Addition to, Deviation or Exclusion from the Method: NA	
N.O.W : "Construction of 48M Span Intermediate Lane Motor Bridge & its approach in Km-2 of Gairsain to village Devalkot Motor Road in District Chamoli."	
Issued to: Mr. Umashankar Singh Rawat, Tharali Chamoli, Uttarakhand	

### Location: R.H.S

Parameters			Test Value	Ambient Air Quality Standards in respect of Noise Limits in dB(A) Leq, (the Noise Pollution Regulation & Control) RULES-2000			
				Industrial	Commercial	Residential	Silence
Noise Level (Day)dB(A)	Leq	Day	42.7	75	65	55	50
	Lmax.	Day	45.2	-	-	-	-
	Lmin.	Day	38.4	-	-	-	-

\*\*\*\*\*End of Report\*\*\*\*\*



Checked & Issued by  
Authorised Signatory

1. The result Listed refer only to the tested sample & applicable parameters endorsement of products is neither inferred nor implied.
2. Total liability of our lab is limited to the invoiced amount.
3. Sample not drawn by lab and sample will be destroyed after 30 days from the date of issue of test report.
4. This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.