



# DEVBHOOMI TESTING LABORATORY DEHRADUN

NABL Accredited, Govt. Approved, MSME Registered, & ISO : 9001:2015 & 14001: 2015 Certified Laboratory

Neelkanth Enclave, Harbhajwala, Telpur Chowk, Shimla By Pass Road, Dehradun 248171

Mob: +91-7217360360, +91-7579118238, 8859392493, 9760764229

Email: devbhoomilab@gmail.com

## TEST REPORT

Description of Sample: R.C.C Cube Raft “M-30”	Report No.: DTL/DDN/2025/0415/01
Sample Id.: 04152025/01	Date of Report: 19/07/2025
Sample Quantity: 3 Nos.	Date of Casting: 12/07/2025
Sample Condition: Receipt as OK	Date of Receipt: 19/07/2025
Sample Plan & Sampling Method: NA	Start Date of Testing: 19/07/2025
Environment Condition (Temp. & Humidity): NA	Date of Completion: 19/07/2025
Addition to, Deviation or Exclusion from the Method: NA	Page 1 of 1
Agg. No:09/BR/RFB-EPC/UGRIDP/2023	
N.O.W: Construction of 30m span motor bridge in Ujjwalpur to Gwad Dungri Jaspur MR.	
Contractor: M/s Umashankar Singh Rawat Construction	
Issued to: Umashankar Singh Rawat, Tharali Chamoli, Uttarakhand.	

COMPRESSIVE STRENGTH After 07 Days				
S.No.	Weight of Cube, Kg	Method of test Ref to:	Compressive Strength, N/mm <sup>2</sup>	Average Comp. Strength, N/mm <sup>2</sup>
1.	8.290	IS-516-1959 RA: 2018	24.39	24.40
2.	8.260		25.62	
3.	8.310		24.19	

\*\*\*\*\*End of Report\*\*\*\*\*



Checked & Issued by  
Authorised Signatory

1. The result Listed refer only to the tested sample & applicable parameters endorsement of products is neither inferred nor implied.
2. Total liability of our lab is limited to the invoiced amount.
3. Sample not drawn by lab and sample will be destroyed after 30 days from the date of issue of test report.
4. This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.