

# run\_case33loss202

## File Details

```
% run_case33Loss202.m

mpc = case33Loss202(); % Load your custom case

results = runpf(mpc); % Run power flow

printpf(results); % Print results
```

## Output:

MATPOWER Version 8.0, 17-May-2024

Power Flow -- AC-polar-power formulation

Newton's method converged in 3 iterations.

PF successful

Converged in 0.37 seconds

```
=====
====
| System Summary |
=====
=====
```

How many? How much? P (MW) Q (MVar)

```
-----
Buses 33 Total Gen Capacity 3267.0 -3267.0 to 3267.0
Generators 33 On-line Capacity 99.0 -99.0 to 99.0
Committed Gens 1 Generation (actual) 3.9 2.4
Loads 32 Load 3.7 2.3
Fixed 32 Fixed 3.7 2.3
Dispatchable 0 Dispatchable -0.0 of -0.0 -0.0
Shunts 0 Shunt (inj) -0.0 0.0
Branches 32 Losses ( $I^2 * Z$ ) 0.20 0.14
Transformers 0 Branch Charging (inj) - 0.0
Inter-ties 0 Total Inter-tie Flow 0.0 0.0
Areas 1
```

Minimum Maximum

Voltage Magnitude 0.913 p.u. @ bus 18 1.000 p.u. @ bus 1  
Voltage Angle -0.50 deg @ bus 18 0.50 deg @ bus 30  
P Losses ( $I^2 \cdot R$ ) - 0.05 MW @ line 2-3  
Q Losses ( $I^2 \cdot X$ ) - 0.03 MVar @ line 5-6

| Bus Data |

Bus Voltage Generation Load

# Mag(pu) Ang(deg) P (MW) Q (MVar) P (MW) Q (MVar)

1	1.000	0.000*	3.92	2.44	-	-
2	0.997	0.014	-	-	0.10	0.06
3	0.983	0.096	-	-	0.09	0.04
4	0.975	0.162	-	-	0.12	0.08
5	0.968	0.228	-	-	0.06	0.03
6	0.950	0.134	-	-	0.06	0.02
7	0.946	-0.096	-	-	0.20	0.10
8	0.941	-0.060	-	-	0.20	0.10
9	0.935	-0.133	-	-	0.06	0.02
10	0.929	-0.196	-	-	0.06	0.02
11	0.928	-0.189	-	-	0.04	0.03
12	0.927	-0.179	-	-	0.06	0.04
13	0.921	-0.270	-	-	0.06	0.04
14	0.918	-0.349	-	-	0.12	0.08
15	0.917	-0.386	-	-	0.06	0.01
16	0.916	-0.409	-	-	0.06	0.02
17	0.914	-0.487	-	-	0.06	0.02
18	0.913	-0.496	-	-	0.09	0.04
19	0.997	0.004	-	-	0.09	0.04
20	0.993	-0.063	-	-	0.09	0.04
21	0.992	-0.083	-	-	0.09	0.04
22	0.992	-0.103	-	-	0.09	0.04
23	0.979	0.065	-	-	0.09	0.05
24	0.973	-0.024	-	-	0.42	0.20
25	0.969	-0.067	-	-	0.42	0.20
26	0.948	0.173	-	-	0.06	0.03
27	0.945	0.229	-	-	0.06	0.03
28	0.934	0.312	-	-	0.06	0.02
29	0.926	0.390	-	-	0.12	0.07
30	0.922	0.496	-	-	0.20	0.60
31	0.918	0.411	-	-	0.15	0.07
32	0.917	0.388	-	-	0.21	0.10

33 0.917 0.380 - - 0.06 0.04

Total: 3.92 2.44 3.72 2.30

### | Branch Data |

Brnch From To From Bus Injection To Bus Injection Loss ( $I^2 * Z$ )  
# Bus Bus P (MW) Q (MVar) P (MW) Q (MVar) P (MW) Q (MVar)

1	1	2	3.92	2.44	-3.91	-2.43	0.012	0.01
2	2	3	3.44	2.21	-3.39	-2.18	0.052	0.03
3	3	4	2.36	1.68	-2.34	-1.67	0.020	0.01
4	4	5	2.22	1.59	-2.20	-1.58	0.019	0.01
5	5	6	2.14	1.55	-2.11	-1.52	0.038	0.03
6	6	7	1.10	0.53	-1.09	-0.52	0.002	0.01
7	7	8	0.89	0.42	-0.89	-0.42	0.005	0.00
8	8	9	0.69	0.32	-0.68	-0.32	0.004	0.00
9	9	10	0.62	0.30	-0.62	-0.29	0.004	0.00
10	10	11	0.56	0.27	-0.56	-0.27	0.001	0.00
11	11	12	0.52	0.24	-0.51	-0.24	0.001	0.00
12	12	13	0.45	0.21	-0.45	-0.21	0.003	0.00
13	13	14	0.39	0.17	-0.39	-0.17	0.001	0.00
14	14	15	0.27	0.09	-0.27	-0.09	0.000	0.00
15	15	16	0.21	0.08	-0.21	-0.08	0.000	0.00
16	16	17	0.15	0.06	-0.15	-0.06	0.000	0.00
17	17	18	0.09	0.04	-0.09	-0.04	0.000	0.00
18	2	19	0.36	0.16	-0.36	-0.16	0.000	0.00
19	19	20	0.27	0.12	-0.27	-0.12	0.001	0.00
20	20	21	0.18	0.08	-0.18	-0.08	0.000	0.00
21	21	22	0.09	0.04	-0.09	-0.04	0.000	0.00
22	3	23	0.94	0.46	-0.94	-0.46	0.003	0.00
23	23	24	0.85	0.41	-0.84	-0.40	0.005	0.00
24	24	25	0.42	0.20	-0.42	-0.20	0.001	0.00
25	6	26	0.95	0.97	-0.95	-0.97	0.003	0.00
26	26	27	0.89	0.95	-0.88	-0.95	0.003	0.00
27	27	28	0.82	0.92	-0.81	-0.91	0.011	0.01
28	28	29	0.75	0.89	-0.75	-0.88	0.008	0.01
29	29	30	0.63	0.81	-0.62	-0.81	0.004	0.00
30	30	31	0.42	0.21	-0.42	-0.21	0.002	0.00
31	31	32	0.27	0.14	-0.27	-0.14	0.000	0.00
32	32	33	0.06	0.04	-0.06	-0.04	0.000	0.00

Total: 0.203 0.14

Converged in 0.37 seconds

```
=====
====
| System Summary |
=====
=====
```

How many? How much? P (MW) Q (MVA<sub>r</sub>)

```
-----
Buses 33 Total Gen Capacity 3267.0 -3267.0 to 3267.0
Generators 33 On-line Capacity 99.0 -99.0 to 99.0
Committed Gens 1 Generation (actual) 3.9 2.4
Loads 32 Load 3.7 2.3
Fixed 32 Fixed 3.7 2.3
Dispatchable 0 Dispatchable -0.0 of -0.0 -0.0
Shunts 0 Shunt (inj) -0.0 0.0
Branches 32 Losses (I2 * Z) 0.20 0.14
Transformers 0 Branch Charging (inj) - 0.0
Inter-ties 0 Total Inter-tie Flow 0.0 0.0
Areas 1
```

Minimum Maximum

```
-----
Voltage Magnitude 0.913 p.u. @ bus 18 1.000 p.u. @ bus 1
Voltage Angle -0.50 deg @ bus 18 0.50 deg @ bus 30
P Losses (I2*R) - 0.05 MW @ line 2-3
Q Losses (I2*X) - 0.03 MVAr @ line 5-6
```

```
=====
====
| Bus Data |
=====
=====
```

Bus Voltage Generation Load

# Mag(pu) Ang(deg) P (MW) Q (MVA<sub>r</sub>) P (MW) Q (MVA<sub>r</sub>)

```
-----
1 1.000 0.000* 3.92 2.44 - -
2 0.997 0.014 - - 0.10 0.06
3 0.983 0.096 - - 0.09 0.04
4 0.975 0.162 - - 0.12 0.08
5 0.968 0.228 - - 0.06 0.03
6 0.950 0.134 - - 0.06 0.02
7 0.946 -0.096 - - 0.20 0.10
8 0.941 -0.060 - - 0.20 0.10
9 0.935 -0.133 - - 0.06 0.02
10 0.929 -0.196 - - 0.06 0.02
11 0.928 -0.189 - - 0.04 0.03
12 0.927 -0.179 - - 0.06 0.04
13 0.921 -0.270 - - 0.06 0.04
```

14	0.918	-0.349	-	-	0.12	0.08
15	0.917	-0.386	-	-	0.06	0.01
16	0.916	-0.409	-	-	0.06	0.02
17	0.914	-0.487	-	-	0.06	0.02
18	0.913	-0.496	-	-	0.09	0.04
19	0.997	0.004	-	-	0.09	0.04
20	0.993	-0.063	-	-	0.09	0.04
21	0.992	-0.083	-	-	0.09	0.04
22	0.992	-0.103	-	-	0.09	0.04
23	0.979	0.065	-	-	0.09	0.05
24	0.973	-0.024	-	-	0.42	0.20
25	0.969	-0.067	-	-	0.42	0.20
26	0.948	0.173	-	-	0.06	0.03
27	0.945	0.229	-	-	0.06	0.03
28	0.934	0.312	-	-	0.06	0.02
29	0.926	0.390	-	-	0.12	0.07
30	0.922	0.496	-	-	0.20	0.60
31	0.918	0.411	-	-	0.15	0.07
32	0.917	0.388	-	-	0.21	0.10
33	0.917	0.380	-	-	0.06	0.04

-----

Total: 3.92 2.44 3.72 2.30

=====

====

| Branch Data |

=====

====

Brnch From To From Bus Injection To Bus Injection Loss ( $I^2 * Z$ )

# Bus Bus P (MW) Q (MVar) P (MW) Q (MVar) P (MW) Q (MVar)

-----

1	1	2	3.92	2.44	-3.91	-2.43	0.012	0.01
2	2	3	3.44	2.21	-3.39	-2.18	0.052	0.03
3	3	4	2.36	1.68	-2.34	-1.67	0.020	0.01
4	4	5	2.22	1.59	-2.20	-1.58	0.019	0.01
5	5	6	2.14	1.55	-2.11	-1.52	0.038	0.03
6	6	7	1.10	0.53	-1.09	-0.52	0.002	0.01
7	7	8	0.89	0.42	-0.89	-0.42	0.005	0.00
8	8	9	0.69	0.32	-0.68	-0.32	0.004	0.00
9	9	10	0.62	0.30	-0.62	-0.29	0.004	0.00
10	10	11	0.56	0.27	-0.56	-0.27	0.001	0.00
11	11	12	0.52	0.24	-0.51	-0.24	0.001	0.00
12	12	13	0.45	0.21	-0.45	-0.21	0.003	0.00
13	13	14	0.39	0.17	-0.39	-0.17	0.001	0.00
14	14	15	0.27	0.09	-0.27	-0.09	0.000	0.00
15	15	16	0.21	0.08	-0.21	-0.08	0.000	0.00
16	16	17	0.15	0.06	-0.15	-0.06	0.000	0.00
17	17	18	0.09	0.04	-0.09	-0.04	0.000	0.00
18	2	19	0.36	0.16	-0.36	-0.16	0.000	0.00

19	19	20	0.27	0.12	-0.27	-0.12	0.001	0.00
20	20	21	0.18	0.08	-0.18	-0.08	0.000	0.00
21	21	22	0.09	0.04	-0.09	-0.04	0.000	0.00
22	3	23	0.94	0.46	-0.94	-0.46	0.003	0.00
23	23	24	0.85	0.41	-0.84	-0.40	0.005	0.00
24	24	25	0.42	0.20	-0.42	-0.20	0.001	0.00
25	6	26	0.95	0.97	-0.95	-0.97	0.003	0.00
26	26	27	0.89	0.95	-0.88	-0.95	0.003	0.00
27	27	28	0.82	0.92	-0.81	-0.91	0.011	0.01
28	28	29	0.75	0.89	-0.75	-0.88	0.008	0.01
29	29	30	0.63	0.81	-0.62	-0.81	0.004	0.00
30	30	31	0.42	0.21	-0.42	-0.21	0.002	0.00
31	31	32	0.27	0.14	-0.27	-0.14	0.000	0.00
32	32	33	0.06	0.04	-0.06	-0.04	0.000	0.00

-----

Total: 0.203 0.14