

# Ecoinvent web-based tool for wastewater treatment inventories (WWinvent)

Lluís Corominas, George Ekama, Yves Comeau, Peter Vanrolleghem, Pascal Lesage

June 2018

## CONTENTS

1	Introduction .....	4
1.1	Objective of the ecoinvent wastewater tool.....	4
1.2	Scope of the tool .....	4
1.3	Wastewater treatment modelling.....	6
1.4	Using the tool .....	7
2	Description of the model.....	8
2.1	Influent fractionation .....	9
2.1.1	COD Influent fractionation .....	10
2.1.2	Nitrogen influent fractionation (in red what is an input; in green what is calculated) .....	12
2.1.3	Phosphorus influent fractionation .....	13
2.1.4	Suspended solids .....	13
2.1.5	Default fractionation factors for the industrial wastewater .....	14
2.2	Operating preferences (design choices) .....	15
2.2.1	Elementary flows (COD, N, P).....	15
2.2.2	Primary settling .....	16
2.2.3	BOD removal only.....	17
2.2.4	BOD removal and nitrification.....	17
2.2.5	BOD and N removal .....	18
2.2.6	Biological P removal .....	18
2.2.7	Chemical P removal .....	19
2.3	Other pollutants .....	28
2.4	Sludge composition .....	29
2.4.1	Primary sludge composition .....	29
2.4.2	Secondary sludge composition .....	29
2.4.3	Sludge composition of precipitate from chemical P removal .....	30
2.5	Energy consumption.....	30
2.5.1	Aeration energy consumption.....	31
2.5.2	Pumping energy consumption and mixing energy consumption .....	31
2.5.3	Dewatering .....	32
2.5.4	Other .....	32

2.6	Chemicals consumption .....	34
2.6.1	Chemicals for alkalinity control.....	34
2.6.2	Iron chloride for chemical P removal .....	34
2.6.3	Polyelectrolyte for thickening .....	35
3	Construction inventories.....	36
3.1	Large WWTP .....	36
3.1.1	Procedure followed to obtain a detailed construction inventory.....	36
3.1.2	Goal and scope definition .....	37
3.1.3	Inventory analysis.....	39
3.1.4	Small-medium WWTPs.....	39
3.1.5	Materials classification and grouping .....	41
3.1.6	Other assumptions .....	41
3.2	Sewer system .....	46
4	“Direct discharge of wastewater” dataset .....	46
4.1	Collected wastewater not connected to a WWTP .....	46
4.2	Combined sewer overflow wastewater .....	47
4.2.1	Sewer system .....	48
5	Uncertainty assessment .....	48
6	Calculation engine.....	49
7	WWTP mixes per regions .....	49
7.1	Country mixes.....	51
7.2	Global mix.....	55
7.3	User own mix.....	55
8	Using the web tool .....	55
8.1	Activity data entry page .....	55
8.2	Marginal approach calculation page.....	56
8.3	Reviewing, modifying and submitting the Spold files .....	59
8.3.1	Opening the datasets in ecoEditor .....	59
8.3.2	Adapting the datasets .....	60
8.3.3	Submitting the datasets .....	60
9	References.....	60

# 1 Introduction

## 1.1 Objective of the ecoinvent wastewater tool

Wastewater treatment is an activity that is often encountered in LCA: many activities generate wastewater, and, unless this wastewater is discharged without treatment to the environment or is treated onsite, a complete LCA needs to account for the burdens of transporting this wastewater in a sewer system and treating it in a wastewater treatment plant (WWTP). The ecoinvent database has multiple datasets covering the treatment of wastewater. However, these datasets are often insufficient for three reasons. First, the burdens of wastewater treatment depend directly on the composition of the wastewater. Second, the technologies used for wastewater treatment will also affect both the impacts of the treatment itself and the amount of pollutants that are not removed by the WWTP and ultimately discharged to the environment. Third, they do not account for the fraction of wastewater that is discharged to the sewer system but not connected to a WWTP, and hence directly discharged in the environment.

The “ecoinvent wastewater tool” (in this report, “tool” for short) aims to cover this gap:


- It can generate wastewater specific wastewater treatment inventories: the user need only inform the tool about the composition of the wastewater.
- It generates inventories for the treatment of this wastewater in a number of WWTP configurations that can be adapted to represent WWTP actually found in a region where the wastewater is discharged.
- It accounts for wastewater that is discharged to the sewer system but is not connected to a WWTP.

Of specific interest to ecoinvent data providers, it also generates ecoSpold files for these inventories, allowing the datasets to be submitted, via the [ecoEditor](#), to ecoinvent. This allows data providers who are submitting data on an activity to jointly submit the datasets for the treatment of the wastewater their activity generates.

## 1.2 Scope of the tool

The tool focuses on wastewater that is sent to the sewer system. It therefore excludes wastewater that is directly discharged to the environment by a transforming activity, which should be accounted for in the elementary flows of this activity. It also excludes the onsite treatment of wastewater, whose burdens should be included within the scope of the transforming activity.

The tool typically generates two datasets (see Figure 1). The first is a “no treatment” dataset, that accounts for the fraction of wastewater discharged to the sewer system but not treated in a WWTP (section 4.1), and for Combined Sewer Overflow (CSO) (section 4.2), which are discharges of wastewater to the environment due to episodes of overflow in the sewer system. The second is a treatment dataset that accounts for the treatment of the fraction of the wastewater that ultimately reaches the WWTP.



**Figure 1: Scope of the tool and the two datasets generally generated**

The system boundary of this tool includes the construction and the operation of the WWTP. With regards to operation, it accounts for elementary flows of untreated wastewater, combined sewer overflows and treated flows at the WWTP. In addition, it accounts for energy consumption for pumping, aeration and sludge thickening at a centrifuge. It also accounts for the consumption of most common chemicals used in WWTPs. Sludge treatment is out of the scope of this tool. Sludge from primary treatment and sludge from secondary treatment is quantified and well characterized, but their treatment is handled outside of this tool.

The tool can be used in four different contexts (Table 1), which differ on two aspects:

- Specific vs. average WWTP: If the user of the tool has knowledge on wastewater treatment technologies and also knows in which WWTP the wastewater will be treated, it is possible, via user-modifiable parameters, to model a specific WWTP. Most users, however, will not have this type of information, and will hence generate an average dataset, based on the installed wastewater treatment capacity in a region.
- Municipal vs. “specific activity” wastewater: The tool can generate datasets for both the treatment of average municipal wastewater and for the treatment of wastewater from a specific activity (henceforth “activity wastewater”) cotreated in a WWTP that is treating municipal wastewater. In both cases, the tool estimates the burdens of treating 1m<sup>3</sup> of the wastewater within the WWTP.

**Table 1: Four uses of the tool**


	<b>Wastewater from a specific activity</b>	<b>Average municipal wastewater</b>
Average WWT	Generate datasets that describe how a wastewater generated from	Generate datasets on the treatment of average municipal

	an activity will be treated on average. User supplies wastewater characteristics but does not need to supply any information on how the wastewater will be treated.	wastewater. User supplies wastewater characteristics but does not need to supply any information on how the wastewater will be treated.
Specific WWT	Generate datasets that describe how a wastewater generated from an activity will be treated in a specific WWTP. User supplies wastewater characteristics and information on the WWTP.	Generate datasets that describe the treatment of wastewater in a specific WWTP. User supplies wastewater characteristics and information on the WWTP.

### 1.3 Wastewater treatment modelling

The model behind the tool is based on internationally recognized process design guidelines rather than sampled data from a restricted number of WWTP (see Section 2). It therefore models plausible, but not actual, WWTP.

WWTP is a multifunctional process: it cotreats wastewater from multiple sources. The approach taken to allocate WWTP inputs and outputs to the wastewater of interest is ISO 14044's "step 2" approach: the partition reflects the way in which these inputs and outputs are changed by a quantitative change in the amount of treatment of the wastewater of interest. To achieve this, the model is run twice (Figure 2): once with just the municipal wastewater ( $Q_{ref}$ ), and once with the municipal wastewater and 1 m<sup>3</sup> of the activity wastewater ( $Q_{ref+act}$ ). Both runs generate a number of results (amount of sludge generated, electricity consumed, etc.), and the difference is calculated for all of these. For some modelled input or output X, the ratio  $(X_{ref+act} - X_{ref}) / (Q_{ref+act} - Q_{ref})$  reflects the way X is changed by the cotreatment of each m<sup>3</sup> of activity wastewater. While this approach is based on subdivision it is also coherent with a consequential approach (it reflects the consequence of cotreating the wastewater of interest). The tool output is therefore consistent with both an attributional and a consequential database.



**Figure 2: Graphical representation of the allocation approach**

For the treatment of municipal wastewater, where the composition of the reference wastewater and the wastewater of interest are the same, the same approach is used: the calculated  $(X_{\text{ref+act}} - X_{\text{ref}})/(Q_{\text{ref+act}} - Q_{\text{ref}})$  reflects the burdens of treating one additional m<sup>3</sup> of wastewater, which is taken to be representative of treating any m<sup>3</sup> of the wastewater. This is a simplification that may yield results different to those that a simple  $X_{\text{total}}/Q_{\text{total}}$  approach would yield.

## 1.4 Using the tool

The procedure for using the tool is described in detail in section 8. The main steps are as follows:

- The user must provide data on the wastewater to treat: its source (e.g. from steel production, average municipal), its properties (COD, temperature, etc.), the region where the water is discharged to the sewer system and the volume of water to treat.
- The user then specifies whether the dataset to generate should reflect a specific WWTP or an average for the selected region.
- If the user selects “specific WWTP”, then he must adapt the design parameters of the WWTP: included technologies, composition of the wastewater and design parameters
- If the user selects “average”, then a table with results per included WWTP is generated. The user can have an in-depth look at each WWTP model individually.
- The user then downloads ecoSpold files.
- These ecoSpold files are to be open in the ecoEditor, and fields needing adaptation should be revised (e.g. comment fields, uncertainty fields). Once the datasets are ready, they are simply submitted via the ecoEditor. Typically, these would be submitted at the same time as the datasets modelling the activity that generates the activity wastewater.

## 2 Description of the model

The model behind the tool is based on the activated sludge process guideline typically known as Metcalf and Eddy (Tchobanoglous et al., 2014). This is one of the most widely accepted guidelines for the wastewater treatment community. Activated sludge process design guidelines comprise a set of equations that computed in a sequential manner are used to quantify a number of design outputs as a function of design inputs. The design inputs include influent characteristics (e.g. flow, concentration of pollutants), operational settings (e.g. oxygen concentration in the biological reactor), safety factors, kinetic and stoichiometric parameters and effluent requirements (e.g. target ammonia concentration in the effluent of the WWTP). The design outputs comprise aerobic, anoxic, anaerobic volumes, dissolved oxygen demand; internal and external recycle flow-rates, settling areas and dosage of chemicals (external carbon source, metal salts, and alkalinity). This guideline follows a mechanistic approach which is a reduced/modified/simplified versions of the International Water Association (IWA) Activated Sludge Models (ASM) (Henze et al., 2000). The values of the design outputs have a direct link to the design inputs. For example, in some guidelines the biodegradable fraction is important for evaluating oxygen demand, process sludge production and aeration volume requirements. Also, the stricter effluent requirements and the higher level of safety will increase aerobic/anoxic volumes requirements, external/internal recycle rates and the oxygen demand. After all, design outputs will somehow determine characteristics (reactor configuration, blowers' capacity, pumping stations' size, storage tank volume) of the plant.




Figure 3. Activated sludge modeling approach

The following technologies are modelled according to the Metcalf and Eddy design equations. The correspondence with the latest version of the 2014 edition is provided in the following table.



**Table 2. Technologies included and their exact reference in Tchobanoglous et al. (2014). \* the example of Metcalf and Eddy is for pre-precipitation, but we have applied for co-precipitation.**

	Metcalf and Eddy chapter	Example (initial page)
BOD removal only	Chapter 8-6	756
BOD and nitrification	Chapter 8-6	762
BOD and N removal	Chapter 8-7	810
Biological P removal	Chapter 8-8	880
Chemical P removal	chapter 6-4	484*

The proposed modelling approach is sensitive to different technologies, temperatures, pollutants loads, design practices in different countries and legal requirements for the pollutant loads in the effluent of the WWTP. In this report we explain how we extract the design equations from Tchobanoglous et al. (2014) and integrate into a tool which allows estimating inventories for LCA studies. For a deeper understanding of the design equations please refer to Tchobanoglous et al. (2014). The tool is transparent in the sense that the user can have access to the actual implementation of the equations.

## 2.1 Influent fractionation

All measurements used as inputs to the model have to be translated into model variables and some model outputs need to be converted into variables, which can be compared with measurements of the real system. The wastewater influent needs to be characterized following a model-specific fractionation procedure to convert measurements into model state-variables.

Metcalf and Eddy design guidelines work with the following model state-variables: sCOD (soluble or filtered COD), bCOD (biodegradable COD), rbCOD (readily biodegradable COD), BOD (biochemical oxygen demand), sBOD (soluble BOD), VFA (Volatile Fatty Acids), VSS (volatile suspended solids), TSS (total suspended solids), NH<sub>4</sub> (ammonium), PO<sub>4</sub> (phosphate), and Alkalinity.

In order to convert measurements into these Metcalf and Eddy variables we will first conduct the detailed influent fractionation typical from the ASM-family models; then, the fractions obtained from these detailed fractionation will be combined to obtain the Metcalf and Eddy variables.

### 2.1.1 COD Influent fractionation

COD					COD					
bCOD				nbCOD	sCOD			pCOD		
bsCOD (readily biodg)		bpCOD (slow biodg)		nbsCOD (=sCODe)	nbpCOD	bsCOD (readily biodg)		nbsCOD (=sCODe)	bpCOD (slow biodg)	nbpCOD
Complex	VFA	Colloidal	Particulate			Complex	VFA		Colloidal	Particulate

**Figure 4. COD fractionation. b:biodegradable; nb: non-biodegradable; s:soluble; p:particulate;**

#### A) Detailed fractionation

The fractionation proposed according to most recent literature subdivides total COD fractions as CSU (unbiodegradable organic matter), SB (Soluble (rapidly) biodegradable matter), CB (Slowly biodegradable colloidal matter), XB (Particulate biodegradable organics), XH (organisms) and XU (Particulate unbiodegradable organics). Average typical ratios provided for raw municipal wastewater are provided below (taken from BioWin simulation platform).

According to Influent Specifier (BioWin)				Total COD fractions								
Raw municipal WW				Avg typical ratios								
Avg ratios				so,		so,		so,				
0,15	0,85	S <sub>VFA</sub>	C <sub>S<sub>U</sub></sub>	0,05	0,38	0,05	0,05	0,024	0,136			
		S <sub>F</sub>	S <sub>B</sub>	0,16						0,64	0,17	0,17
0,25			C <sub>B</sub>	0,47	0,47	0,47	0,02	0,02				
0,75		X <sub>B,H</sub>	X <sub>B</sub>						0,13	0,13	1,00	1,00
			X <sub>H</sub>									
			X <sub>U</sub>									

Hence, during the detailed fractionation the following variables are calculated:

$$\begin{aligned}
 CS_U &= f_{CSU\_COD} * COD; \\
 S_{VFA} &= f_{SB\_COD} * f_{VFA\_SB} * COD; \\
 S_F &= f_{SB\_COD} * COD - S_{VFA}; \\
 C_B &= (1 - f_{XB\_XCB}) * f_{XCB\_COD} * COD; \\
 X_B &= f_{XB\_XCB} * f_{XCB\_COD} * COD; \\
 X_H &= f_{XH\_XCOD} * COD; \\
 X_U &= f_{XU\_COD} * COD; \\
 X\_COD &= X_B + X_H + X_U; \\
 CS_B &= C_B + S_{VFA} + S_F; \\
 X_{BH} &= X_B + X_H;
 \end{aligned}$$

## B) Metcalf and Eddy inputs

The following equations are needed to convert the detailed fractionation into Metcalf and eddy inputs. The factors in green are obtained as well from Biowin default fractionation.

$$\begin{aligned}
 sCOD &= CS\_U + S\_VFA + S\_F + C\_B; \\
 bCOD &= COD - X\_U - CS\_U; \\
 rbCOD &= S\_VFA + S\_F; \\
 BOD &= COD/f_{COD\_cBOD5}; \\
 sBOD &= sCOD/f_{COD\_cBOD5}; \\
 VFA &= S\_VFA; \\
 VSS &= X\_COD/f_{XCOD\_VSS}; \\
 TSS &= X_{lg} + VSS; \\
 NH4 &= f_{SNH4\_TKN} * TKN; \\
 PO4 &= f_{SPO4\_TP} * TP; \\
 Alkalinity &= S_{Alk};
 \end{aligned}$$

**Table 3. Typical values for raw municipal wastewater**

Symbol	Description	Units	Range	Avg value
$f_{COD\_cBOD5}$	COD to BOD5 ratio	g COD/g BOD5	1.9-2.2	2.04
$f_{SB\_COD}$	Rapidly biodegradable COD fraction	g COD/g COD	0.12-0.25	0.16
$f_{VFA\_SB}$	VFA fraction of the rapidly biodegrad. COD	g COD/g COD	0.0-0.3	0.15
$f_{XCB\_COD}$	Slowly biodegradable COD fraction	g COD/g COD	-	0.64
$f_{Xb\_XCB}$	Particulate fraction of the slowly biodegradable COD	g COD/g COD	-	0.73
$f_{XCOD\_VSS}$	Particulate COD to VSS ratio	g COD/g VSS	1.5-1.7	1.6
$f_{XU\_COD}$	Unbiodegradable particulate COD fraction	g COD/g COD	-	0.13
$X_{lg}$	Inorganic suspended solids	mg ISS/L	15-45	45
$f_{XH\_XCOD}$	Heterotrophic biomass fraction of the XCOD	g COD/g COD	-	0.02
$f_{CSU\_COD}$	Unbiodegradable filterable COD fraction	g COD/g COD	0.03-0.08	0.05
$f_{SNH4\_TKN}$	NH4 to NTK fraction	g N/g N	0.5-0.8	0.66
$f_{SPO4\_TP}$	o-PO4 over total P fraction	g P/g P	0.3-0.6	0.5
$S_{Alk}$	Alkalinity	meq/L	100	300

**Table 4. COD influent fractionation (in red what is an input ; in green what is calculated)**

Symbol	Description	Equation/Value
<b>COD</b>	Total chemical oxygen demand	Input
sCOD	soluble chemical oxygen demand	$= CS\_U + S\_VFA + S\_F + C\_B;$
BOD	Five day carbonaceous biochemical oxygen demand	$= COD/f_{COD\_cBOD5};$
sBOD	Soluble five day carbonaceous biochemical oxygen demand	$= sCOD/f_{COD\_cBOD5};$
bCOD	Biodegradable COD	$= COD - X\_U - CS\_U;$
rbCOD	Readily biodegradable COD	$= S\_VFA + S\_F;$
VFA	Volatile fatty acids	$= S\_VFA;$

Other fractions are needed to close the mass balances around the WWTP.

**Table 5. COD influent fractionation (continuation)**

Symbol	Description	Equation/Value
nbCOD	Non biodegradable COD	= COD - bCOD
nbsCODE	Non biodegradable soluble COD	= sCOD - (bCOD/BOD) x sBOD
nbpCOD	Non biodegradable particulate COD	= COD - bCOD - nbsCODE

### 2.1.2 Nitrogen influent fractionation (in red what is an input; in green what is calculated)

TKN				
NH <sub>4</sub>	ON			
	bON		nbON	
	bsON	bpON	nbsON	nbpON

**Figure 5. TKN fractionation. b:biodegradable; nb: non-biodegradable; s:soluble; p:particulate; ON: organic nitrogen;**

**Table 6. N influent fractionation**

Symbol		Equation/Value	Source/Comments
TKN	Nitrogen kjeldahl	Input	
NH <sub>4</sub>	Ammonia	Input	
ON	Organic nitrogen	TKN-NH <sub>4</sub>	
nbpON	Nonbiodegradable particulate organic nitrogen	nbpON = fN(nbVSS) ; fN=0.064 ;	0.064 taken from Metcalf & Eddy
nbsON	Nonbiodegradable soluble organic nitrogen	= 0.3 g/m <sup>3</sup> ;	0.3 taken from ASM2d
TKN_N2O	Nitrogen that is ultimately converted into N <sub>2</sub> O, expressed as a percentage of the influent TKN	TKN_N2O = fN2O X TKN; fN2O= 0.001 gN-N2O/gN-TKN	The range can be between 0.0001 and 0.112 according to Foley et al. (2015). Our default is 0.001;
bTKN	Biodegradable TKN available for nitrification	bTKN = TKN - nbpON – nbsON – TKN_N2O	This is the fraction of N used for nitrification. We assume 100% of bTKN is hydrolyzed to Ammonia.

### 2.1.3 Phosphorus influent fractionation

TP				
PO <sub>4</sub>	OP			
	bOP		nbOP	
	bsOP	bpOP	nbsOP	nbpOP

Figure 6. P fractionation. b:biodegradable; nb: non-biodegradable; s:soluble; p:particulate; OP: Organic Phosphorus

Table 7. Influent P fractionation (in red what is an input ; in green what is calculated)

Symbol	Description	Equation/Value	Source/Comments
TP	Total phosphorus	Input	
PO <sub>4</sub>	Phosphate	Input	
OP	Organic phosphorus	TP-PO <sub>4</sub>	
nbpOP		$nbpP = fP \cdot (nbVSS)$ ; $fP=0.015$ gP/gnbpVSS;	fP value taken from Tchobanoglous et al., 2014).
nbsOP		= 0 gP/m <sup>3</sup>	value provided by George Ekama
nbOP		= nbsOP + nbpOP	
aP		aP = TP-nbOP	

### 2.1.4 Suspended solids

TSS		
VSS		iTSS
nbVSS	bVSS	

Figure 7. Suspended solids fractionation

Table 8. Suspended solids fractionation equations

Symbol	Description	Equation/Value
TSS	Total suspended solids	input
VSS	Volatile suspended solids	input
iTSS	Inerts	$iTSS = TSS - VSS$
VSSCOD	Volatile suspended solids ratio	$= (TCOD - sCOD) / VSS$
nbVSS	non-biodegradable volatile suspended solids	$= nbpCOD / VSSCOD$

### **2.1.5 Default fractionation factors for the industrial wastewater**

There is limited information in the literature on the fractionation of industrial wastewater. As a preliminary approach we provide default fractions for four types of industrial wastewater:

- Type 1: Highly soluble - high degradability (Beverages industry wastewater)
- Type 2: Highly particulate - high degradability (pig manure)
- Type 3: Highly soluble - low degradability (tanning wastewater)
- Type 4: Highly particulate - low degradability (thermomechanical pulp and paper wastewater)

**Table 9. Default fractionation factors for different types of wastewater**

Symbol	Description	Units	Type 1	Type 2	Type 3	Type 4
$f_{\text{COD\_cBOD5}}$	COD to BOD5 ratio	g COD/g BOD5	1,71	3,0	2,2	2,50
$f_{\text{SB\_COD}}$	Rapidly biodegradable COD fraction	g COD/g COD	0,61	0,20	0,28	0,28
$f_{\text{VFA\_SB}}$	VFA fraction of the rapidly biodegrad. COD	g COD/g COD	0,55	0,30	0,00	0,00
$f_{\text{XCB\_COD}}$	Slowly biodegradable COD fraction	g COD/g COD	0,26	0,70	0,34	0,39
$f_{\text{XB\_XCB}}$	Particulate fraction of the slowly biodegradable COD	g COD/g COD	0,71	0,75	0,88	0,60
$f_{\text{XCOD\_VSS}}$	Particulate COD to VSS ratio	g COD/g VSS	1,51	1,48	1,37	2,18
$f_{\text{XU\_COD}}$	Unbiodegradable particulate COD fraction	g COD/g COD	0,09	0,05	0,05	0,29
$X_{\text{lg}}$	Inorganic suspended solids	mg ISS/L	100	6500	135	1315
$f_{\text{XH\_XCOD}}$	Heterotrophic biomass fraction of the XCOD	g COD/g COD	0,11	0,02	0,00	0,00
$f_{\text{CSU\_COD}}$	Unbiodegradable filterable COD fraction	g COD/g COD	0,04	0,05	0,33	0,04
$f_{\text{SNH4\_TKN}}$	NH4 to NTK fraction	g N/g N	0,10	0,55	0,0	0,57
$f_{\text{SPO4\_TP}}$	o-PO4 over total P fraction	g P/g P	0,93	0,18	0,0	0,00
$S_{\text{Alk}}$	Alkalinity	meq/L	3000	100	2,0	1100

## 2.2 Operating preferences (design choices)

Operating preferences are to be established before executing the design. Table 12 provides with a list of the operating preferences and their correspondence to the different modeled elements is provided.

### 2.2.1 Elementary flows (COD, N, P)

The inputs of the tool determine the mass of compounds (in kg/d) that enter the studied wastewater treatment system. Then, different equations are used to estimate how much of these compounds are discharged to the effluent water  $F_{j,\text{water}}$ , to the air  $F_{j,\text{air}}$  and as sludge  $F_{j,\text{sludge}}$ , where  $j$  is the element balanced (COD, N or P).

COD balance: For organic matter we provide the elementary flows based on COD (chemical oxygen demand). The following terms are needed to close the balance:

- Carbonaceous oxygen demand
- Load that is discharged into the effluent because it has not been degraded in the system (non biodegradable soluble compounds that leave the system as they enter), it is biodegradable but has not been degraded, or the COD content of the solids that do not settle
- COD that goes into sludge because of sludge production or because it is the nonbiodegradable particulate fraction (nbpCOD).

N balance:

- TKN and NO3 loads that are discharged into the effluent because they not been removed and the N content of the solids that do not settle

- N that goes into sludge because of sludge production or because it is the nonbiodegradable particulate fraction (nbpON).

P balance:

- $\text{PO}_4^{3-}$  load that is discharged into the effluent because it's not been degraded and the P content of the solids that do not settle
- P that goes into sludge because of sludge production or because it is the nonbiodegradable particulate fraction (nbpP).

Additionally, we provide equations to estimate the amount of  $\text{CO}_2$ ,  $\text{N}_2$  and  $\text{N}_2\text{O}$  emitted. We provide the users a verification that the mass balances close with an error smaller than 1%. This is provided in the tool in the results section.

### 2.2.2 Primary settling

Primary settlers are designed to allow particulate compounds from the wastewater to settle. They are the first stage of treatment after the removal of rags and grit in the inlet works. The settled sludge is removed by pump or gravity feed to a sludge treatment process. The most common situation is that primary settlers remove 2/3rd of the raw wastewater organic nitrogen (TKN minus ammonia) and 2/3rd of the raw wastewater organic phosphorus (TP minus OP) (Personal consultation with George Ekama). The primary settler removes as well part of the inert inorganics from the raw wastewater. Soluble compounds leave the primary settler as they enter. Still, the user of this tool can modify these removal efficiencies in the design parameters tab.

**Table 10. Primary settling parameters**

Wastewater fraction	Description	Value	Unit
removal_bpCOD	Removal efficiency of biodegradable particulate COD	40	%
removal_nbpCOD	Removal of non-biodegradable particulate COD	60	%
removal_ON	Removal efficiency of organic nitrogen	66.6	%
removal_OP	Removal efficiency of organic phosphorus	66.6	%
removal_iTSS	Removal efficiency of inerts inorganics	70	%



### 2.2.3 BOD removal only

A typical complete-mix activated sludge process for BOD removal is shown on Figure 8. Effluent from the primary settler and the recycled return activated sludge are introduced in the aerobic biological reactor. In the aerobic reactor oxygen is supplied to the system, and organic substrates can be oxidized by providing energy and a carbon source for the growth of heterotrophic bacteria.




Figure 8. BOD removal only technology scheme

Notes:

- For organic matter we provide the elementary flow based on COD; just one C balance based on COD. The BOD is included within the balance, but will not have a separate balance. In order to estimate the C content of COD we use as a default value of 3 g COD/g TOC; still, the user can change that factor in the tool.
- CO<sub>2</sub> balance includes the CO<sub>2</sub> from BOD oxidation (includes COD removal under aerobic and under anoxic conditions, with the assumption that yield in aerobic is same as anoxic) plus CO<sub>2</sub> from endogenous decay minus the CO<sub>2</sub> consumed by nitrifiers
- 1.42 is the conversion gCOD/gVSS (The conversion factor 1.42 is required to express the mass of microbial VSS in COD units, assuming the generally acknowledged empirical formula C<sub>5</sub>H<sub>7</sub>NO<sub>2</sub> for bacterial biomass (Metcalf and Eddy, 2014).
- COD air is the carbonaceous oxygen demand. It is needed for the COD mass balance, but is actually not an outcome for ecoinvent. The emission to air is in terms of CO<sub>2</sub> (COD plus oxygen is converted into CO<sub>2</sub> by the organisms). There is no real emission of COD to air, we just estimate it to close the mass balance.
- 3.6% of the CO<sub>2</sub> is assumed to be of non-biogenic origin (Law et al., 2013). The user can change this value if better estimates are available.

### 2.2.4 BOD removal and nitrification

The treatment goal is to remove organic matter and convert influent ammonia into nitrate. Besides heterotrophic bacteria in charge of removing organic substrates, in a BOD removal and nitrification system, sufficient sludge retention time is needed to ensure the growth of autotrophic bacteria. These can grow obtaining energy from ammonia and nitrite oxidation using bicarbonate as the carbon source. This process is called nitrification and occurs in two

steps: i) the aerobic oxidation of ammonium to nitrite by the ammonium oxidizer bacteria (AOB) and ii) the aerobic oxidation of nitrite into nitrate by the nitrite oxidizer bacteria (NOB).




Figure 9. BOD removal and nitrification technology scheme

### 2.2.5 BOD and N removal

The treatment goal is to remove organic matter and nitrogen. The selected configuration is a Modified Ludzack-Ettinger process (MLE). In MLE configurations, the initial contact of the influent wastewater and return activated sludge occurs in an anoxic zone (ANOX), which is followed by an aerobic zone (AER) (see process layout in Fig. 8). The process relies on the nitrate formed in the aerobic zone being returned via an internal recycle to the anoxic zone to be denitrified.





Figure 10. BOD removal and N removal technology scheme

### 2.2.6 Biological P removal

In the biological removal of phosphorus, the phosphorus in the influent wastewater is incorporated into cell biomass, which subsequently is removed from the process as a result of sludge wasting. Phosphorus accumulating organisms (PAOs) are encouraged to grow and consume phosphorus in systems that use a reactor configuration that provides PAOs with a

competitive advantage over other bacteria. An anaerobic tank is then needed, that is placed ahead of the activated sludge anoxic tank.



**Figure 11. Biological P removal technology scheme**

### 2.2.7 Chemical P removal

The chemical precipitation of phosphorus is brought about by the addition of the salts of multivalent metal ions that form precipitates of sparingly soluble phosphates. The multivalent metal ions used most commonly are calcium  $[Ca(2)]$ , aluminium  $[Al(3)]$  and iron  $[Fe(3)]$ . In this tool we implement co-precipitation, where the addition of chemicals to form precipitates that are removed along with waste biological sludge are added to (1) the effluent from primary sedimentation, (2) the mixed liquor (in the activated sludge process), or (3) the effluent from a biological treatment process before secondary sedimentation.

Table 11. Calculations needed before starting the design

Id	Description	Equation/Value	Source/notes
VSS <sub>e</sub>	WWTP Effluent volatile suspended solids (g/m <sup>3</sup> )	= TSS <sub>eff</sub> · 0.85	TSS <sub>eff</sub> : Average effluent TSS concentration (from 5 to 35 mg/L); 35 mg/L is the limit established by the directive 91/271 EU. This will be imposed in the design exercise; and from this one we will estimate VSS <sub>e</sub> . But to be on the safe side, we design for 25 mg TSS/L.
Q <sub>was</sub>	Wastage flow rate (m <sup>3</sup> /d)	$Q_w \left( \frac{m^3}{d} \right) = \frac{\frac{V_{reactor} \times MLSS}{SRT} - TSS_{eff} \times Q_{in}}{-1 \times TSS_{eff} + TSS_{was}}$ <p>V in m<sup>3</sup>, MLSS in g/m<sup>3</sup>, SRT in days, TSS in g/m<sup>3</sup>, Q in m<sup>3</sup>/d</p>	<p>Typical equation of SRT calculation (see metcalf and eddy)</p> <p>V<sub>reactor</sub> is the total volume of biological reactor. SRT is different depending on the technology. For BOD removal only, the SRT is an input (e.g. 5 days). For technologies involving nitrification, the SRT is estimated during the design process.</p>
Q <sub>in</sub>	Influent flow (m <sup>3</sup> /d)		
Q <sub>e</sub>	Effluent flow (m <sup>3</sup> /d)	Q <sub>e</sub> =Q <sub>in</sub> -Q <sub>was</sub>	

**Table 12. Design choices. (columns indicate whether that particular input is required for a particular technology)**

Symbol	Description	unit	CSO	1ary settl	BOD only	BOD + NH4	BOD + N	ChemP or BioP
NH4eff	Effluent ammonia target	g N/m <sup>3</sup>				X	X	
NO3eff	Effluent nitrate target	g N/m <sup>3</sup>					X	
PO4eff	Effluent phosphate target	g P/m <sup>3</sup>						X
CSO_particulate	Fraction of particulates that are discharged with the combined sewer overflows	%	X					
CSO_soluble	Fraction of particulates that are discharged with the combined sewer overflows	%	X					
removal_bpCOD	Percentage removal of bpCOD during primary settling	%		X				
removal_nbpCOD	Percentage removal of nbpCOD during primary settling	%		X				
removal_ON	Percentage removal of ON during primary settling	%		X				
removal_OP	Percentage removal of OP during primary settling	%		X				
removal_iTSS	Percentage removal of iTSS during primary settling	%		X				
MLSS_X_TSS	Design mixed liquor suspended solids	g/m <sup>3</sup>			X	X	X	
DO	Dissolved oxygen concentration in biological aerobic reactor	g/m <sup>3</sup> as O <sub>2</sub>			X	X	X	
clarifiers	Number of clarifiers	clarifiers			X	X	X	
sBODe	soluble BOD in the effluent	g/m <sup>3</sup> as O <sub>2</sub>			X	X	X	
TSSe	Total suspended solids in the effluent	g/m <sup>3</sup>			X	X	X	
zb	Site elevation above sea level	m			X	X	X	
Pressure	Pressure at site elevation	Pa			X	X	X	
Df	Liquid depth above diffusers in biological reactor	m			X	X	X	
h_settler	Height of settler	m			X	X	X	
X_R	Return sludge mass concentration	g/m <sup>3</sup>			X	X	X	
SRT	Sludge Retention Time	d			X			
SOR	Hydraulic application rate for secondary settler	m <sup>3</sup> /m <sup>2</sup> ·d			X	X	X	
SF	Peak to average TKN load	∅			X	X	X	
Anoxic_mixing_energy	Mixing energy for anoxic reactor	kW/1000 m <sup>3</sup>					X	
FeCl3_solution	Ferric chloride solution	%						X
FeCl3_unit_weight	Ferric chloride unit weight	kg/L						X
days	Time of storage of the ferric chloride	d						X
influent_H	Influent pumping water lift height	m			X	X	X	

**Table 13. List of model parameters with their default values**

Symbol	Description	Value	Units
<i>Elementary composition of sludge</i>			
	COD content of biological sludge	1.42	g COD/g VSS
	N content of biological sludge	0.12	g N /g VSS
	P content of biological sludge	0.015	g P/g VSS
<i>Physics (universal)</i>			
Pa	standard pressure at sea level	10.33	m
R	ideal gases constant	8314	kg*m2/s2*kmol*K*1000
g	gravity	9.81	m/s2
M	air molecular weight	28.97	g/mol
M_Fe	Fe molecular weight	55.845	g/mol
M_P	P molecular weight	30.974	g/mol
<i>Kinetic coefficients heterotrophs</i>			
<i>Table 8-14, page 755 of Tchobanoglous (2014)</i>			
$k_S$	Semisaturation constant of heterotrophic growth on COD	8	g_bCOD/m3
$Y_H$	Heterotrophic growth yield	0.45	g_VSS/g_bCOD
$b_H$	Heterotrophic organisms decay rate	0.12	1/d
$f_d$	Fraction of biomass contributing to biomass debris	0.15	unitless
<i>Kinetic coefficients nitrifiers</i>			
<i>Table 8-14, page 755 of Tchobanoglous (2014)</i>			
$\mu_{n,AOB,max}$	Maximum growth rate of AOB organisms	0.9	1/d
$K_{NH_4}$	Semisaturation constant of AOB growth on ammonia	0.5	g NH4-N/m3
$Y_N$	AOB growth yield	0.15	g VSS/g NH4-N
$b_{AOB}$	Autotrophic organisms decay rate	0.17	1/d
$K_{O,AOB}$	Semisaturation constant of AOB growth on oxygen	0.50	g O2/m3
<i>Aeration-related</i>			
C_s_20	sat DO at sea level at 20°C	9.09	g/m3
F	fouling factor	0.90	-
de	mid-depth correction factor	0.40	(range: 0.25 - 0.45)
E	oxygen transfer efficiency	0.35	

**Table 14. Calculation of sludge production (the excess sludge calculation with chemical addition is explained in the chemical P removal section); In the case of the technology BOD removal only, the SRT is an input;  $P_{x,bio}$  is  $P_{x,bio, OHO}$  for the technology BOD removal only, and  $P_{x,bio, OHO\&AOB}$  for the technologies that involve nitrification**

Symbol	Description	Equation
$b_{H,T}$	Heterotrophic organisms decay rate corrected by temperature	$b_{H,T} = b_H \times \theta^{T-20}$
$b_{AOB,T}$	Autotrophic organisms decay rate corrected by temperature	$b_{AOB,T} = b_{AOB} \times \theta^{T-20}$
$\mu_{n,AOB}$		$\mu_{n,AOB} = \left( \frac{\mu_{n,AOB,max}}{K_{NH4} + NH4_{eff}} \right) \left( \frac{DO}{K_{O,AOB} + DO} \right)$
$\mu_{n,AOB,T}$	Specific growth rate of nitrifiers	$\mu_{n,AOB,T} = \mu_{n,AOB} \times \theta^{T-20}$
$SRT$	Sludge retention time	$SRT = \frac{1}{\mu_{n,AOB,T}}$
$P_{x,bio\_OHO}$ (Kg/d)	Biomass sludge production in VSS units (heterotrophic organisms growth)	$P_{x,bio, OHO} (VSS) = \frac{Q_{in}Y_H(S_0 - S)}{1 + b_{H,T}(SRT)} + \frac{(f_d)(b_{H,T})Q_{in}(S_0 - S)SRT}{1 + b_{H,T}(SRT)}$
$P_{x,bio\_OHO\&AOB}$ (Kg/d)	Biomass sludge production in VSS units (heterotrophic and nitrifier organisms growth)	$P_{x,bio, OHO\&AOB} (VSS) = \frac{Q_{in}Y_H(S_0 - S)}{1 + b_{H,T}(SRT)} + \frac{(f_d)(b_{H,T})Q_{in}(S_0 - S)SRT}{1 + b_{H,T}(SRT)} + \frac{Q_{in}Y_N(NOx)}{1 + b_{AOB,T}(SRT)}$
$P_{x,VSS}$ (Kg/d)	Sludge production in VSS units (biomass and non-biodegradable VSS)	$P_{x,VSS} = P_{x,bio} + Q_{in} \times nbVSS$
$P_{x,TSS}$ (Kg/d)	Total sludge production in TSS units (inerts from the influent included as well)	$P_{x,TSS} = \frac{P_{x,bio}}{0.85} + Q_{in}(nbVSS) + Q_{in}(iTSS)$

Table 15. Water air and sludge composition for the “BOD removal only” technology; we assume NOx is NO3-. [Comment 1]: The first term summed in is the direct oxidation of influent bCOD, while the second term is the endogenous respiration of microbial biomass. 3.6% of the CO2 is assumed to be of non-biogenic origin (Law et al., 2013), and is accounted in the GHG emissions.

	Water (effluent) (g/d)	Air (g/d)	Sludge (g/d)
COD	$F_{COD,water} \left( \frac{g}{d} \right) = Q_{in} \times sCOD_e + Q_e \times VSS_e \times 1.42$ $sCOD_e \left( \frac{g}{m^3} \right) = nb sCOD + \frac{k_s(1 + b_{H,T} \times SRT)}{SRT(Y_H - b_{H,T}) - 1}$	$F_{COD,O_2demand} \left( \frac{g}{d} \right) = Q_{in} \times (S_0 - S) - 1.42 \times Px_{bio, OHO} \times 1000 \text{ (g/1kg)}$	$F_{COD,sludge} \left( \frac{g}{d} \right) = A + B - C$ $A = Px_{bio, OHO} \times 1.42 \times 1000 \text{ (g/1kg)}$ $B = Q_{in} \times nb pCOD$ $C = Q_e \times VSS_e \times 1.42$
CO2	-	$F_{CO_2,air} \left( \frac{g}{d} \right) = k_{CO_2/COD} \times Q_{in} \times (1 - Y_H) \times (S_0 - S) + k_{CO_2/biomass} \times \frac{(1-f_d)(b_{H,T})Q_{in}(S_0-S)SRT}{1+b_{H,T}(SRT)}$ <p>[Comment 1]</p>	-
TKN	$F_{TKN,water} \left( \frac{g}{d} \right) = Q_{in} \times (TKN_{in} - nb pON) + Q_e \times VSS_e \times 0.12 - (0.12 \times Px_{bio, OHO} \times 1000)$	-	$F_{TKN,sludge} = A + B - C$ $A = 0.12 \times Px_{bio} \times 1000 \text{ (g/1kg)};$ $B = Q_{in} \times nb pON$ $C = Q_e \times VSS_e \times 0.12$
NOx	-	-	-
N2	-	-	-
N2O	-	-	-
TP	$F_{TP,water} \left( \frac{g}{d} \right) = (Q_{in} \times PO4_e) + (Q_e \times VSS_e \times 0.015)$ $PO4_e \left( \frac{g}{m^3} \right) = aP - P_{synthesis}$ $P_{synthesis} = 0.015 \times Px_{bio, OHO} \times 1000 \text{ (g/1kg)}$	-	$F_{TP,sludge} = A + B - C$ $A = 0.015 \times P_{x,bio} \times 1000 \text{ (g/1kg)}$ $B = Q_{in} \times nb pP$ $C = Q_e \times VSS_e \times 0.015$



**Table 16. BOD removal and nitrification**

	Water (effluent) (g/d)	Air (g/d)	Sludge (g/d)
COD	$F_{COD,water} \left( \frac{g}{d} \right) = Q_{in} \times sCOD_e + Q_e \times VSS_e \times 1.42$ $sCOD_e \left( \frac{g}{m^3} \right) = nbsCOD + \frac{k_s(1 + b_{H,T} \times SRT)}{SRT(Y_H - b_{H,T}) - 1}$	$F_{COD,O_2demand} \left( \frac{g}{d} \right) = Q_{in} \times (S_0 - S) - 1.42$ $\times Px, bio, OHO\&AOB \times 1000 \left( \frac{g}{1kg} \right)$ $+ 4.57 \times \frac{F_{NOx,water}}{Q_e}$	$F_{COD,sludge} \left( \frac{g}{d} \right) = A + B - C$ $A = Px, bio, OHO\&AOB \times 1.42$ $\times 1000 (g/1kg)$ $B = Q_{in} \times nbpCOD$ $C = Q_e \times VSS_e \times 1.42$
CO2	-	$F_{CO2,air} \left( \frac{g}{d} \right) = k_{CO2/COD} \times Q_{in} \times (1 - Y_H) \times (S_0 - S) +$ $k_{CO2/biomass} \times \frac{(1-f_d)(b_{H,T})Q_{in}(S_0-S)SRT}{1+b_{H,T}(SRT)} - 4.49 \frac{gCO_2}{gN\ nitrified} \times$ $F_{NOx,water}$	
TKN	$F_{TKN,water} \left( \frac{g}{d} \right) = Q_e \times (NH_{4eff} + VSS_e \times 0.12) + Q_{in}$ $\times (nbsON)$	-	$F_{TKN,sludge} = A + B - C$ $A = 0.12 \times Px, bio \times 1000 (g/1kg);$ $B = Q_{in} \times nbpON$ $C = Q_e \times VSS_e \times 0.12$
NOx	$F_{NOx,water} \left( \frac{g}{d} \right) = Q_{in} \times bTKN - Q_e \times NH_{4,eff} - 0.12$ $\times Px, bio, OHO\&AOB \times 1000 (g/1kg)$	-	$Q_{was} \times \frac{F_{NOx,water}}{Q_e}$
N2	-	-	-
N2O	-	$F_{N2O,air} = Q_{in} \times TKN_{N2O}$	-
TP	$F_{TP,water} \left( \frac{g}{d} \right) = (Q_{in} \times PO_{4e}) + (Q_e \times VSS_e \times 0.015)$ $PO_{4e} \left( \frac{g}{m^3} \right) = aP - P_{synthesis}$ $P_{synthesis} = 0.015 \times Px, bio, OHO\&AOB \times 1000 (g/1kg)$	-	$F_{TP,sludge} = A + B - C$ $A = 0.015 \times P_{x,bio} \times 1000 (g/1kg)$ $B = Q_{in} \times nbpP$ $C = Q_e \times VSS_e \times 0.015$

**Table 17. BOD and N removal.  $NOx_e$  is imposed by design input.  $NOx_{nitri}$  is the nitrate concentration in the effluent obtained from the nitrification design exercise (prior to denitrification).**

	Water (effluent) (g/d)	Air (g/d)	Sludge (g/d)
COD	$F_{COD,water} \left( \frac{g}{d} \right) = Q_{in} \times sCOD_e + Q_e \times VSS_e \times 1.42$ $sCOD_e \left( \frac{g}{m^3} \right) = nbsCOD + \frac{k_s(1 + b_{H,T} \times SRT)}{SRT(Y_H - b_{H,T}) - 1}$	$F_{COD,o2demand} \left( \frac{g}{d} \right) = Q_{in} \times (S_0 - S) - 1.42 \times$ $Px_{bio, OHO\&AOB} \times 1000 \left( \frac{g}{1kg} \right) + 4.57 \times \frac{F_{NOx,water}}{Q_e} -$ $2.86 \times Q_e \times (NOx_{nitri} - NOx_e)$	$F_{COD,sludge} \left( \frac{g}{d} \right) = A + B - C$ $A = Px_{bio, OHO\&AOB} \times 1.42 \times 1000 (g/1kg)$ $B = Q_{in} \times nbpCOD$ $C = Q_e \times VSS_e \times 1.42$
CO2	-	$F_{CO2,air} \left( \frac{g}{d} \right) = k_{CO2/COD} \times Q_{in} \times (1 - Y_H) \times (S_0 - S) +$ $k_{CO2/biomass} \times \frac{(1-f_d)(b_{H,T})Q_{in}(S_0-S)SRT}{1+b_{H,T}(SRT)} - 4.49 \frac{gCO2}{gN \text{ nitrified}} \times$ $F_{NOx,water}$	
TKN	$F_{TKN,water} \left( \frac{g}{d} \right) = Q_e \times (NH4_{eff} + VSS_e \times 0.12) + Q_{in}$ $\times (nbsON)$	-	$F_{TKN,sludge} = A + B - C$ $A = 0.12 \times Px_{bio} \times 1000 (g/1kg);$ $B = Q_{in} \times nbpON$ $C = Q_e \times VSS_e \times 0.12$
NOx	$F_{NOx,water} \left( \frac{g}{d} \right) = Q_e \times NOx_e$	-	$Q_{was} \times NOx_e$
N2	-	$F_{N2,air} \left( \frac{g}{d} \right) = Q_{in} \times (NOx_{nitri} - NOx_e)$	-
N2O	-	$F_{N2O,air} = Q_{in} \times TKN_{N2O}$	-
TP	$F_{TP,water} \left( \frac{g}{d} \right) = (Q_{in} \times PO4_e) + (Q_e \times VSS_e \times 0.015)$ $PO4_e \left( \frac{g}{m^3} \right) = aP - P_{synthesis}$ $P_{synthesis} = 0.015 \times Px_{bio, OHO\&AOB} \times 1000 (g/1kg)$	-	$F_{TP,sludge} = A + B - C$ $A = 0.015 \times P_{x,bio} \times 1000 (g/1kg)$ $B = Q_{in} \times nbpP$ $C = Q_e \times VSS_e \times 0.015$

**Table 18. Biological P removal.**  $f_{rbCOD/P}$  is obtained from the implementation of Figure 8-38 of Metcalf and Eddy.  $Px, bio$  refers either to  $Px, bio, OHO$  or  $Px, bio, OHO\&AOB$  depending if BioP removal is coupled to a BOD removal only system or to a BOD and nitrification or to a BOD and N removal system.  $f_{rbCOD/P}$  defines the required readily biodegradable COD to remove P biologically. This approach does not impose a  $PO_4$  concentration in the effluent, but imposes an accumulation of the available phosphate, limited by the availability of rbCOD.

TP	$F_{TP,water} \left( \frac{g}{d} \right) = (Q_e \times PO4_e) + (Q_e \times VSSe \times \left( \frac{PO4_{in} - PO4_e}{Px, vss} \right))$ $PO4_e = PO4_{in} - P_{EBPR} - P_{synthesis}$ $P_{EBPR} = \frac{\frac{rbCOD}{Q_{in}}}{f_{rbCOD/P}}$ $P_{synthesis} = 0.015 \times Px, bio \times 1000 \text{ (g/1kg)}$	-	$F_{TP,sludge} = A + B - C$ $A = P_{synthesis} + P_{EBPR}$ $B = Q_{in} \times nbpP$ $C = Q_e \times VSSe \times \left( \frac{PO4_{in} - PO4_e}{Px, vss} \right)$
----	--	---	--

**Table 19. Chem P removal.**

Chemical P removal	$F_{TP,water} \left( \frac{g}{d} \right) = (Q_e \times PO4_e) + (Q_e \times VSSe \times \left( \frac{PO4_{in} - PO4_e}{Px, vss} \right))$ <p><math>PO4_e</math> is imposed through the design inputs</p>		$F_{TP,sludge} = A + B - C$ $A = P_{synthesis} + (aPchem - PO4_e) \times Q_{in}$ $B = Q_{in} \times nbpP$ $C = Q_e \times VSSe \times \left( \frac{PO4_{in} - PO4_e}{Px, vss} \right)$ $aPchem = aP - P_{synthesis}$
--------------------	--	--	--

## 2.3 Other pollutants

The same metals (and other elements) and transfer functions to water, air and sludge applied in the tool developed previously by Ecoinvent (Doka 2007) have been applied in this tool.

**Table 20. Transfer coefficients of metals and other elements**

Element	Influent WW concentration (mg/L)	Transfer to air (%)	Transfer to fresh sludge (%)	Transfer to effluent water (%)
B	0	0,0%	50,0%	50,0%
Cl	0,03003122	0,0%	0,0%	100,0%
Br	0	0,0%	0,0%	100,0%
F	3,2769E-05	0,0%	0,0%	100,0%
I	0	0,0%	0,0%	100,0%
Ag	0	0,0%	75,0%	25,0%
As	0,0000009	0,0%	22,0%	78,0%
Ba	0	0,0%	95,0%	5,0%
Cd	2,8063E-07	0,0%	50,0%	50,0%
Co	1,6177E-06	0,0%	50,0%	50,0%
Cr	1,2232E-05	0,0%	50,0%	50,0%
Cu	3,7443E-05	0,0%	75,0%	25,0%
Hg	2,0004E-07	0,0%	70,0%	30,0%
Mn	0,000053	0,0%	50,0%	50,0%
Mo	9,5744E-07	0,0%	50,0%	50,0%
Ni	6,5891E-06	0,0%	40,0%	60,0%
Pb	8,6314E-06	0,0%	90,0%	10,0%
Sb	0	0,0%	50,0%	50,0%
Se	0	0,0%	50,0%	50,0%
Sn	0,0000034	0,0%	59,0%	41,0%
V	0	0,0%	50,0%	50,0%
Zn	0,00010935	0,0%	70,0%	30,0%
Be	0	0,0%	50,0%	50,0%
Sc	0	0,0%	50,0%	50,0%
Sr	0	0,0%	50,0%	50,0%
Ti	0	0,0%	50,0%	50,0%
Tl	0	0,0%	50,0%	50,0%
W	0	0,0%	50,0%	50,0%
Si	0,0031263	0,0%	95,0%	5,0%
Fe	0,00709277	0,0%	50,0%	50,0%
Ca	0,05083371	0,0%	10,0%	90,0%
Al	0,00103784	0,0%	95,0%	5,0%
K	0,0003989	0,0%	0,0%	100,0%
Mg	0,00570707	0,0%	10,0%	90,0%
Na	0,00218597	0,0%	0,0%	100,0%

## 2.4 Sludge composition

### 2.4.1 Primary sludge composition

The composition of primary sludge depends on the removal of the different fractions during primary settling. The following equations allow for the estimation of the composition of primary sludge.

Factors:

$$\begin{aligned}
 f_{CV\_nbp} &= VSS\_COD, & (g\_pCOD/g\_VSS) \\
 f_{CV\_bp} &= bpCOD\_bVSS & (g\_bpCOD/g\_bVSS) \\
 f_C &= 0.51, & (g\_C /g\_VSS) \\
 f_{N\_nbp} &= 0.12, & (g\_N /g\_VSS) \\
 f_{N\_bp} &= 0.06, & (g\_N /g\_VSS) \\
 f_{P\_nbp} &= 0.015, & (g\_P /g\_VSS) \\
 f_{P\_bp} &= 0.010, & (g\_P /g\_VSS) \\
 f_{O\_nbp} &= 16/18*(1 - f_{CV\_nbp}/8 - 8/12*f_C - 17/14*f_{N\_nbp} - 26/31*f_{P\_nbp}) & (g\_O/g\_VSS) \\
 f_{O\_bp} &= 16/18*(1 - f_{CV\_bp}/8 - 8/12*f_C - 17/14*f_{N\_bp} - 26/31*f_{P\_bp}) & (g\_O/g\_VSS) \\
 f_{H\_nbp} &= 2/18*(1 + f_{CV\_nbp} - 44/12*f_C + 10/14*f_{N\_nbp} - 71/31*f_{P\_nbp}) & (g\_H/g\_VSS) \\
 f_{H\_bp} &= 2/18*(1 + f_{CV\_bp} - 44/12*f_C + 10/14*f_{N\_bp} - 71/31*f_{P\_bp}) & (g\_H/g\_VSS)
 \end{aligned}$$

Sludge composition:

$$\begin{aligned}
 C\_content &= f_C * VSS\_removed & (kg/d) \\
 H\_content &= nbVSS\_removed*f_{H\_nbp} + bVSS\_removed*f_{H\_bp} & (kg/d) \\
 O\_content &= nbVSS\_removed*f_{O\_nbp} + bVSS\_removed*f_{O\_bp} & (kg/d) \\
 N\_content &= nbVSS\_removed*f_{N\_nbp} + bVSS\_removed*f_{N\_bp} & (kg/d) \\
 P\_content &= nbVSS\_removed*f_{P\_nbp} + bVSS\_removed*f_{P\_bp} & (kg/d)
 \end{aligned}$$

VSS\_removed and bVSS\_removed correspond to the sludge that is formed during primary settling.

Water content estimation. We assume that after centrifuges we have a total dry solids percentage of 25%. This means that 75% is water (by weight relations). Hence, if we have 786 kg TSS/d produced as primary sludge, then the water content (WC) is =  $786/25*75 = 2358$  kg water/d. This water is assumed to be recycled back to the influent of the WWTP.

### 2.4.2 Secondary sludge composition

Sludge production is estimated through the Metcalf & Eddy equations (see  $P_x$ , VSS calculated variable in section 2.3.1). Assuming the COD\_VSS ratio of 1.42, the composition in terms of C, H, O, N and P is calculated as follows:

If the COD/VSS ( $f_{CV}=1.42$ ), C/VSS ( $f_C=0.51$ ), N/VSS ( $f_N=0.12$ ) and P/VSS ( $f_P=0.015$ ) are known then the O/VSS ( $f_O$ ) And H/VSS ( $f_H$ ) can be calculated with the following equations:

$$f_O = 16/18 ( 1- f_{CV}/8 - 8/12 f_C - 17/14 f_N - 26/31 f_P )$$

$$f_H = 2/18 (1 + f_{CV} - 44/12 f_C + 10/14 f_N - 71/31 f_P)$$

So for  $f_{CV} = 1.42$ ;  $f_C = 0.51$ ,  $f_N = 0.12$  and  $f_P = 0.015$ , then  $f_O = 0.288$  and  $f_H = 0.067$ .

$f_C + f_H + f_O + f_N + f_P$  must be = to 1.000.

Overall:

$$C_{\text{content}} = P_{X\_VSS} * 0.51 \text{ (kg/d)}$$

$$H_{\text{content}} = P_{X\_VSS} * 0.067 \text{ (kg/d)}$$

$$O_{\text{content}} = P_{X\_VSS} * 0.288 \text{ (kg/d)}$$

$N_{\text{content}} = P_{X\_VSS} * 0.12$ ; 0.12 is the value provided by Metcalf & Eddy on the N content in sludge (kg/d)

$P_{\text{content}} = P_{X\_VSS} * 0.015$ ; 0.015 is the value provided by Metcalf & Eddy on the P content in sludge (kg/d)

Water content estimation. We assume that after centrifuges we have a total dry solids percentage of 25%. This means that 75% is water (by weight relations). Hence, if we have 786 kg TSS/d produced as primary sludge, then the water content (WC) is =  $786/25 * 75 = 2358$  kg water/d.

### 2.4.3 Sludge composition of precipitate from chemical P removal

Chemical P removal promotes the formation of extra sludge. The composition of that extra sludge depends on the amount of iron chloride added, and hence is estimated as follows.

Chemical	P	removal	process	variables	needed:
-	extra_iSS				(kg/d)
-	Fe_P_mole_ratio		(mole	Fe/mole	P)
Molecular	weights	of	Fe	and	P
- M_Fe	= 55.845;		//g/mol	(Fe molecular	weight)
-M_P	= 30.974;		//g/mol	(P molecular	weight)

Fractions:

$$Fe_{\text{content}} = \text{extra\_iSS} * M_{Fe} * Fe\_P\_mole\_ratio / (106.8 * Fe\_P\_mole\_ratio + 80);$$

$$H_{\text{content}} = \text{extra\_iSS} * (3 * Fe\_P\_mole\_ratio + 1) / (106.8 * Fe\_P\_mole\_ratio + 80);$$

$$P_{\text{content}} = \text{extra\_iSS} * M_P / (106.8 * Fe\_P\_mole\_ratio + 80);$$

$$O_{\text{content}} = \text{extra\_iSS} * 48 * (Fe\_P\_mole\_ratio + 1) / (106.8 * Fe\_P\_mole\_ratio + 80);$$

Notes: 106.8 is the molecular weight of iron chloride; 48 is the molecular weight of 3 oxygens

## 2.5 Energy consumption

Only electricity consumption for aeration, pumping, mixing, dewatering and other overhead uses are included. No other sources of energy (e.g. natural gas boiler) are considered. Other

than energy for sludge dewatering, energy consumed or produced during the treatment of sludge is also excluded.

### 2.5.1 Aeration energy consumption

Metcalf & Eddy provides equations to design the aeration capacity.

$R_0 = (Q \cdot (S_0 - S) / 1000 - 1.42 \cdot P_{X_{bio}}) / 24 + 0$ ; // kg<sub>O2</sub>/h note:

$C_T = \text{air\_solubility\_of\_oxygen}(T, 0)$ ; //mg<sub>O2</sub>/L -> elevation=0 TableE-1, Appendix E, implemented in "utils.js"

$P_b = P_a \cdot \text{Math.exp}(-g \cdot M \cdot (z_b - 0) / (R \cdot (273.15 + T)))$ ; //Pa -> pressure at plant site

$C_{inf\_20} = C_{s\_20} \cdot (1 + d_e \cdot D_f / P_a)$ ; //mg<sub>O2</sub>/L

$OTR_f = R_0$ ; //kgO<sub>2</sub>/h;  $OTR_f$  is calculated separately per each technology; as denitrification implies less consumption of Oxygen as part of the COD is removed anoxically by using NO<sub>3</sub><sup>-</sup> as electron acceptor.

$SOTR = (OTR_f / (\alpha \cdot F)) \cdot (C_{inf\_20} / (\beta \cdot C_T / C_{s\_20} \cdot P_b / P_a \cdot C_{inf\_20} - C_L)) \cdot (\text{Math.pow}(1.024, 20 - T))$ ; //kg/h

$kg\_O2\_per\_m3\_air = \text{density\_of\_air}(T, \text{Pressure}) \cdot 0.2318$  //oxygen in air by weight is 23.18%, by volume is 20.99%

$air\_flowrate = SOTR / (E \cdot 60 \cdot kg\_O2\_per\_m3\_air) \mid | 0$ ; //m<sup>3</sup>/min

However, Metcalf & eddy does not provide energy consumption calculations. We suggest a simplified approach that uses SOTR calculated from Metcalf & Eddy, and using typical ranges of Standard Aeration Energy (SAE). We assume that for Fine bubble systems SAE ranges between 3.6 and 4.8 kgO<sub>2</sub>/kWh, and we take 4 kgO<sub>2</sub>/kWh as a default value.

$$AE (kW) = \frac{SOTR \left( \frac{kgO_2}{h} \right)}{SAE \left( \frac{kgO_2}{kWh} \right)}$$

We can convert kW into kwh consumed per day (kWh/d) by multiplying AE\*24.

Overall, this approach results in a low energy consumption in the biological reactors of about 0.2 kWh·m<sup>-3</sup> of treated wastewater. This is at the lower end of typical ranges (hence we assume the designed WWTPs are well designed in terms of energy equipment), which are between 0.13 and 5.5 kWh·m<sup>-3</sup> (Enerwater, 2015).

### 2.5.2 Pumping energy consumption and mixing energy consumption

Pumping flows are calculated with the Metcalf and Eddy equations. Then, energy consumption factors (PE<sub>Qx</sub>) (obtained from Gernaey et al., 2014) are used per each type of pump including internal recirculation, external recirculation, wastage and mixing.

**Table 21. Pumping energy consumption**

Element	Equation	Factors
Internal recirculation	$Q_{int} * PE_{Q_{int}}$	$PE_{Q_{int}}$ : 0.004 kWh.m <sup>-3</sup> (Gernaey et al., 2014)
External recirculation	$Q_r * PE_{Q_r}$	$PE_{Q_r}$ : 0.008 kWh.m <sup>-3</sup> (Gernaey et al., 2014)
Wastage	$Q_{was} * PE_{Q_w}$	$PE_{Q_w}$ : 0.050 kWh.m <sup>-3</sup> (Gernaey et al., 2014)
Mixing	$PE_{mix} * V_{anoxic}$	$PE_{mix}$ is assumed to be 5 kwh/m <sup>3</sup> /d. $V_{anoxic}$ (m <sup>3</sup> ) is the volume of the anoxic reactor obtained during the design of the BOD and N removal technology
Influent pumping	$P \text{ (Watts)} = \rho \cdot g \cdot Q \cdot H$ , where: $\rho$ is density of water = 1000 kg/m <sup>3</sup> $g$ = gravitation constant = 9.81 m/s <sup>2</sup> $Q$ is flow in m <sup>3</sup> /s $H$ is water lift height and friction head in m.	We use a standard lift height of 10 m. User can change it if they have a better estimation. $P$ excludes losses in gear box and electrical inefficiency. So for electrical power consumption these losses increase the power consumption.

### 2.5.3 Dewatering

We use the multiplication factor 20 kWh/tDM sludge (Corominas et al., 2013).

Hence, DewE (kWh) =  $20 * P\_X\_TSS/1000$ ;

### 2.5.4 Other

We took data from different WWTPs (Stillwell et al., 2010).

**Table 22. Reference energy consumption data**

Volume of treated wastewater (m <sup>3</sup> /d)	3785	18927	37854	75708	189271
Lighting and buildings (kWh/d)	200	400	800	1200	2000
Pumping (kWh/d)	171	716	1402	2559	6030
Pre-treatment (kWh/d)	51	89	136	253	606
Primary (kWh/d)	15	78	155	310	776
Biological (kWh/d)	947	4718	9429	18637	46264
Sludge treatment (kWh/d)	6	243	4204	7194	16268
Total	1390	6244	16126	30153	71944

#### 2.5.4.1 Without primary treatment:

otherE (kWh/d) =  $0.0124 * \text{Flow} + 337.77$






Figure 12. energy consumption of WWTPs of different sizes excluding primary treatment

#### 1.1.1.1. With primary treatment:




Figure 13. Energy consumption of WWTPs of different sizes including primary treatment

$$\text{otherE (kWh/d)} = 0.0165 * \text{Flow} + 337.59$$

## 2.6 Chemicals consumption

We do not include a comprehensive list of chemicals that might be consumed in WWTPs, but provide empirical factors for the three most widely used ones: lime to maintain the pH, iron chloride for chemical P removal and polyelectrolyte for thickening sludge.

### 2.6.1 Chemicals for alkalinity control

Nitrification is pH-sensitive and rates decline significantly at pH values below 6.8. A pH of 7.0 to 7.2 is normally used to maintain reasonable nitrification rates, and for locations with low-alkalinity waters, alkalinity is added at the WWTP to maintain acceptable pH values. The amount of alkalinity added depends on the initial alkalinity concentration and amount of ammonia to be oxidized. Alkalinity may be added in the form of lime, soda ash, sodium bicarbonate, sodium carbonate, or magnesium hydroxide. In this tool we assume that the added chemical is sodium carbonate ( $\text{NaHCO}_3$ ) as this is the chemical available in the Ecoinvent database and is easy to handle in WWTPs.

$$\text{alkalinity\_used\_for\_nitrification (g CaCO}_3\text{/m}^3\text{)} = 7.14 \text{ (g CaCO}_3\text{/gN)} * \text{NOx (gN)}$$

where 7.14 (g  $\text{CaCO}_3$ /g $\text{NH}_4\text{-N}$  nitrified) is obtained from the following stoichiometric equation:  
 $\text{NH}_4^+ + 2\text{HCO}_3^- + 2\text{O}_2 \rightarrow \text{NO}_3^- + 2\text{CO}_2 + 3\text{H}_2\text{O}$

We assume that 70 g  $\text{CaCO}_3$ /m<sup>3</sup> is the residual alkalinity needed to maintain pH in the range 6.8-7.0. Hence, 70 equals influent alkalinity minus used alkalinity + alkalinity added.

$\text{alkalinity\_added (kg CaCO}_3\text{/d)} = (70 - \text{Alkalinity} + \text{alkalinity\_used\_for\_nitrification}) * Q / 1000$ ; where Q is the flow in m<sup>3</sup>/d.

In order to convert the alkalinity from  $\text{CaCO}_3$  to  $\text{NaHCO}_3$  we use the following equation:

$$\text{alkalinity\_added\_NaHCO}_3 \text{ (kg NaHCO}_3\text{/d)} = \text{alkalinity\_added} * (84 \text{ g NaHCO}_3 / 100 \text{ g CaCO}_3)$$

### 2.6.2 Iron chloride for chemical P removal

In this tool we implemented phosphate precipitation with iron. In the case of iron, 1 mole will precipitate 1 mole of phosphate; however, these reactions are competing with other reactions and dosages are established on the basis of bench-scale tests. Metcalf and Eddy includes in Figure 6-13 the Fe/P molar ratio required to achieve different effluent phosphate concentrations. We assume the precipitant is iron chloride 40%, which is available in Ecoinvent database.

**Table 23. Parameters for the chemical P model**

Parameter	Default value
Fe_P_mole_ratio	look-up table (Figure 6-13, pag 484 Tchobanoglous et al., 2014)
Raw_sludge_specific_gravity	1.03
Raw_sludge_moisture_content	94
Chemical_sludge_specific_gravity	1.05
Chemical_sludge_moisture_content	92.5

**Table 24. Model inputs for chem P removal.**

	Default values
FeCl3_solution	40%
FeCl3_unit_weight	1.35 Kg/L

Calculation of dosage of iron chloride to remove the available  $\text{PO}_4^{3-}$  ( $\text{PO}_4$  in the following equations, obtained after subtracting the influent  $\text{PO}_4^{3-}$  minus the  $\text{PO}_4^{3-}$  used for the growth of organisms). The user can select the target  $\text{PO}_4^{3-}$  concentration in the effluent ( $\text{PO}_4_{\text{eff}}$ ).

$$\text{Fe\_III\_dose} = \text{Fe\_P\_mole\_ratio} * (\text{PO}_4 - \text{PO}_4_{\text{eff}}) * \text{M\_Fe} / \text{M\_P}; \text{ (mg/L)}$$

$$\text{Fe\_dose} = Q * \text{Fe\_III\_dose} / 1000; \text{ (kg/d)}$$

$$\text{percent\_Fe\_in\_FeCl}_3 = 100 * \text{M\_Fe} / 162.3; \text{ (%)}$$

$$\text{amount\_FeCl}_3_{\text{solution}} = \text{Fe\_dose} / \text{percent\_Fe\_in\_FeCl}_3 * 100; \text{ (kg/d)}$$

$$\text{FeCl}_3_{\text{volume}} = \text{amount\_FeCl}_3_{\text{solution}} / (\text{FeCl}_3_{\text{solution}} / 100 * \text{FeCl}_3_{\text{unit\_weight}}) \text{ || } 0; \text{ (L/d)}$$

The storage volume of  $\text{FeCl}_3$  is calculated as follows:

$$\text{storage\_req\_15\_d} = \text{FeCl}_3_{\text{volume}} / 1000 * \text{days}; \text{ (m}^3\text{)}$$

There is an increase in the sludge production when adding iron chloride. This is as well calculated as follows.

$$\text{Fe\_dose\_M} = \text{Fe\_III\_dose} / 1000 / \text{M\_Fe}; \text{ (M (mol/L))}$$

$$\text{P\_removed} = (\text{PO}_4 - \text{PO}_4_{\text{eff}}) / 1000 / \text{M\_P}; \text{ (M(mol/L))}$$

$$\text{Fe}_{1.6}\text{H}_2\text{PO}_4\text{OH\_sludge} = \text{P\_removed} * 251 * 1000; \text{ //mg/L (251 is Fe}_{1.6}\text{H}_2\text{PO}_4\text{OH molecular weight)}$$

$$\text{Excess\_Fe\_added} = \text{Fe\_dose\_M} - 1.6 * \text{P\_removed}; \text{ (M (mol/L) )}$$

$$\text{FeOH}_3_{\text{sludge}} = \text{Excess\_Fe\_added} * (106.8) * 1000; \text{ (mg/L (106.8 is FeCl}_3\text{ molecular weight))}$$

$$\text{Excess\_sludge} = \text{FeH}_2\text{PO}_4\text{OH\_sludge} + \text{FeOH}_3_{\text{sludge}}; \text{ (mg/L)}$$

$$\text{Excess\_sludge\_kg} = Q * \text{Excess\_sludge} / 1000; \text{ (kg/d)}$$

(see the composition of excess sludge in section 2.5.3)

### 2.6.3 Polyelectrolyte for thickening (dewatering polymer)

Polyelectrolyte dosage per Ton of dry matter of sludge. We take the value obtained in Morera et al. (2017) from the WWTP of Girona, which is 10 kg polyelectrolyte/Tn DM. We assume the polyelectrolyte proxy in the Ecoinvent database is acrylamide.

### 3 Construction inventories

In this tool we propose to use the following range of WWTP sizes, based on population equivalents:


Class	Class 4	Class 3b	Class 3a	Class 2	Class 1
PE range	2,000-10,000	10,000-20,000	20,000-50,000	50,000-100,000	over 10,000
PE reference WWTP	8,750	18,750	44,153	100,000	206,250
Name reference WWTP	Navàs	Balaguer	Manlleu	L'Escala	Girona

We don't include the PE range of WWTPs smaller than 2000 PE. Such class would be better represented with a soft technology (wetlands or ponds) rather than a conventional activated sludge technology. In the following sections we explain how the construction inventories for the 5 reference WWTPs (1 large and 4 small to medium) were obtained.

#### 3.1 Large WWTP

##### 3.1.1 Procedure followed to obtain a detailed construction inventory

Detailed inventories for civil works includes the following steps (Figure 14): (1) Obtain the construction budget for the WWTP. In the budget, all elements needed for civil works (e.g., excavations, handrails, concrete, etc.) are listed, along with the price and the amount of each one. (2) Then, all these elements in the budget are identified and grouped in a simplified list (e.g., excavation of a representative type of soil, a representative type of concrete, etc.). (3) Once all elements of the budget are identified and grouped, it is necessary to search for equivalent elements in a specialized constructive database of reference (in our case the local database Banc BEDEC, which is used by constructors to make their budgets). This database provides all the necessary information about materials and energy consumed to build a unit of each element. (4) Finally, the material and energy inventories are calculated by relating the elements obtained from the construction budget to the equivalent elements of the reference database.



**Figure 14. Procedure followed to obtain the detailed inventory of the WWTP construction. Equipment is not included in this inventory.**

Five WWTP units were considered in the case study: (1) pumping + pretreatment, (2) primary treatment, (3) secondary treatment, (4) sludge line and deposition, and (5) buildings and services. Table 25 provides a description of the elementary processes considered for each operational unit considered in this work. The procedure was applied to obtain detailed inventories for each one of these units of the WWTP.

**Table 25. Description of all the unit processes included in each operation unit studied.**

<b>Operational unit</b>	<b>Elementary processes included</b>
<b>Pumping+pretreatment</b>	Wastewater well reception, pumping station, pretreatment building, part of the connections and part of the unit to dose chemicals
<b>Primary treatment</b>	Primary settlers, units to mix water and chemicals, chamber to measure the flow and part of the connections
<b>Secondary treatment</b>	Biological reactors, secondary settlers, chamber to measure the sludge sent to the sludge line, chamber to measure and pump the sludge sent back to the biological reactor, part of the unit to dose chemicals and part of the connections
<b>Sludge line and deposition</b>	Thickening tanks and buildings for the thickening tanks, chamber to pump the sludge, dewatering building, zone for the dewatered sludge, anaerobic digestion unit and part of connections, final sludge treatment in a composting plant
<b>Others</b>	Chemicals storage, control building, adaptation of the land and sidewalks

### 3.1.2 Goal and scope definition

The goal was to perform an LCA of the Girona WWTP, considering the construction of the plant (civil works), the operation and dismantling, and making an individual analysis for the five WWTP units. The functional unit of the study is 1 m<sup>3</sup> of treated wastewater assuming that the WWTP is working at full capacity. In fact, WWTPs are designed and constructed to serve a specific capacity. However, the treated flow does not always match with the design flow. We assumed the lifetime of the WWTP to be 30 years. The sensitivity of the lifetime of the WWTP on the LCA assessment is addressed in a sensitivity analysis. Salvage values for the equipment are considered when the life spans of the WWTP and of the equipment do not match.

The studied WWTP is located in Girona (Catalonia, NE of Spain). It treats the wastewater from the main city and different nearby towns located around the WWTP before the effluent is discharged into the Ter River. The plant has a capacity of 206,250 population equivalents (PE), which corresponds to a design flow rate of 55,000 m<sup>3</sup>·d<sup>-1</sup>. However, in the year 2013 the WWTP of Girona treated on average 42,000 m<sup>3</sup>·d<sup>-1</sup>. The water line consists of a Modified Ludzack-Ettinger (MLE) configuration with biological removal of organic matter and nitrogen and chemical removal of phosphorus. The sludge line consists of thickening, anaerobic sludge digestion with electricity production from the biogas, and sludge dewatering. The dewatered sludge is sent to a nearby composting plant. The composting plant is a private installation located 20 km away from the WWTP, and it treats not only the sludge from the WWTP but also other organic residues from other facilities. Figure 15 shows a scheme of the WWTP with a

separation of each analyzed operational unit and an indication of the operational data used to perform the LCA of the operation.




Figure 15. Layout of the WWTP of Girona.

Pumping and pretreatment includes five pumps, two channels that are 16 meters long, two sieves, screening and grease separation. Primary treatment has three primary settlers, each with a total capacity of 412 m<sup>3</sup>. Secondary treatment consists of three different reactors with a total capacity of 29,620 m<sup>3</sup> and three settlers, each with a capacity of 5,027 m<sup>3</sup>. The sludge line includes two thickeners of 16 m of diameter, two primary digesters with a 3,432 m<sup>3</sup> volume, two secondary digesters with an 814 m<sup>3</sup> volume, two dewatering devices and a cogeneration device.

The system boundaries (Figure 16) consider the WWTP's construction, operation and dismantling. The production of all materials (and their transport) and energy used to build the WWTP (civil works + equipment) are accounted. The dismantling is considered in this study for the most abundant materials for both civil works and equipment, assuming that concrete and reinforced concrete are disposed at a landfill for inert waste, 91% of metals are recycled (Sansom and Avery, 2014) and 25% of plastics are recycled, 34% of plastics are incinerated with electricity recovery and the rest disposed in a landfill (Plastics Europe, 2012). The construction of the composting plant is not within the system boundaries.




Figure 16. Elements included in the inventory. Equipment is available in the inventory of the paper Morera et al. (2017) but has not been included in the inventory of this ecoinvent tool.

### 3.1.3 Inventory analysis





The procedure described in section 3.1.1 has been applied to obtain the construction inventories of each of the five WWTP units in terms of materials and energy. Hence, for all WWTP stages (pre-treatment, primary treatment, secondary treatment, sludge line, buildings and services) we have accounted for materials and energy. A summary of the construction inventory can be found in Table 29. 45 different types of materials have been used in the construction of the WWTP of Girona (see Table S-1 from supporting information of Morera et al. (2017) for a complete material inventory). Even though Morera et al. (2017) included inventory of equipment materials, such inventory has not been included in this ecoinvent inventory analysis. Hence, equipment has not been accounted for in the inventories for these 4 WWTPs. Transports have been estimated considering the weight of the materials and assuming an average distance of 40 km.

### 3.1.4 Small-medium WWTPs

#### 3.1.4.1 Unit processes classification

The functional unit of the study is the construction of a WWTP. Four WWTPs with capacities ranging from 1,500 to 21,000 m<sup>3</sup>·d<sup>-1</sup> (Table 26) were chosen for inventory development. The WWTPs have similar configurations, employing an oxidation ditch to remove carbon and nitrogen and simple sludge treatment via thickening and dewatering. We assumed the lifetime of the WWTP to be 30 years.

**Table 26. Location, capacity and operation scheme of the studied WWTPs. Dark grey represents the pretreatment, black the biological reactor, light grey secondary settler and light grey with lines in diagonal represents the sludge treatment.**

Location (Region)	Capacity ( $\text{m}^3 \cdot \text{d}^{-1}$ )	Configuration
Navàs (Bagès)	1,500	
Balaguer (La Noguera)	3,750	
Manlleu (Osona)	14,400	
L'Escala (Alt Empordà)	21,000	

**Table 27. Specifications of the different WWTPs**

WWTP name	Navàs	Balaguer	Manlleu	L'Escala	Girona	Navàs
Capacity ( $\text{m}^3/\text{d}$ )	1500	3750	14400	21000	55000	1500
Capacity (PE)	8750	18750	44153	100000	206250	8750
Entrance load ( $\text{kgDBO}_5/\text{d}$ )	525	1125	5328	6300	12375	525
Entrance load TN ( $\text{kg N/d}$ )	112,5	356,25	576	1260	3190	112,5
Concrete volume in biological reactor ( $\text{m}^3$ )	542,366	859,468	2256,391	5002,596	7983,07	542,366

The construction inventories for the four plants were created by first obtaining the constructive budget of each plant. Next, the constructive budget database, Banc BEDEC (Barcelona, Spain), was used to estimate the materials and energy use associated with each budget item. The budget items and associated materials and energy use were categorized based on WWTP treatment elements including: pre-treatment, secondary treatment, sludge line, buildings, urbanization, tube connections and power station (Table 29). More information on this inventory development methodology can be found in Morera et al. (2017).

**Table 28. Elements considered in the budget that were included in the construction inventory.**

Elements	Sub-elements
Pre-Treatment	<ul style="list-style-type: none"> <li>- Receiving waters well</li> <li>- Pumping station</li> <li>- Screening</li> </ul>



	<ul style="list-style-type: none"> <li>- Grit removal</li> <li>- Degreasing operations</li> </ul>
Secondary Treatment	<ul style="list-style-type: none"> <li>- Biological reactor</li> <li>- Secondary settler</li> </ul>
Sludge Line	<ul style="list-style-type: none"> <li>- Thickener</li> <li>- Dewatering</li> </ul>
Buildings	<ul style="list-style-type: none"> <li>- Control and Services Buildings</li> <li>- Buildings that hold key elements</li> </ul>
Urbanization	<ul style="list-style-type: none"> <li>- Process of asphaltting inside the WWTP</li> <li>- Sidewalks construction</li> <li>- Construction of green zones</li> <li>- Placement of metallic fences around the WWTP</li> </ul>
Tube connections	<ul style="list-style-type: none"> <li>- Tube connections</li> </ul>
Power connections	<ul style="list-style-type: none"> <li>- Buildings that hold the electricity transformer</li> </ul>

An assumption made is that reactors were all partially buried leaving a height of 1.5 meters above ground. The soil that was excavated was assumed to be compact soil in all cases. Gravity thickening was assumed for all WWTPs.

### 3.1.5 Materials classification and grouping

A grouping of materials was applied to compare the mass of materials between inventories of this study and of Ecoinvent, selecting one material representative and summing up all masses of materials belonging to the same group. No grouping was applied though when calculating the environmental impacts out of the inventories, and hence all materials with their own characterization factors were applied.

### 3.1.6 Other assumptions

- Excavation process was calculated from the consumption of diesel needed for the machines to excavate the needed volume of soil.
- The electricity is generated on site by an electrical generator (current practice on-site, after personal communication with the construction company Voltes S.L.U).
- These inventories account for transport of the excess excavated soil to the landfill or the transport from the manufacturer to the workplace with a distance of 40 km each, assuming also the internal transports.
- Concrete category applied in the inventories is concrete with non-special requirements. Construction companies (e.g. Voltes S.L.U) that advised that the concrete used for the construction of WWTPs does not need any special requirements.

**Table 29. Inventory for the 5 WWTPs.**

name	ByProduct	unit	class 1	class 2	class 3a	class 3b	class 4
wastewater treatment facility, capacity class 2, between 50,000 and 100,000 PE	ReferenceProduct	unit	#N/A	1	#N/A	#N/A	#N/A
waste reinforced concrete	ByProduct	kg	53084935,5	31582121	17546484,7	5508866,78	2603344,81
waste polyvinylchloride product	ByProduct	kg	12204,7971	13047,18	92,255688	849,401226	680,266936
waste polyethylene/polypropylene product	ByProduct	kg	486555,197	58172,1	4266,51589	2875,29173	153,715969
waste glass sheet	ByProduct	kg	1267,804	1029,34	259,983463	60,375	1263,91333
waste mineral wool	ByProduct	kg	845,196	2359,469	#N/A	3,08555727	29,0983
waste brick	ByProduct	kg	1173911,38	1285803	274565,26	413417,297	219549,744
aluminium scrap, post-consumer	ByProduct	kg	788,0192	6949,085	649,67876	897,902222	365,293699
iron scrap, unsorted	ByProduct	kg	47511,6179	21889,8	50087,8161	7326,60395	12229,1549
inert waste	ByProduct	kg	129401140	75127265	70293102,2	11400662,7	6488091
diesel, burned in building machine	FromTechnosphere	MJ	12439793,5	9295006	6870733,36	1781618,55	1060124,61
concrete, normal	FromTechnosphere	m3	21463,2012	12788,22	7133,52646	2281,3295	1072,25446
reinforcing steel	FromTechnosphere	kg	1974539,45	1129912	560681,996	78290,9702	50626,669
steel, low-alloyed	FromTechnosphere	kg	54514,7151	32227,83	49977,2037	7997,57635	11104,548
wire drawing, steel	FromTechnosphere	kg	27977,1074	16253,55	8009,7428	1011,60899	752,531851
aluminium, primary, ingot	FromTechnosphere	kg	788,0192	6949,085	649,67876	897,902222	365,293699
anodising, aluminium sheet	FromTechnosphere	m2	394,0096	3474,542	324,83938	448,951111	182,646849
zinc coat, pieces	FromTechnosphere	m2	5791,22823	991,8919	17680,2066	2590,49151	2980,65379
steel, chromium steel 18/8	FromTechnosphere	kg	10205,523	2246,321	8120,35523	340,636586	884,738796
bronze	FromTechnosphere	kg	#N/A	8,666777	#N/A	1,96827532	0,85
copper	FromTechnosphere	kg	0,54	413,2127	#N/A	124,842966	54,7068508
wire drawing, copper	FromTechnosphere	kg	0,54	359,6877	#N/A	62,8950931	42,2244606
brass	FromTechnosphere	kg	#N/A	44,05651	3,62413643	107,844291	4,0244
cast iron	FromTechnosphere	kg	10768,4872	3669,2	#N/A	#N/A	992,4
enamelling	FromTechnosphere	m2	5384,24358	1834,6	#N/A	#N/A	496,2

polyvinylchloride, bulk polymerised	FromTechnosphere	kg	10984,3174	11742,47	83,0301192	764,461104	612,240242
polyvinylchloride, emulsion polymerised	FromTechnosphere	kg	1220,47971	1304,718	9,2255688	84,9401226	68,0266936
polypropylene, granulate	FromTechnosphere	kg	179,4576	720,5452	#N/A	71,508	#N/A
polyurethane, rigid foam	FromTechnosphere	kg	106,81459	53,08729	23,3042636	33,0111111	12,8865866
silicone product	FromTechnosphere	kg	4,21735	11,0036	6,38624354	9,14705556	2,82926848
synthetic rubber	FromTechnosphere	kg	12853,5183	658,5539	3481,48168	1793,2297	121,74914
polystyrene, expandable	FromTechnosphere	kg	#N/A	309,8135	#N/A	#N/A	#N/A
polyethylene terephthalate, granulate, amorphous	FromTechnosphere	kg	#N/A	264,9079	#N/A	0,33942667	0,97603913
polystyrene, extruded	FromTechnosphere	kg	1301,2734	2173,388	#N/A	181,251	6,384
polyethylene, high density, granulate	FromTechnosphere	kg	12358,2459	1959,884	761,72994	3,43889	3,43889
nylon 6-6	FromTechnosphere	kg	5,4532	2,994375	#N/A	0,7636	0,7636
glass fibre reinforced plastic, polyester resin, hand lay-up	FromTechnosphere	kg	459750,434	52028,92	#N/A	791,75	7,51771429
polystyrene, general purpose	FromTechnosphere	kg	#N/A	12,28193	#N/A	1,37386987	3,95063457
glued laminated timber, for outdoor use	FromTechnosphere	m3	26,5705726	8,77123	5,05272065	1,47170852	0,54389334
particle board, for outdoor use	FromTechnosphere	m3	44,5123969	77,76026	5,80742848	1,68096711	1,33699325
lime mortar	FromTechnosphere	kg	224840,88	359579,2	85796,2535	50481,951	34632,4669
cement mortar	FromTechnosphere	kg	327813,222	112097,3	19798,7272	32866,3951	38648,6343
adhesive mortar	FromTechnosphere	kg	11992,7724	70877,11	10123,3084	5982,01929	5526,32697
concrete, high exacting requirements	FromTechnosphere	m3	26,3104089	0,066129	#N/A	#N/A	#N/A
gypsum plasterboard	FromTechnosphere	kg	#N/A	5053,221	#N/A	1184,1984	336,2944
cover plaster, mineral	FromTechnosphere	kg	2,05	31182,77	702,9	2453,79912	4510,31622
concrete block	FromTechnosphere	kg	773923,321	563818,8	243071,014	307096,93	156394,762
lightweight concrete block, polystyrene	FromTechnosphere	kg	112589,382	128581,4	#N/A	22115,275	180,9
light clay brick	FromTechnosphere	kg	287398,675	588349,2	31494,246	83020,8939	62637,7874
sand	FromTechnosphere	kg	#N/A	1,07E+08	45996642,8	1886691,73	1036489,73
gravel, crushed	FromTechnosphere	kg	5342855,82	684521,6	6303028,75	1757460,13	226669,6

diesel	FromTechnosphere	kg	2656,15883	1697,211	684,689348	292,222584	80,38979
flat glass, coated	FromTechnosphere	kg	1267,804	1029,34	259,983463	60,375	1263,91333
alkyd paint, white, without water, in 60% solution state	FromTechnosphere	kg	51,832	27459,07	204,12	220,834	116,68
bitumen adhesive compound, hot	FromTechnosphere	kg	1554,332	52110,1	9778,92833	19993,8512	1171,8679
alkyd resin, long oil, without solvent, in 70% white spirit solution state	FromTechnosphere	kg	509,04981	236,1614	#N/A	#N/A	#N/A
solvent, organic	FromTechnosphere	kg	#N/A	181,68	#N/A	28,77	#N/A
mastic asphalt	FromTechnosphere	kg	1503,072	756,93	852,936	115,08	#N/A
stone wool	FromTechnosphere	kg	845,196	2359,469	#N/A	3,08555727	29,0983
sanitary ceramics	FromTechnosphere	kg	#N/A	256,1	#N/A	60,6	67,1
acrylic varnish, without water, in 87.5% solution state	FromTechnosphere	kg	#N/A	64,80621	#N/A	#N/A	2,6208
acrylic filler	FromTechnosphere	kg	#N/A	178,138	#N/A	48,384	#N/A
adhesive, for metal	FromTechnosphere	kg	200,658	0,071503	#N/A	#N/A	2,1504
printed paper	FromTechnosphere	kg	0,841456	30,17483	#N/A	1,69344	#N/A
natural stone plate, polished	FromTechnosphere	kg	#N/A	91526,4	235,584784	23013,6148	#N/A
polycarbonate	FromTechnosphere	kg	#N/A	0,012781	#N/A	#N/A	#N/A
compost	FromTechnosphere	kg	#N/A	17971,92	#N/A	#N/A	23491,279
expanded clay	FromTechnosphere	kg	#N/A	33230,89	#N/A	#N/A	#N/A
acrylonitrile-butadiene-styrene copolymer	FromTechnosphere	kg	#N/A	9,938051	#N/A	#N/A	#N/A
diesel, burned in diesel-electric generating set, 18.5kW	FromTechnosphere	MJ	74948,4461	181040	5022,95181	13135,2471	21450,7466
transport, freight, lorry >32 metric ton, EURO4	FromTechnosphere	metric ton*km	8665189,94	8288042	5745415,3	892914,863	405977,191
sheet rolling, steel	FromTechnosphere	kg	30921,1666	#N/A	2103,32221	856,876167	473,900883
impact extrusion of steel, cold, 5 strokes	FromTechnosphere	kg	26944,3733	#N/A	48619,4014	7602,28554	12180,129
injection moulding	FromTechnosphere	kg	648,098149	#N/A	3601,37588	2343,34991	567,426738
extrusion, plastic pipes	FromTechnosphere	kg	483924,103	#N/A	763,78194	1888,36336	273,33607
Water, unspecified natural origin	FromEnvironment	m3	378,837002	#N/A	32,5161808	595,494414	8,6566074

Transformation, from grassland, natural (non-use)	FromEnvironment	m2	49650	#N/A	16675	11730	1925
Occupation, construction site	FromEnvironment	m2*year	49650	#N/A	16675	#N/A	1925
Transformation, to industrial area	FromEnvironment	m2	45150	#N/A	10568	#N/A	#N/A
Transformation, to urban/industrial fallow (non-use)	FromEnvironment	m2	4500	#N/A	6107	#N/A	#N/A
Occupation, industrial area	FromEnvironment	m2*year	1354500	#N/A	317040	#N/A	#N/A
Occupation, urban/industrial fallow (non-use)	FromEnvironment	m2*year	135000	#N/A	183210	#N/A	#N/A
wastewater treatment facility, capacity class 3a, between 20,000 and 50,000 PE	ReferenceProduct	unit	#N/A	#N/A	1	#N/A	#N/A
butyl acrylate	FromTechnosphere	kg	0,8064	#N/A	0,6151938	#N/A	0,2016
epoxy resin, liquid	FromTechnosphere	kg	812,6976	#N/A	0,8928	42,8517278	47,7687
wastewater treatment facility, capacity class 1, greater than 100,000 PE	ReferenceProduct	unit	1	#N/A	#N/A	#N/A	#N/A
polystyrene foam slab	FromTechnosphere	kg	55,714	#N/A	#N/A	299,134296	#N/A
switch, toggle type	FromTechnosphere	kg	2,14	#N/A	#N/A	6,4410252	18,5215044
cement, unspecified	FromTechnosphere	kg	15230,3	#N/A	#N/A	107459,447	#N/A
wastewater treatment facility, capacity class 3b, between 10,000 and 20,000 PE	ReferenceProduct	unit	#N/A	#N/A	#N/A	1	#N/A
polyester-complexed starch biopolymer	FromTechnosphere	kg	#N/A	#N/A	#N/A	39,3539278	#N/A
wastewater treatment facility, capacity class 4, between 2,000 and 10,000 PE	ReferenceProduct	unit	#N/A	#N/A	#N/A	#N/A	1
polysulfide, sealing compound	FromTechnosphere	kg	#N/A	#N/A	#N/A	#N/A	1,2672
ethylene vinyl acetate copolymer	FromTechnosphere	kg	#N/A	#N/A	#N/A	#N/A	37,5906

### 3.2 Sewer system

The modelling of the sewer system is taken from Doka (2009) and represents a rough estimate at best. Doka (2009) provided Swiss data on meters per capita of sewers per capacity. This value is converted to m<sup>3</sup> of transported wastewater using the capacity and treated volume amounts from the Spanish wastewater treatment plants discussed in the previous section. The same relations are assumed to hold whether the water sent to the sewer is ultimately discharged to the environment or treated.

## 4 “Direct discharge of wastewater” dataset

Not all wastewater generated by the population is collected in sewer systems, not all sewer systems are connected to a WWTP, and some sewer systems may be associated with losses before reaching the WWTP. This tool specifically accounts for the latter two of these aspects in a specific dataset, “direct discharge of wastewater”.

### 4.1 Collected wastewater not connected to a WWTP

Wastewater collected but not connected to a WWTP is modelled as a direct emission to the environment. The dataset converts all the pollutants in the wastewater (e.g. mass concentration of Total Kjeldahl Nitrogen, mass concentration of a metal) into emissions to water (Nitrogen, organic bound to surface water, metal ion to surface water). The actual water is also emitted to the environment (Water to surface water). The reference flow is 1 m<sup>3</sup> of wastewater directly discharged to the environment from the sewer.

The fraction of wastewater that is discharged to the environment from sewer systems without treatment is accounted for in the production volume of the dataset. During linking, ecoinvent will calculate the relative shares of water being treated and that directly discharged based on the relative production volumes of the direct discharge and treatment datasets. The production volume is calculated using data from the report WHO/Unicef joint monitoring program from 2017, which includes sanitation data for most countries of the world. The data is available through <https://washdata.org/data>.

From the data obtained for 2015 we estimate the following ratio:

$$\frac{\% \text{ population whose wastewater is collected in sewers but discharged to rivers without treatment}}{\text{percentage of population connected to sewers}}$$

This percentage per country is applied to the production volume of water discharged to the sewer system, which is a user input and is calculated by the production volume of the unit process generating the wastewater and the amount of wastewater generated per unit of its reference flow.

Geographies in the ecoinvent database are mapped to those in the WHO data. In cases where ecoinvent geographies did not have a direct match in the WHO data, a best match was manually found.

## 4.2 Combined sewer overflow wastewater

Combined sewer system (CSS) collects rainwater runoff, municipal sewage, and industrial wastewater in the same pipe. Normally, these systems will transport the total volume of sewage to a WWTP for treatment. However, some rain episodes result in volumes of runoff that, when mixed with municipal and industrial waste, can exceed the capacities of a CSS. When capacity is exceeded, a combined sewer overflow (CSO) occurs, which is the discharge of untreated sewage (mixed with urban runoff) from a CSO structure directly into surface water. Because CSOs contain untreated municipal and industrial waste, toxic materials, and debris, they impact the physicochemical, biological, hydraulic, and aesthetic status of receiving water bodies.

These emissions are accounted for in the “untreated wastewater” dataset. They are calculated in a three-step process:

- A fraction wastewater pollutants reported in the wastewater properties are assumed discharge due to the CSO episodes. This fraction should be country-specific, and depends on the share of sewer systems that are combined (rather than separate), on rainfall, snowmelt, etc. In the tool, the default values used are taken from Doka (2009): 1% of the particulate compounds of the wastewater and 2% of the soluble compounds. The tools’ thorough influent wastewater fractionation allows differentiating amongst soluble and particulate compounds. These represent Swiss data, and may not apply to other situations. The data provider can these values directly in the tool.
- The calculated amounts of compounds lost due to CSO episodes are then converted to emissions to water using the same approach as outlined for direct discharge of water.
- Finally, these emissions are scaled to account only for collected wastewater that is actually connected to a WWTP (to avoid double counting), and then scaled again to the reference flow of the direct discharge dataset, where CSO is reported. The resulting equation is:

$$\frac{\text{kg emission}}{\text{m}^3 \text{directly discharge water}} = \frac{\text{compounds lost due to CSO}}{\text{m}^3 \text{treated water}} \times \frac{\text{m}^3 \text{treated water}}{\text{m}^3 \text{total water}} \times \frac{\text{m}^3 \text{total water}}{\text{m}^3 \text{directly discharged water}}$$

Note that in regions where the fraction of directly discharged water is 0, CSO is not accounted for. Indeed, in these cases, the ratio (m<sup>3</sup> total water/m<sup>3</sup> directly discharged water) has a division by 0 problem, and the production volume of the “no treatment” dataset would be 0. This is a limitation of the model. Future versions should consider including CSO in the treatment dataset instead, or including them in the market dataset, where sewers could also eventually be included.

#### 4.2.1 Sewer system

The water that is discharged directly to the environment still uses the sewer system. Hence, it is necessary to include the sewer infrastructure input. This is done using the same sewer system proportions as for the wastewater treatment dataset, where it was based on the capacity of existing WWTPs. This is a rough approximation, which can be corrected by the data provider if more specific information is available.

For countries where there are no WWTPs, the sewer estimation uses the default market shares of WWTPs, based on the South African situation for now (see Section 7).

## 5 Uncertainty assessment

The uncertainty of all quantified data in the ecoSpold datasets is estimated using the Pedigree matrix approach:

- A basic uncertainty factor is identified for all types of exchanges, ranging from 0.0006 for inputs of electricity to 0.65 for emissions of metals to water.
- Pedigree scores, which cover different aspects of data quality, are also given, which will result in “additional” uncertainty.

The approach assumes that all parameters are lognormally distributed.

The tool needs to provide basic uncertainty factors and pedigree scores in a very general way, without any information on the quality of the data that the data provider will input into the model. It therefore behoves the user to check these values directly in the ecoEditor tool and make adjustments where appropriate. All uncertainty fields are documented to inform the user on how the default uncertainty factors were selected. Here are some of the assumptions that were made when selecting the default basic uncertainty and pedigree scores:

- Production volumes of direct discharge and treatment datasets: The uncertainty of these production volumes is based on the uncertainty of the WHO data used to identify how much wastewater sent to the sewer system is actually treated. It therefore neglects the uncertainty in the actual amount of wastewater generated upstream.
- Emissions to water of direct discharge:
  - The basic uncertainty of emissions associated with direct discharge of wastewater is approximated as the uncertainty of an emission to water. For example, the uncertainty for the emission of metals associated with the direct discharge of wastewater containing a metal pollutant is approximated as 0.65, the basic uncertainty of a heavy metal emission to water. This will overestimate the uncertainty for wastewaters that were well characterized.
  - The pedigree scores depend on whether the CSO (scores = [5, 5, 4, 5, 1]) or the directly discharged (scores = [1, 1, 1, 1, 1]) amounts are greater.
- Except for infrastructure inputs, technosphere exchange amounts calculated by the model are all given a basic uncertainty of 0.0006 and pedigree scores of [3, 5, 1, 5, 4].
- Infrastructure and sewer inputs are given basic uncertainty factors of 0.3. The pedigree scores for sewer amounts is [5, 5, 5, 5, 5], and for infrastructure, [5, 5, 1, 5, 5].



## 6 Calculation engine

The main goal of the tool is to estimate the inputs and outputs of treating 1 m<sup>3</sup> of a particular activity wastewater in a reference (or a set of reference) WWTP/s that already treats a (much larger) volume of water. For this estimation, the model runs twice, once with just the reference wastewater and once with the reference wastewater and a marginal amount (1m<sup>3</sup>/d) of activity wastewater. The difference is taken to be a reflection of how inputs and outputs (elementary flows, energy consumption, chemicals consumption, sludge production, etc.) change with an additional amount of the activity wastewater, and hence the approach follows the ISO14044 Step 2 approach. Because it uses a marginal difference in influent at the WWTP point of operation, the approach is sometimes referred to in this text as the “marginal” approach. We do not provide a design for a WWTP for an activity wastewater.

In the case there is only one reference WWTP:

- 1) WWTP model is run only accounting for the “municipal” wastewater characteristics of the inhabitants connected to the WWTP. Design outcomes and elementary flows are obtained.
- 2) A mass balance is conducted on the “municipal” wastewater characteristics plus the activity wastewater characteristics. A second set of design outcomes and elementary flows is obtained.
- 3) The difference between the results obtained in step 2 minus step 1 is the burden associated to the activity wastewater.

In the case there is a mix of reference WWTPs (WWTP mixes):

- 1) The approach explained for just one reference WWTP is repeated for as many reference WWTPs are available.
- 2) The results of each iteration are weighted based on the percentage of treated load (measured as population equivalents) per each reference WWTP.

It is worth mentioning that adding activity wastewater to the existing “municipal” wastewater can have positive or negative effects. The simplest example is adding an activity wastewater that has much higher temperature than the “municipal” wastewater. If the temperature at the WWTP is increased, the kinetics are faster and hence there is larger removal of pollutants. This means, that adding an activity wastewater does not always results in increases of environmental burdens for all variables. This explains the negative values obtained by the tool (in the inventory of the contributions of the activity wastewater) in some cases.

## 7 WWTP mixes per regions

A WWTP mix is a set of WWTPS where the activity wastewater will be cotreated with other (reference) wastewater. For each WWTP included in a particular mix the following characteristics are to be supplied.

**Table 30. List of parameters needed for each element of the mix**

<b>Id</b>	<b>Description</b>	<b>unit</b>
% of PE treated	Percentage of entire country PE treated	
Technology	Select type of technology	

Population equivalents	Average PE of plant in mix	PE
COD	chemical oxygen demand	g COD/m <sup>3</sup>
TKN	kjeldhal nitrogen	g N/m <sup>3</sup>
TP	Total Phosphorus	g P/m <sup>3</sup>
Temperature		°C
Q	Flow	m <sup>3</sup> (d)
NH <sub>4</sub> eff	Effluent ammonia target	g N/m <sup>3</sup>
NO <sub>3</sub> eff	Effluent nitrate target	g N/m <sup>3</sup>
PO <sub>4</sub> eff	Effluent phosphate target	g P/m <sup>3</sup>
Ag	Silver	g/m <sup>3</sup>
Al	Aluminium	g/m <sup>3</sup>
As	Arsenic	g/m <sup>3</sup>
B	Boron	g/m <sup>3</sup>
Ba	Barium	g/m <sup>3</sup>
Be	Beryllium	g/m <sup>3</sup>
Br	Bromine	g/m <sup>3</sup>
Ca	Calcium	g/m <sup>3</sup>
Cd	Cadmium	g/m <sup>3</sup>
Cl	Chlorine	g/m <sup>3</sup>
Co	Cobalt	g/m <sup>3</sup>
Cr	Chromium	g/m <sup>3</sup>
Cu	Copper	g/m <sup>3</sup>
F	Fluorine	g/m <sup>3</sup>
Fe	Iron	g/m <sup>3</sup>
Hg	Mercury	g/m <sup>3</sup>
I	Iodine	g/m <sup>3</sup>
K	Potassium	g/m <sup>3</sup>
Mg	Magnesium	g/m <sup>3</sup>
Mn	Manganese	g/m <sup>3</sup>
Mo	Molybdenum	g/m <sup>3</sup>
Na	Sodium	g/m <sup>3</sup>
Ni	Nikel	g/m <sup>3</sup>
Pb	Lead	g/m <sup>3</sup>
Sb	Antimony	g/m <sup>3</sup>
Sc	Scandium	g/m <sup>3</sup>
Se	Selenium	g/m <sup>3</sup>
Si	Silicon	g/m <sup>3</sup>
Sn	Tin	g/m <sup>3</sup>
Sr	Strontium	g/m <sup>3</sup>
Ti	Titanium	g/m <sup>3</sup>
Tl	Thallium	g/m <sup>3</sup>
V	Vanadium	g/m <sup>3</sup>
W	Tungsten	g/m <sup>3</sup>
Zn	Zinc	g/m <sup>3</sup>
CSO_particulate	Fraction of particulates that are discharged with the combined sewer overflows	%
CSO_soluble	Fraction of particulates that are discharged with the combined	%

	sewer overflows	
removal_bpCOD	Percentage removal of bpCOD during primary settling	%
removal_nbpCOD	Percentage removal of nbpCOD during primary settling	%
removal_ON	Percentage removal of ON during primary settling	%
removal_OP	Percentage removal of OP during primary settling	%
removal_iTSS	Percentage removal of iTSS during primary settling	%
MLSS_X_TSS	Design mixed liquor suspended solids	g/m <sup>3</sup>
DO	Dissolved oxygen concentration in biological aerobic reactor	g/m <sup>3</sup> as O <sub>2</sub>
clarifiers	Number of clarifiers	clarifiers
sBODe	soluble BOD in the effluent	g/m <sup>3</sup> as O <sub>2</sub>
TSSe	Total suspended solids in the effluent	g/m <sup>3</sup>
zb	Site elevation above sea level	m
Pressure	Pressure at site elevation	Pa
Df	Liquid depth above diffusers in biological reactor	m
h_settler	Height of settler	m
X_R	Return sludge mass concentration	g/m <sup>3</sup>
SRT	Sludge Retention Time	d
SOR	Hydraulic application rate for secondary settler	m <sup>3</sup> /m <sup>2</sup> ·d
SF	Peak to average TKN load	Ø
Anoxic_mixing_energy	Mixing energy for anoxic reactor	kW/1000 m <sup>3</sup>
FeCl3_solution	Ferric chloride solution	%
FeCl3_unit_weight	Ferric chloride unit weight	kg/L
days	Time of storage of the ferric chloride	d
influent_H	Influent pumping water lift height	m

## 7.1 Country mixes

The tool is ready to create new country WWTP mixes. As an example we provide in here the country mix of WWTPs for South-Africa.

**Table 31. Example of the South-Africa mix**

South Africa	Description	unit	mix 1	mix 2	mix 3	mix 4
% of PE treated	Percentage of entire country PE treated		9,3	13,4	30,1	47,2
Technology	Select type of technology		BOD+ND+BioP	BOD+ND+BioP	BOD+ND+BioP	BOD+ND+BioP
Population equivalents	Average PE of plant in mix	PE	62000	502000	1124000	1765000
COD	chemical oxygen demand	g COD/m3	800	800	800	800
TKN	kjeldhal nitrogen	g N/m3	64	64	64	64
TP	Total Phosphorus	g P/m3	10	10	10	10
Temperature		°C	14	14	14	14
Q	Flow	m3(d)	7700	62800	140500	220700
NH4eff	Effluent ammonia target	g N/m3	-	1	-	1
NO3eff	Effluent nitrate target	g N/m3	-	6	-	6
PO4eff	Effluent phosphate target	g P/m3	-	1	-	1
Ag	Silver	g/m <sup>3</sup>	0	0	0	0
Al	Aluminium	g/m <sup>3</sup>	1,0379	1,0379	1,0379	1,0379
As	Arsenic	g/m <sup>3</sup>	0,0009	0,0009	0,0009	0,0009
B	Boron	g/m <sup>3</sup>	0	0	0	0
Ba	Barium	g/m <sup>3</sup>	0	0	0	0
Be	Beryllium	g/m <sup>3</sup>	0	0	0	0
Br	Bromine	g/m <sup>3</sup>	0	0	0	0
Ca	Calcium	g/m <sup>3</sup>	50,834	50,834	50,834	50,834
Cd	Cadmium	g/m <sup>3</sup>	0,0003	0,0003	0,0003	0,0003
Cl	Chlorine	g/m <sup>3</sup>	30,031	30,031	30,031	30,031
Co	Cobalt	g/m <sup>3</sup>	0,0016	0,0016	0,0016	0,0016
Cr	Chromium	g/m <sup>3</sup>	0,0122	0,0122	0,0122	0,0122
Cu	Copper	g/m <sup>3</sup>	0,0374	0,0374	0,0374	0,0374
F	Fluorine	g/m <sup>3</sup>	0,0328	0,0328	0,0328	0,0328

Fe	Iron	g/m <sup>3</sup>	7,0928	7,0928	7,0928	7,0928
Hg	Mercury	g/m <sup>3</sup>	0,0002	0,0002	0,0002	0,0002
I	Iodine	g/m <sup>3</sup>	0	0	0	0
K	Potassium	g/m <sup>3</sup>	0,3989	0,3989	0,3989	0,3989
Mg	Magnessium	g/m <sup>3</sup>	5,7071	5,7071	5,7071	5,7071
Mn	Manganese	g/m <sup>3</sup>	0,053	0,053	0,053	0,053
Mo	Molybdenum	g/m <sup>3</sup>	0,001	0,001	0,001	0,001
Na	Sodium	g/m <sup>3</sup>	2,186	2,186	2,186	2,186
Ni	Nikel	g/m <sup>3</sup>	0,0066	0,0066	0,0066	0,0066
Pb	Lead	g/m <sup>3</sup>	0,0088	0,0088	0,0088	0,0088
Sb	Antimony	g/m <sup>3</sup>	0	0	0	0
Sc	Scandium	g/m <sup>3</sup>	0	0	0	0
Se	Selenium	g/m <sup>3</sup>	0	0	0	0
Si	Silicon	g/m <sup>3</sup>	3,1263	3,1263	3,1263	3,1263
Sn	Tin	g/m <sup>3</sup>	0,0034	0,0034	0,0034	0,0034
Sr	Strontium	g/m <sup>3</sup>	0	0	0	0
Ti	Titanium	g/m <sup>3</sup>	0	0	0	0
Tl	Thallium	g/m <sup>3</sup>	0	0	0	0
V	Vanadium	g/m <sup>3</sup>	0	0	0	0
W	Tungsten	g/m <sup>3</sup>	0	0	0	0
Zn	Zinc	g/m <sup>3</sup>	0,1094	0,1094	0,1094	0,1094
CSO_particulate	Fraction of particulates that are discharged with the combined sewer overflows	%	0	0	0	0
CSO_soluble	Fraction of particulates that are discharged with the combined sewer overflows	%	0	0	0	0
removal_bpCOD	Percentage removal of bpCOD during primary settling	%	40	40	40	40
removal_nbpCOD	Percentage removal of nbpCOD during primary settling	%	60	60	60	60
removal_ON	Percentage removal of ON during primary settling	%	66,6	66,6	66,6	66,6
removal_OP	Percentage removal of OP during primary settling	%	66,6	66,6	66,6	66,6

removal_iTSS	Percentage removal of iTSS during primary settling	%	70	70	70	70
MLSS_X_TSS	Design mixed liquor suspended solids	g/m <sup>3</sup>	3000	3000	3000	3000
DO	Dissolved oxygen concentration in biological aerobic reactor	g/m <sup>3</sup> as O <sub>2</sub>	2	2	2	2
clarifiers	Number of clarifiers	clarifiers	3	3	3	3
sBODe	soluble BOD in the effluent	g/m <sup>3</sup> as O <sub>2</sub>	3	3	3	3
TSSe	Total suspended solids in the effluent	g/m <sup>3</sup>	5	5	5	5
zb	Site elevation above sea level	m	500	500	500	500
Pressure	Pressure at site elevation	Pa	95600	95600	95600	95600
Df	Liquid depth above diffusers in biological reactor	m	4,4	4,4	4,4	4,4
h_settler	Height of settler	m	4	4	4	4
X_R	Return sludge mass concentration	g/m <sup>3</sup>	8000	8000	8000	8000
SRT	Sludge Retention Time	d	5	-	5	-
SOR	Hydraulic application rate for secondary settler	m <sup>3</sup> /m <sup>2</sup> ·d	24	24	24	24
SF	Peak to average TKN load	∅	1,5	1,5	1,5	1,5
Anoxic_mixing_energy	Mixing energy for anoxic reactor	kW/1000 m <sup>3</sup>	5	5	5	5
FeCl3_solution	Ferric chloride solution	%	40	40	40	40
FeCl3_unit_weight	Ferric chloride unit weight	kg/L	1,35	1,35	1,35	1,35
days	Time of storage of the ferric chloride	d	15	15	15	15
influent_H	Influent pumping water lift height	m	10	10	10	10

## 7.2 Global mix

The global mix is currently the one belonging to South-Africa. At the time of writing this report, the global average is based on South African data only. Data from other countries will be integrated at a later date.

## 7.3 User own mix

The tool allows for the users to build their own mixes in a user-friendly manner. The mix can be created and then saved as a json file which can be uploaded afterwards.

# 8 Using the web tool

## 8.1 Activity data entry page

The user enters activity wastewater source, location (select global or a particular country), industrial wastewater type, volume of wastewater discharged, wastewater composition and the wastewater treatment plant type (specific or country average) in the Activity data entry page.

---

File →

---

1. Wastewater source

[help](#)

---

2. Location where the wastewater is being emitted

---

3. Industrial wastewater type

---

4. Volume of water discharged

m<sup>3</sup>/d | [help](#)

---

5.  Wastewater composition

---

6. Wastewater treatment plant type

---

7.

---

With regards to the industrial wastewater type the user can select amongst the following 5 options: type 0: municipal, type 1: highly soluble and high degradability, type 2: highly particulate and high degradability, type 3: highly soluble and low degradability, and type 4: highly particulate and low degradability. This selection is used to execute the fractionation of the total COD, TKN and TP that has to enter under the wastewater composition tab.

File →

1. Wastewater source  
activity name

2. Location where the wastewater is being emitted  
Global

3. Industrial wastewater type  
Type 0: Municipal

4.

6. Wastewater treatment plant type  
Specific WWTP — calculate the marginal contribution to a single treatment plant

7.

The user selects "Specific WWTP" or "country average WWTP". With the "Specific WWTP" the user will enter the characteristics of a particular user defined WWTP and run the marginal approach against that one. If the user selects country average WWTP, the default WWTP mix of a given country (selected in the data entry page), with predefined values already available in the tool is loaded in the following page. The marginal approach is then run n times, one per each element of the WWTP mix.

## 8.2 Marginal approach calculation page

Study your activity's contribution to one or more wastewater treatment plants

### 1. Inputs

Inputs	Activity WW	WWTPs new plant	Run alone Run with activity chosen
Treated Pop. Eq. (%)	-	100	total: 100%
<b>Technologies</b>			
Primary settler	-	<input checked="" type="checkbox"/>	
BOD removal	-	<input checked="" type="checkbox"/>	
Nitrification	-	<input type="checkbox"/>	
Denitrification	-	<input type="checkbox"/>	
Biological P removal	-	<input type="checkbox"/>	
Chemical P removal	-	<input type="checkbox"/>	
<b>Wastewater composition</b>			
Q	100	22700	m <sup>3</sup> /d
T	12	12	°C
COD	300	300	g m <sup>-3</sup> as O <sub>2</sub>
TKN	35	35	g m <sup>-3</sup> as N
TP	6	6	g m <sup>-3</sup> as P
BOD	Δ 147.06	147.06	g m <sup>-3</sup> as O <sub>2</sub>
sBOD	Δ 55.88	55.88	g m <sup>-3</sup> as O <sub>2</sub>
sCOD	Δ 114	114	g m <sup>-3</sup> as O <sub>2</sub>
bCOD	Δ 246	246	g m <sup>-3</sup> as O <sub>2</sub>
rbCOD	Δ 48	48	g m <sup>-3</sup> as O <sub>2</sub>
VFA	Δ 7.2	7.2	g m <sup>-3</sup> as O <sub>2</sub>
VSS	Δ 116.25	116.25	g m <sup>-3</sup>
TSS	Δ 161.25	161.25	g m <sup>-3</sup>
NH <sub>4</sub>	Δ 23.1	23.1	g m <sup>-3</sup> as N
PO <sub>4</sub>	Δ 3	3	g m <sup>-3</sup> as P
Alkalinity	Δ 300	300	g m <sup>-3</sup> as CaCO <sub>3</sub>
Ag	0	0	g m <sup>-3</sup> as Ag

### 2. Results

#### 2.1 Contribution: influent/effluent only

Select units: ☒ kg/d ☐ % ☐ kg/m<sup>3</sup> activity ww

Compound	Influent	Water	Effluent Air	Sludge
↓ Main compounds				
COD	21.56/4.915	2.179/496.7	9.556/2.179	9.799/2.234
CO <sub>2</sub>			12.06/2.750	
CH <sub>4</sub>				
TKN	2.655/605.4	1.886/430.1		0.769/175.3
NO <sub>x</sub>				
N <sub>2</sub>				
N <sub>2</sub> O				
TP	0.393/89.55	0.291/66.31		0.102/23.24
→ Metals and other elements				

#### 2.2 Contribution: all characteristics

Variable	Contribution	Unit	Percent contribution
→ Fractionation (50)			
→ Combined Sewer Overflow (42)			
→ Primary settler (12)			
→ BOD removal (24)			
→ Secondary settler sizing (6)			
→ Metals and other elements (70)			
→ sludge_composition (21)			
→ Energy consumption (13)			
→ chemicals (7)			
→ summary (58)			
→ Outputs (172)			
→ other (15)			

There are two main sections: Inputs (on the left) and Results (on the right).

- A) If the user has selected "specific WWTP" in the activity data entry page there is only one reference WWTP to be defined. Default values are provided but the user can modify them. For the reference WWTPs the type of wastewater is municipal, and



hence the “municipal” wastewater fractionation factors are provided. The user selects the technology of the reference WWTP, indicating whether it includes a primary settler, BOD removal, nitrification, denitrification, and/or biological or chemical P removal. With regards to the wastewater composition, the user first enters flow, temperature, COD, TKN and TP. All other wastewater composition fractions can be estimated from the “municipal” fractionation factors by pressing the warning symbol next to each compound. Still, the user can change the values.

- B) If the user has selected “country average WWTP” in the activity data entry page, there are multiple reference WWTPs provided. Default values are provided, and we recommend not to change them.

When the user is satisfied with the entrance of the inputs has to press the “run simulation” button. This button, triggers the calculation of the marginal approach. The action is fast to compute, and the user immediately sees the new outcomes in the results section.

Finally, when results have been computed, the user can press the “Generate Ecospold file” button to generate the Ecospold file.

Advanced users who would like to get more information and understand how these inventories have been generated have two extra options:



- 1) Run alone: A new web tab opens where the user can run a simulation of the reference WWTP alone, without considering the activity wastewater and not calculating the marginal approach;

**1. User inputs****1.1. Wastewater treatment technologies**

Primary settler	<input checked="" type="checkbox"/>	<a href="#">equations</a>
BOD removal	<input checked="" type="checkbox"/>	<a href="#">equations</a>
Nitrification	<input type="checkbox"/>	<a href="#">equations</a>
Denitrification	<input type="checkbox"/>	<a href="#">equations</a>
Biological P removal	<input type="checkbox"/>	<a href="#">equations</a>
Chemical P removal (coprecipitation only)	<input type="checkbox"/>	<a href="#">equations</a>

**1.2. Wastewater composition and design parameters**  
(required: 82 of 82)

Wastewater composition		
Q	22700	m <sup>3</sup> /d
T	12	°C
COD	300	g m <sup>-3</sup> as O <sub>2</sub>
TKN	35	g m <sup>-3</sup> as N
TP	6	g m <sup>-3</sup> as P
BOD	≐ 147.06	g m <sup>-3</sup> as O <sub>2</sub>
uBOD	≐ 55.88	g m <sup>-3</sup> as O <sub>2</sub>
uCOD	≐ 114	g m <sup>-3</sup> as O <sub>2</sub>
uCOD	≐ 246	g m <sup>-3</sup> as O <sub>2</sub>
uCOD	≐ 48	g m <sup>-3</sup> as O <sub>2</sub>
VFA	≐ 7.2	g m <sup>-3</sup> as O <sub>2</sub>
VSS	≐ 116.25	g m <sup>-3</sup>
TSS	≐ 161.25	g m <sup>-3</sup>
NH <sub>4</sub>	≐ 23.1	g m <sup>-3</sup> as N
PO <sub>4</sub>	≐ 3	g m <sup>-3</sup> as P
Alkalinity	≐ 300	g m <sup>-3</sup> as CaCO <sub>3</sub>
Metals and other elements		
Design parameters		
CSO_particulate	1	%
CSO_soluble	2	%
removal_kgCOD	40	%

**2. Variables calculated: 259**

Variable	Result	Unit
Combined Sewer Overflow		
Primary settler		
Fractionation		
BOD removal		
Secondary settler sizing		
Metals and other elements		
Energy consumption		
other		
sludge_composition		
chemicals		

[↑.top](#)**3. Outputs**Select units: ☒ kg/d ☐ g/m<sup>3</sup>**3.1. Influent — Effluent**

Compound	Influent (kg/d)	Effluent (kg/d)		
		Water	Air	Sludge
Main compounds				
COD	4,894	494.6	2,169	2,224
CO <sub>2</sub>			2,738	
CH <sub>4</sub>				
TKN	602.8	428.2		174.6
NO <sub>x</sub>				
N <sub>2</sub>				
N <sub>2</sub> O				
TP	89.15	66.02		23.14
Metals and other elements				

**3.2. Mass balances (equations)**

Element	Influent (kg/d)	Effluent (kg/d)			Error (%)
		Water	Air	Sludge	
COD	4,894	494.6	2,169	2,224	0.11 %
N	602.8	428.2		174.6	0 %
P	89.15	66.02		23.14	0 %

**3.3. Sludge production**

- Primary sludge
  - Removed TSS: 1,847 kg TSS/d
    - H<sub>2</sub>O content: 9,543 kg H<sub>2</sub>O/d
  - Removed VSS: 1,139 kg VSS/d
    - C content: 580.9 kg C/d
    - H content: 95.9 kg H/d
    - O content: 364.2 kg O/d
    - N content: 85.27 kg N/d
    - P content: 12.8 kg P/d
- Secondary sludge
  - P\_X\_TSS: 2,107 kg TSS/d
    - H<sub>2</sub>O content: 6,322 kg H<sub>2</sub>O/d
  - P\_X\_VSS: 1,562 kg VSS/d
    - C content: 795.5 kg C/d
    - H content: 184.3 kg H/d
    - O content: 450 kg O/d
    - N content: 187.4 kg N/d
    - P content: 23.43 kg P/d
- FeCl<sub>3</sub> additional sludge: 0 kg TSS/d
  - Fe content: 0 kg Fe/d
  - H content: 0 kg H/d

2) Run with activity: A new tab opens where the user can execute the modelling approach for the sum of the municipal and the activity wastewater;

**1. User inputs****1.1. Wastewater treatment technologies**

Primary settler	<input checked="" type="checkbox"/>	<a href="#">equations</a>
BOD removal	<input checked="" type="checkbox"/>	<a href="#">equations</a>
Nitrification	<input type="checkbox"/>	<a href="#">equations</a>
Denitrification	<input type="checkbox"/>	<a href="#">equations</a>
Biological P removal	<input type="checkbox"/>	<a href="#">equations</a>
Chemical P removal (coprecipitation only)	<input type="checkbox"/>	<a href="#">equations</a>

**1.2. Wastewater composition and design parameters**  
(required: 82 of 82)

Wastewater composition		
Q	22800	m <sup>3</sup> /d
T	12	°C
COD	300	g m <sup>-3</sup> as O <sub>2</sub>
TKN	35	g m <sup>-3</sup> as N
TP	6	g m <sup>-3</sup> as P
BOD	≐ 147.06	g m <sup>-3</sup> as O <sub>2</sub>
uBOD	≐ 55.88	g m <sup>-3</sup> as O <sub>2</sub>
uCOD	≐ 114	g m <sup>-3</sup> as O <sub>2</sub>
uCOD	≐ 246	g m <sup>-3</sup> as O <sub>2</sub>
uCOD	≐ 48	g m <sup>-3</sup> as O <sub>2</sub>
VFA	≐ 7.2	g m <sup>-3</sup> as O <sub>2</sub>
VSS	≐ 116.25	g m <sup>-3</sup>
TSS	≐ 161.25	g m <sup>-3</sup>
NH <sub>4</sub>	≐ 23.1	g m <sup>-3</sup> as N
PO <sub>4</sub>	≐ 3	g m <sup>-3</sup> as P
Alkalinity	≐ 300	g m <sup>-3</sup> as CaCO <sub>3</sub>
Metals and other elements		
Design parameters		
CSO_particulate	1	%
CSO_soluble	2	%

**2. Variables calculated: 259**

Variable	Result	Unit
Combined Sewer Overflow		
Primary settler		
Fractionation		
BOD removal		
Secondary settler sizing		
Metals and other elements		
Energy consumption		
other		
sludge_composition		
chemicals		

[↑.top](#)**3. Outputs**Select units: ☒ kg/d ☐ g/m<sup>3</sup>**3.1. Influent — Effluent**

Compound	Influent (kg/d)	Effluent (kg/d)		
		Water	Air	Sludge
Main compounds				
COD	4,915	496.7	2,179	2,234
CO <sub>2</sub>			2,750	
CH <sub>4</sub>				
TKN	605.4	430.1		175.3
NO <sub>x</sub>				
N <sub>2</sub>				
N <sub>2</sub> O				
TP	89.55	66.31		23.24
Metals and other elements				

**3.2. Mass balances (equations)**

Element	Influent (kg/d)	Effluent (kg/d)			Error (%)
		Water	Air	Sludge	
COD	4,915	496.7	2,179	2,234	0.11 %
N	605.4	430.1		175.3	0 %
P	89.55	66.31		23.24	0 %

**3.3. Sludge production**

- Primary sludge
  - Removed TSS: 1,855 kg TSS/d
    - H<sub>2</sub>O content: 9,565 kg H<sub>2</sub>O/d
  - Removed VSS: 1,144 kg VSS/d
    - C content: 583.5 kg C/d
    - H content: 96.32 kg H/d
    - O content: 365.8 kg O/d
    - N content: 85.64 kg N/d
    - P content: 12.86 kg P/d
- Secondary sludge
  - P\_X\_TSS: 2,117 kg TSS/d
    - H<sub>2</sub>O content: 6,350 kg H<sub>2</sub>O/d
  - P\_X\_VSS: 1,569 kg VSS/d
    - C content: 800 kg C/d
    - H content: 184.8 kg H/d
    - O content: 452 kg O/d
    - N content: 188.2 kg N/d
    - P content: 23.53 kg P/d
- FeCl<sub>3</sub> additional sludge: 0 kg TSS/d
  - Fe content: 0 kg Fe/d
  - H content: 0 kg H/d

The user can have access to the actual implementation of the equations, by clicking the hyperlinks of the calculated variables (section2 of the run with activity webpage).

The user can also access the equations through the information page, where Table 32 is guiding the user.

**Table 32. Access to equations implemented in the backend of the tool**

Technology	Source	Code
1. Fractionation	<a href="#">M&amp;EA 5th ed (p. 756)</a>	<a href="#">fractionation.js</a>
2. BOD removal	<a href="#">M&amp;EA 5th ed (p. 756)</a>	<a href="#">bod_removal_only.js</a>
3. Nitrification	<a href="#">M&amp;EA 5th ed (p. 762)</a>	<a href="#">nitrification.js</a>
4. Denitrification	<a href="#">M&amp;EA 5th ed (p. 810)</a>	<a href="#">n_removal.js</a>
5. P removal (biologically)	<a href="#">M&amp;EA 5th ed (p. 880)</a>	<a href="#">bio_P_removal.js</a>
6. P removal (chemically)	<a href="#">M&amp;EA 5th ed (p. 484)</a>	<a href="#">chem_P_removal.js</a>
7. SST sizing	<a href="#">M&amp;EA 5th ed (p. 767)</a>	<a href="#">sst_sizing.js</a>
8. Metals and other elements	<a href="#">G. Doka excel tool</a>	<a href="#">metals_doka.js</a>
9. CSO removal	Based on M&EA fractionation	<a href="#">cso_removal.js</a>
10. Primary settler	G. Ekama	<a href="#">primary_settler.js</a>
11. Sludge composition	G. Ekama	<a href="#">sludge_composition.js</a>
12. Energy consumption	G. Ekama, Y. Comeau, L. Corominas	<a href="#">energy_consumption.js</a>
13. Figures, tables and appendixes	M&EA 5th ed	<a href="#">utils.js</a>
14. <a href="#">Input estimations</a>	BioWin 5.2	<a href="#">estimations.js</a>
15. <a href="#">Construction materials</a>	<a href="#">Morera et al, 2017</a>	<a href="#">construction.js</a>

### 8.3 Reviewing, modifying and submitting the Spold files

The tool will generate two Spold files. Spold files are files containing LCI data in the ecoSpold2 data format (see <https://www.ecoinvent.org/data-provider/data-provider-toolkit/ecospold2/ecospold2.html>). While some LCA software can import such files, the most common use of these files are to submit the datasets to ecoinvent so they can integrate them in their database.

To submit the datasets to ecoinvent, the data provider must:

- Open the datasets in the ecoEditor tool;
- Adapt the datasets as required;
- Submit the datasets directly from within the ecoEditor.

The ecoinvent Center will then receive the datasets and proceed to a review. The data provider may be required to make some adaptations to the dataset once they have been reviewed.

#### 8.3.1 Opening the datasets in ecoEditor

When the Spold files are generated from the tool, the data provider will download them. To open them in the ecoEditor, one must:

- Have ecoEditor installed on their computer. The ecoEditor is a freeware provided by ecoinvent to “create, edit, review and upload datasets for the future versions of the

ecoinvent database" (see <https://www.ecoinvent.org/data-provider/data-provider-toolkit/ecoeditor/ecoeditor.html>).

- From ecoEditor, click on "Open dataset from file" and select the downloaded files.

That is all there is to it. Learning to use the ecoEditor is not very hard, but in any case the interaction data providers will have with it will be very minimal, given that the web tool already did much of the heavy work to generate the datasets.

### 8.3.2 Adapting the datasets

The web tool will populate all obligatory fields with data based on the model structure and user inputs. However, given the flexibility of the web tool, it was impossible to predict all the specificities of a given use. Therefore, it behoves the data provider to verify the data.

Notably, the fields in the Activity Description and the Modelling and Administrative pages should be checked. The uncertainty fields for wastewater properties and direct discharges should also be revised if the wastewater composition is well known (see Section 5).

### 8.3.3 Submitting the datasets

The datasets are then submitted directly from within the ecoEditor. Specifically, the datasets need to be submitted to "validation", "external validation" and finally "external review", all options directly available in the ecoEditor tool under the "File" menu item.

## 9 References

- Corominas L, Larsen HF, Flores-Alsina X, Vanrolleghem PA. Including Life Cycle Assessment for decision-making in controlling wastewater nutrient removal systems. *J Environ Manage.* 2013;128:759-767. doi:10.1016/j.jenvman.2013.06.002.
- Doka G. (2007). Life Cycle Inventories of Waste Treatment Services. Ecoinvent report No. 13, Swiss Centre for Life Cycle Inventories, Dübendorf, December 2007.
- Enerwater, 2015. Standard method and online tool for assessing and improving the energy efficiency of waste water treatment plants. Deliverable 2.1 Study of published energy data. Accessed in <https://ec.europa.eu/research/participants/documents/downloadPublic?documentIds=080166e5a25bfb10&appId=PPGMS>.
- Foley J., Yuan Z., Keller J., Senante E., Chandran K., Willis J., Shah A., van Loosdrecht M.C.M, van Voorthuizen, E. 2015. N<sub>2</sub>O and CH<sub>4</sub> Emission from Wastewater Collection and Treatment Systems: State of the Science Report and Treatment Report. GWRC Report series. IWA Publishing. ISBN: 97811780407333.
- Gernaey, K.V., Jeppsson, U., Vanrolleghem, P.A., Copp, J.B. (Eds.), 2014. Bench- marking of Control Strategies for Wastewater Treatment Plants. IWA Publishing.
- Henze, M., Gujer, W., Mino, T., van Loosdrecht, M.C.M., 2000. Activated Sludge Models ASM1, ASM2, ASM2d and ASM3. IWA Scientific and Technical Report No 9. IWA Publishing, London, UK.
- Law Y, Jacobsen GE, Smith AM, Yuan Z, Lant P. Fossil organic carbon in wastewater and its fate in treatment plants. *Water Res.* 2013;47(14):5270-5281. doi:10.1016/j.watres.2013.06.002.

- Morera S, Corominas L, Rigola M, Poch M, Comas J. Using a detailed inventory of a large wastewater treatment plant to estimate the relative importance of construction to the overall environmental impacts. *Water Res.* 2017;122. doi:10.1016/j.watres.2017.05.069.
- Plastics Europe, 2012. *Plastics e the Facts 2012. An Analysis of European Plastics Production, Demand and Waste Data for 2011.* Brussels, Belgium.
- Sansom, M., Avery, N., 2014. Reuse and recycling rates of UK steel demolition arisings. *Proc. ICE - Eng. Sustain.* 167 (3).
- Stillwell A.S, Hoppock D.C., and Webber M.E. Energy Recovery from Wastewater Treatment Plants in the United States: A Case Study of the Energy-Water Nexus. *Sustainability* 2010, 2, 945-962; doi:10.3390/su2040945.
- Tchobanoglous et al., 2014. *Wastewater engineering: treatment and resource recovery.* Fifth edition. McGraw Hill. New York. ISBN: 978-0-07-340118-8.
- WHO/Unicef (2017). *Progress on Drinking Water, Sanitation and Hygiene. 2017 update and SDG Baselines.*