

Industrial Asset Inspection Report (PMP-204A)

1. General Metadata

Facility:	Apex Petrochemical Refinery - Sector 4
Inspection Date:	September 10, 2026
Inspector Name:	Marcus Vance (Senior QA Auditor)
System Unit:	Centrifugal Pump Assembly (PMP-204A)

2. Visual Assessment

Conducted standard external physical evaluation of the main housing unit, mechanical seals, and auxiliary lubrication lines. Casing surface exhibits minimal atmospheric oxidation. No immediate external structural fractures or volatile fluid micro-leaks were detected during static state.

3. Quantitative Measurements

Metric Measured	Baseline Spec	Observed Value	Compliance Status
Casing Vibration	< 4.5 mm/s	2.8 mm/s	Within Spec
Bearing Temp	< 75°C	68.2°C	Within Spec
Seal Pressure	12.0 - 15.0 Bar	13.4 Bar	Within Spec

4. Final Verdict & Signature

The asset PMP-204A meets all structural and operational safety specifications. Approved for continued service without modifications. Next inspection cycle window: March 2027.

Signature: *M. Vance* (Electronically Certified)