POID-4507044338

Dhruvit | Aug 12, 2026, 01:23 PM

Table of content

Job details

LT_Mini_Pillar — Dhruvit | Aug 12, 2026, 01:23 PM

Job details

Job Id	Start Date	End Date	Category	Asset	Site	Description
PH2026100006	-	-	LT	-	IIM Ahmedabad	-

Table of content

Inspection details

Basic Details **(Page complete: 100%)**

- Basic Details **(Inspection Points: 8/8)**

Characteristics _ Parameter **(Page complete: 100%)**

- Visual & Physical Checks **(Inspection Points: 11/11)**
- BOM Verification **(Inspection Points: 1/1)**
- Fabrication & Manufacturing Quality Checks **(Inspection Points: 2/2)**
- Raw Material / Bought out Items TC Verification **(Inspection Points: 2/2)**
- Photos Upload **(Inspection Points: 3/3)**
- Acceptance Tests as per QAP/IS **(Inspection Points: 4/4)**
- Other Compliances for Manufacturing Facility **(Inspection Points: 5/5)**

Inspection Observations **(Page complete: 100%)**

- Default **(Inspection Points: 3/3)**

Inspection Conclusion **(Page complete: 100%)**

- Inspection Summary **(Inspection Points: 3/3)**

Inspection details

Prepared by	Started on	Category	Sub category	Description	Inspection location
Dhruvit	Aug 12, 2026, 01:23 PM	LT	Mini Pillar	-	0, 0

Status

Completed

Basic Details

Page complete: 100%

Basic Details

Inspection Points: 8/8

Title : SAP Code

Answer 10460112

Title : Vendor Name

Answer
Larsen & Toubro Ltd. (Electrical & Automation)

Title : Offered Qty

Answer 25 Nos

Title : PO Details

Answer
PO No. 4500134567 dated 01-Jul-2026

Title : AEML Engineer & Designation

Answer
Rajesh Sharma, Senior Engineer (QA)

Title : Vendor Engineer & Designation

Answer Amit Verma, Quality Engineer

Title : Sl Nos of Items

Answer

LTMP/2026/0601 to LTMP/2026/0675

Title : Date of Inspection

Answer — Aug 12, 2026

Characteristics _ Parameter

Page complete: 100%

Visual & Physical Checks

Inspection Points: 11/11

Title : Dimensions

Input — Ok

Title : Sheet Steel Thickness & Type

Input — Others 2mm- OK

Title : Electrical Clearances

Input — Ok

Note : Clearance verified with feeler gauge — OK.

Title : Earthing

Input — Ok

Note : Earth continuity checked; resistance within limit.

Title : Paint Shade & Thickness

Input — Ok

Note : Shade RAL as approved; DFT 60–75 microns average.

Title : Gland Plate- Hole Size and Knockouts

Input — Ok

Title : Hardware

Input — Ok

Title : Door Hinges /Interlock for door removal from hinge

Input Ok

Title : Locking Arrangement

Input Ok

Title : Danger Boards

Input Ok

Note : Danger board fixed with rivets / screws as per drawing.

Title : Foundation Structure

Input Ok

Note : Foundation bolt pitch matches civil drawing.

BOM Verification

Inspection Points: 1/1

Title : Bill of Material

Input Ok

Fabrication & Manufacturing Quality Checks

Inspection Points: 2/2

Title : Welding

Input Ok

Title : Finishing & Painting

Input Ok

Raw Material / Bought out Items TC Verification

Inspection Points: 2/2

Title : TC of GI sheet from raw material sub vendor

Input Ok

Title : Bus Bar Conductivity

Input Ok

Photos Upload

Inspection Points: 3/3

Title : All 4 sides view with door closed condition

Input Attached

Title : Door Open Views Front & Back

Input Attached

Title : Foundation Structure View

Input Attached

Acceptance Tests as per QAP/IS

Inspection Points: 4/4

Title : Insulation resistance test phase to phase & phase to earth

Input Ok

Title : High voltage test

Input Ok

Title : Powder coating thickness measurement

Input Ok

Title : Al Bus Bar conductivity measurement

Input Ok

Note : Measured conductivity within limit; values logged.

Other Compliances for Manufacturing Facility

Inspection Points: 5/5

Title : Safety Aspects in Facility

Input Ok

Title : House Keeping

Input Ok

Note : Housekeeping satisfactory for inspection area.

Title : Eco-friendly Waste Segregation, Collection and Storage Practices w.r.t Hazardous / Non-Hazardous Materials

Input Ok

Title : Calibration of Testing Instruments

Input Ok

Title : SA 8000 Compliance

Input Ok

Note : SA 8000 certificate displayed; validity checked.

Inspection Observations

Page complete: 100%

Default

Inspection Points: 3/3

Observations : 1.

Answer
All dimensional, electrical clearance and earthing checks conform to the approved GA drawing and applicable IS stan dards.

Observations : 2

Answer
Sheet steel thickness, paint shade, powder coating thickness and BOM are as per the approved specification; no devia tion observed.

Observations : 3

Answer
Acceptance tests (insulation resistance, high voltage, bus bar conductivity) completed satisfactorily; material is recom mended for dispatch clearance.

Inspection Conclusion

Page complete: 100%

Inspection Summary

Inspection Points: 3/3

Title : Test Results

Answer

Ok

Title : Technical Clearance

Answer

Yes

Note : Clearance recommended subject to packing confirmation.

Title : Declaration

Answer

Visual, dimensional and electrical acceptance tests carried out as per IS and AEML QAP. Lot cleared for dispatch.