





3x150 TPH BOILER PACKAGE ALONG WITH STEAM TURBO-BLOWER BUILDING  
(EXCLUDING ENABLING WORKS), PKG NO:- 011-01A

TECHNICAL DATA SHEET OF AUXILIARY TRANSFORMER (1MVA/2MVA)

**ALLIED**  
ENERGY SYSTEM PVT. LTD



## TECHNICAL DATA SHEET OF AUXILIARY TRANSFORMER (1MVA/2MVA)

CATEGORY		√			
	APPROVAL	INFORMATION	REFERENCE	RECORD	CONSTRUCTION
CLIENT		Steel Authority of India Ltd. Bhilai Steel Plant Bhilai, Chhattisgarh			
CONSULTANT		MECON Limited Ranchi			
CONTRACTOR	CONSORTIUM OF:				
	 Fujian Longking Co. Ltd. No. 81, Lingyuan Road, Longyan City, Fujian Province, China		 Allied Energy Systems Pvt. Ltd. Plot no. 293, Kehar Singh Estate, West End Marg, Saidulajab, New Delhi-110030 (India)		
PACKAGE	3x150 TPH Boilers along with Steam Turbo-Blower Building (Excl. Enabling Works) [PKG NO. 011-01A]				

### REVISION HISTORY

Rev.	Rev. Date	Prepared By	Checked By	Approved By	Description
00	13-05-13	M/s Voltamp	M/s Voltamp	M/s Voltamp	Submitted For Information

Document No:-		Sub. Date	Rev. No.	Format	NO. OF SHEETS
BSP-FLCL-05-011-01A-06-040-29-BE-03003A		13-05-2013	00	A4	2
Prepared By	M/s Voltamp	Checked By	M/s Voltamp	Approved By	M/s Voltamp

**VOLTAMP TRANSFORMERS LIMITED**

JAROD-SAVLI ROAD, VILL.-VADADLA, TAL.-SAVLI,  
DIST.-VADODARA, GUJARAT, INDIA



**Client** : Longking Engineering India Pvt. Ltd.  
**Cunsaltant** : Mecon Ltd., Ranchi  
**Project** : 3X150 TPH Boiler & Turbo Blower System at Bhilai Steel Plant at Chattisgarh  
**P.O. No.** : LK1304C-WFD004-D003 Dtd. 18.04.13  
**Voltamp's REF. NO.** : 61620

**Date: 02.05.2013**

**Rev. '0'**

PAGE 1 OF 1

Data Sheet for 01 No. 1000 kVA, 6.6 / 0.433 KV Cast Resin Dry Type Transformer

**MAKE** VOLTAMP TRANSFORMERS LTD

**TYPE OF TRANSFORMER** Cast Resin Transformer

**LOCATION OF TRANSFORMER** Indoor

**RATING** 1000 kVA

**VOLTAGE RATIO (HV / LV)** 6.6 | 0.433 kV

**VECTOR GROUP** Dyn11

**TAPPING RANGE** +5.0% | -5% | Steps : 2.50%

**TAPPING BY** Off Circuit Tap Links

**TAPPINGS ON** On HV side

**CLASS OF INSULATION** " F "

**TEMPERATURE RISE IN WINDING** 80 °C Over Ambient: 50 °C

**% IMPEDENCE AT 75°C & PRINCIPAL TAP** 5.00 % (IS Tol.)

**NO LOAD LOSS** 1.8 KW (MAX)

**FULL LOAD LOSS AT 75°C** 11.0 KW (MAX)

**ENCLOSURE PROTECTION** IP 42

**EFFECIENCY \***

% LOAD	1 PF	0.8 PF
100	98.74	98.43
75	98.95	98.69
50	99.10	98.88

**REGULATIONS \***

% LOAD	1 PF	0.8 PF
100	1.219	3.859

**PAINT SHADE** Epoxy: 632 of IS 5

**\* The above furnished values of Efficiency & Regulation are based on Losses / Impedance.  
Which are subjected to the Tolerance as applicable of Losses & Impedance.**

**\*\* Prepared by : Vipul Ajmeri**



Checked & Approved By :

**VOLTAMP TRANSFORMERS LIMITED**

JAROD-SAVLI ROAD, VILL.-VADADLA, TAL.-SAVLI,  
DIST.-VADODARA, GUJARAT, INDIA



**Client** : Longking Engineering India Pvt. Ltd.  
**Cunsaltant** : Mecon Ltd., Ranchi  
**Project** : 3X150 TPH Boiler & Turbo Blower System at Bhilai Steel Plant at Chattisgarh  
**P.O. No.** : LK1304C-WFD004-D003 Dtd. 18.04.13  
**Voltamp's REF. NO.** : 61619

**Date: 02.05.2013**

**Rev. '0'**

PAGE 1 OF 1

Data Sheet for 04 Nos. 2000 kVA, 6.6 / 0.433 KV Cast Resin Dry Type Transformer

**MAKE** VOLTAMP TRANSFORMERS LTD

**TYPE OF TRANSFORMER** Cast Resin Transformer

**LOCATION OF TRANSFORMER** Indoor

**RATING** 2000 kVA

**VOLTAGE RATIO (HV / LV)** 6.6 | 0.433 kV

**VECTOR GROUP** Dyn11

**TAPPING RANGE** +5.0% | -5% | Steps : 2.50%

**TAPPING BY** Off Circuit Tap Links

**TAPPINGS ON** On HV side

**CLASS OF INSULATION** " F "

**TEMPERATURE RISE IN WINDING** 80 °C Over Ambient: 50 °C

**% IMPEDENCE AT 75°C & PRINCIPAL TAP** 6.25 % (IS Tol.)

**NO LOAD LOSS** 3.5 KW (MAX)

**FULL LOAD LOSS AT 75°C** 18.0 KW (MAX)

**ENCLOSURE PROTECTION** IP 42

**EFFECIENCY \***

% LOAD	1 PF	0.8 PF
100	98.94	98.67
75	99.10	98.88
50	99.21	99.01

**REGULATIONS \***

% LOAD	1 PF	0.8 PF
100	1.091	4.528

**PAINT SHADE** Epoxy: 632 of IS 5

**\* The above furnished values of Efficiency & Regulation are based on Losses / Impedance.  
Which are subjected to the Tolerance as applicable of Losses & Impedance.**

**\*\* Prepared by : Vipul Ajmeri**



Checked & Approved By :