



Control Points Summary	Control Logic Description
<div><div>1. OA damper command</div><div>DO</div></div> <div><div>2. Filter differential pressure switch</div><div>DI</div></div> <div><div>3. Filter differential pressure switch</div><div>DI</div></div> <div><div>4. Cooling coil valve commanded position</div><div>AO</div></div> <div><div>5. Heating coil valve commanded position</div><div>AO</div></div> <div><div>6. Fan safety differential pressure switch</div><div>DI</div></div> <div><div>7. Fan VFD signal</div><div>AO</div></div> <div><div>8. ...</div><div></div></div>	<div></div>