


SR207-201
KS201-541
DIST. I/O

FÄLT


FÄLT (EX-ZON)

DOS880 EX SIL

NOD	1.116	1
MTU	06	2
KANAL	07	3
TAG	MV1	4




.M1
FOAR-PG 2x1,0




VENTILPANEL:XXX
UTTAG:XXX

DIS880 EX SIL

NOD	1.116	1
MTU	06	2
KANAL	08	3
TAG	GSO	4



.M2
FOAR-PG 2x2x1,0



FAIL OPEN

Apparat nr.	Antal	Fabrikat	Typ, Benämning, Data etc.
-MV1	1	Lucifer	24VDC, SIL2, Ex me, Namur 34.1N3102
-S1	1	Fagerberg	Indikeringsbox 007-M6-SBB-7RM62, Ex ed

Rev	Nytt I/O-nummer	Datum	Inf av	Godk	Förstag
1	2020-03-26	ARA			
Rev	Ändring				

Text	ON/OFF VENTIL	VENTURI SKRUBBER	Orig. format	A4	Dok. status	ARBETSHANDLING
HYBRIT	Process/Anl.	345SV522	Anl.del			
HYBRIT referens	Rith. nr	345SV522-0001-EA				
Rev						01