



Product Service

C E R T I F I C A T E

No. Z10 16 03 12833 003

Holder of Certificate: Endress + Hauser
Wetzer GmbH + Co. KGObere Wank 1
87484 Nesselwang
GERMANY**Factory(ies):** 12833**Certification Mark:****Product:** Temperature measuring equipment**Model(s):** Temperature Transmitter
TMT82 - SIL**Parameters:**

Software:	SIL3
Structure-SIL:	1oo1 - SIL2
Output:	4 ... 20mA
Error Current:	$\leq 3.6\text{mA}$ or $\geq 21.0\text{mA}$
Class of Protection:	IP20
Temperature range:	-40°C ... $+70^{\circ}\text{C}$

The report and the user documentation in the current valid revision are mandatory part of this certificate. The product complies with the following safety requirements only if the specifications documented in the currently valid revision of this report are met. The certified components are listed in report EN88356C-A in the current valid revision.

Tested according to:

IEC 61508-1(ed.2)
IEC 61508-2(ed.2)
IEC 61508-3(ed.2)
IEC 61508-4(ed.2)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: EN88356C**Valid until:** 2021-04-03**Date,** 2016-04-04

(Peter Weiss)



Page 1 of 1