


SR207-201
KS201-541
DIST. I/O

FÄLT


FÄLT (EX-ZON)

DOS880 EX SIL

NOD	1.116	1
MTU	06	2
KANAL	10	3
TAG	MV1	4




SV524



VENTILPANEL:XXX
UTTAG:XXX

DIS880 EX SIL

NOD	1.116	1
MTU	06	2
KANAL	11	3
TAG	GSO	4



FAIL CLOSE

Apparat nr.	Antal	Fabrikat	Typ, Benämning, Data etc.
-MV1	1	Lucifer	24VDC, SIL1, Ex ME, Namur 34.1N3102
-S1	1	Fagerberg	Indikeringsbox 007-M6-SBB-7RM62, Ex ed

Rev	Nytt I/O-nummer	Datum	Inf av	Godk	Förstag
1	2020-03-26	ARA			
Rev	Ändring				

Text	ON/OFF VENTIL UTLOPP KONDENSOR	Orig. format	A4	Dok. status	ARBETSHANDLING
Process/Anl.	345SV524	Anl.del			
HYBRIT referens		Rith. nr	345SV524-0001-EA	Rev	01