

APPARATSPECIFIKATION		STYRSYSTEM		BARRIÄR		FÄLT (EX-ZON)	
PI354 FABRIKAT : ENDRESS & HAUSER TYP : PMP71 INSIGNAL : - UT SIGNAL : 4-20mA MÄTNMR. : 0-10bar ÖVR. DATA : SIL2, EX IA, PASSIV		SR207-201 KS201-603 DIST. I/O		SR207-201 KS201-603			
AIS880 EX SIL ☒ NOD 1.132 1 MTU 07 2 KANAL 05 3 TAG MV 4 -U1 FABRIKAT : ENDRESS & HAUSER TYP : RB273-B1B INSIGNAL : 4-20mA UT SIGNAL : 4-20mA MÄTNMR. : - ÖVR. DATA :		.A1 FOAR-PG 2x10 1 2 SK 1 2 SK TE		.A2 FOAR-PG 2x10 BLÅ 1 2 SK 1 2 SK PI354 + - TRANSMITTER			
FABRIKAT : TYP : INSIGNAL : UT SIGNAL : MÄTNMR. : ÖVR. DATA :							
FABRIKAT : TYP : INSIGNAL : UT SIGNAL : MÄTNMR. : ÖVR. DATA :							
FABRIKAT : TYP : INSIGNAL : UT SIGNAL : MÄTNMR. : ÖVR. DATA :							
FABRIKAT : TYP : INSIGNAL : UT SIGNAL : MÄTNMR. : ÖVR. DATA :							
Anl. PILOTANLÄGGNING DRI Avdeln. KOMPRESSOR Leverantör ÅF-POYRY AB		Text TRYCKMÄTNING Process/ Anl. 354PI354 HYBRIT referens		Orig. format A4 Anl. del		Dok. status ARBETSHANDLING Rev 00	