SMART GRIDS / MIXED BUILDING COMMUNITY

Prosumer community simulator with heterogeneous buildings

21 October 2026

The accepted design contains **100 buildings with aggregate meters** in ten neighborhoods: 50 small houses, 30 apartment blocks, 10 supermarkets and 10 schools. Exactly 55 buildings own batteries. In the seeded realization, residential buildings contain **619 dwelling units**. One apartment block is one meter with one shared roof, not one roof per flat.

For the team: pages 11-21 explain every parameter, its units and effect, with worked examples and a configuration workflow.

Objective and experiment

Encourage neighborhood P2P electricity trading using price guidance and funded seller rewards, then evaluate storage priority and financial outcomes. Self-balancing, P2P, aggregator and grid settlement preserve energy and cash. Every completed internal trade appears in an hourly Proof-of-Work block.

Scenario	Storage	Regulation	Charging priority
A	55 owners	Off	Self-consumption first
B	55 owners	On	Self-consumption first
C	Disabled	Off	Counterfactual
D	Disabled	On	Counterfactual
E	55 owners	Off	P2P before charging
F	55 owners	On	P2P before charging

Actual result for the new community

With storage, regulation changes P2P energy from **254.554 to 706.991 kWh**, and its share from 4.120% to 11.444%. Cost effects differ by scenario and accounting boundary; all values below come from the recorded execution.

Evidence boundary: geometry, demand profiles, weather and price history are synthetic engineering assumptions. They are not measured building data. This mixed community is a new experiment and cannot be treated as a like-for-like improvement over the previous residential-only community.

02 Neighborhood layout and building types

Each row is one P2P neighborhood: five small houses, three apartment blocks, one supermarket and one school. Type positions are shuffled independently of battery assignment. H001-H100 identify whole-building meters; historical CSV field names retain the word household for compatibility.




Figure 1. Actual seeded layout. HOUSE, BLOCK, SHOP and SCHOOL show type; F denotes floors. Blue buildings and B badges indicate a battery. Positions and marker dimensions are schematic, not geography or feeder geometry.

Every neighborhood has five or six battery owners. IDs, types and ownership stay fixed in all scenarios, including C/D where operation is disabled. The map is generated automatically by simulation runs with charts enabled, together with exact cell and group CSV exports.

03 Building geometry and physical sizing

Type ranges are configurable in **config/buildings.py** and the buildings section of JSON. The following are proposed engineering defaults, not professor requirements or calibrated building-stock data.

Type	Count	Single roof m2	Floors	Daily energy basis
Small house	50	70-150	1-2	8-24 kWh per dwelling
Apartment block	30	180-360	4-10	8-20 kWh per dwelling
Supermarket	10	600-1400	1	0.5-1.1 kWh per m2
School	10	700-1600	2-3	0.08-0.18 kWh per m2

One roof, regardless of height

Total floor area = roof footprint x floors. Blocks contain 2-4 dwelling units per floor. Their demand basis scales with the total number of units. Commercial/school demand scales with total floor area. Small houses represent one dwelling even when they have two floors.

```
PV installed kW = min(single roof m2 x usable roof fraction x PV density, type PV limit)
```


Usable roof fraction is 35-65% and PV density is 0.20 kW/m2. Installed limits are 12 kW for houses, 100 kW for blocks, and 300 kW for supermarkets/schools. Floors and flats do not appear in the PV formula. Adding floors increases the demand basis without creating extra roof area.

Actual seeded attributes, averaged per building

Type	Battery owners	Dwellings	Mean roof m2	Mean PV kW
Apartment block	17	569	259.625	26.113
School	4	0	1,123.754	102.448
Small house	30	50	108.740	10.114
Supermarket	4	0	936.065	97.188

Battery capacity and charge/discharge power scale by type: 10 kWh / 3 kW for a house, 40 / 12 for a block, 100 / 30 for a supermarket and 60 / 18 for a school. Efficiency and SOC constraints remain identical. These scales can be overridden without changing ownership.

04 Dynamic demand and solar forecasts



Synthetic archetypes. Mean per building, not type totals. The same inputs are used in every scenario.

Figure 2. Mean energy per building of each type, per hourly step. Counts differ between types; these are not type totals. All scenarios reuse these same inputs.

Hourly activity and weekday/weekend behavior

Houses and blocks have morning/evening peaks with building-specific timing and hourly variation. Supermarkets retain a base load overnight and add operating load during 07:00-22:00. Schools operate during 08:00-17:00 on weekdays. Weekend daily energy is 105% of weekday baseline for residential types, 90% for supermarkets and 15% for schools; school operating load is disabled on weekends.

Each building receives a seeded daily multiplier within +/-8%. Geometry stays fixed during the experiment; consumption changes by hour and date. A supplied aggregate demand CSV replaces this synthetic model. Weekends are modeled, but school terms, public holidays and weather-sensitive HVAC loads are not. Weekday school operation in June is an explicit simplification.

PV and reference prices

PV kWh = installed kW x irradiance / 1000 x performance factor x hourly duration, capped at installed capacity. Nighttime production is zero. The default illustrative day starts 15 June 2026 at UTC+02:00, using a daylight curve and seeded cloud factors. Reference prices use only pre-start hourly observations; the default 14-day price history is synthetic. Forecast adapters reject missing coverage, duplicate keys and non-finite inputs.

05 Trading, regulation and transaction record

Settlement sequence

Self-balancing: owner PV serves current demand, with eligible battery operations.
P2P: seeded random buyer/seller encounters within each ten-member group, using the seller ask.
Aggregator: lowest asks and highest bids across groups, at midpoint prices.
External grid: remaining demand imports at EUR 0.30/kWh and surplus exports at EUR 0.06/kWh. Quantities update after each trade to prevent double selling.

Guidance and funded rewards

Opening regulator funds	P2P seller reward
Below EUR 1	EUR 0/kWh
EUR 1 to below EUR 5	EUR 0.01/kWh
EUR 5 or above	EUR 0.02/kWh

The fund starts at EUR 0. Guidance blends original offers toward 1.04 x reference for bids and 0.96 x reference for asks, with strength 0.65. Only P2P receives guidance. A full reward reservation is required before a discounted quote. Adjusted ask = guided ask - 50% of reward rate. A successful seller receives trading payment plus full reward. Unaffordable quotes retry original offers without reward; rejected reservations are released.


Regulated grid purchases and sales each pay EUR 0.01/kWh, collected after trading. New fees become available in the following hour. Opening funds fix that hour's reward tier. There are no internal fees or aggregator/grid seller rewards.

Blockchain and conservation

Ten simulated miners take turns testing SHA-256 nonces inside one process. One block per hour records all completed P2P and aggregator trades exactly once. Each hash begins 000 and references its predecessor; the first references 64 zeros. Validation checks hashes, linkage, transaction contents and journal coverage. The blockchain does not choose energy quantities or prices.

PV + discharge + purchases = demand + charge + sales.
Stored energy evolves as E_next = E_start + efficiency_c x charge - discharge / efficiency_d. Storage cannot charge and discharge simultaneously, charge from grid/P2P or sell stored energy.

06 P2P results for the mixed community



Identical hourly inputs across scenarios. See summary.json for data sources and seed. A/B: 55 batteries. C/D: none. E/F: P2P priority. B/D/F: regulated.

Figure 3. Shared-input P2P outcomes. A/B use storage first; C/D disable it; E/F prioritize P2P before charging. B/D/F are regulated.

Scenario	P2P kWh	Share %	Available surplus kWh	P2P trades
A	254.554	4.120	6,177.944	82
B	706.991	11.444	6,177.944	268
C	362.877	4.917	7,379.848	116
D	1,051.853	14.253	7,379.848	373
E	334.444	4.532	7,379.848	101
F	903.547	12.243	7,379.848	335

Primary KPI = 100 x P2P energy / surplus offered after self-balancing. In E/F the denominator includes PV subsequently stored after P2P, so compare absolute energy and raw PV surplus as well as shares. Zero denominators are undefined, not fabricated zeros.


B minus A: P2P energy difference **+452.438 kWh**.

D minus C: P2P energy difference **+688.976 kWh**.

F minus E: P2P energy difference **+569.103 kWh**.


These differences describe the selected day and heuristic. Guidance cannot create surplus or demand, and no improvement is forced for other settings.

07 Grid exchanges and financial results



Identical hourly inputs across scenarios. See summary.json for data sources and seed. A/B: 55 batteries. C/D: none. E/F: P2P priority. B/D/F: regulated.

Figure 4. Grid settlement and aggregator energy use separate scales to retain visibility of internal volumes.




Identical hourly inputs across scenarios. See summary.json for data sources and seed. A/B: 55 batteries. C/D: none. E/F: P2P priority. B/D/F: regulated.

Figure 5. Building-meter net payments versus building meters plus the regulator, alongside fees, rewards and remaining funds.

Meter net cost = purchases - sale revenue + fees - rewards. Internal P2P/aggregator payments cancel over meters. Including the regulator subtracts the change in retained funds and equals net external-grid payments. Battery capital, aging, taxes and inventory valuation are excluded.


A to B: meter cost EUR 1978.25 to 2016.89; meters plus regulator EUR 1978.25 to 1902.86. C to D: meter cost EUR 2188.16 to 2174.97. Cost effects need not have the same sign in every pair.

08 Battery operation and available surplus



Identical hourly inputs across scenarios. See summary.json for data sources and seed. A/B: 55 batteries. C/D: none. E/F: P2P priority. B/D/F: regulated.

Figure 6. Aggregate storage and surplus denominators. A/B charge before P2P; E/F charge remaining PV after P2P. C/D have no active storage.




Identical hourly inputs across scenarios. See summary.json for data sources and seed. A/B: 55 batteries. C/D: none. E/F: P2P priority. B/D/F: regulated.

Figure 7. End-of-hour SOC of the 55 owners in scenario A. Capacity and power differ by building type, while allowed SOC remains 10-90%.

In A, AC charging is 1,201.904 kWh, discharge 1,018.134 kWh and conversion losses 113.681 kWh. Initial stored energy is 324.000 kWh and final storage 394.088 kWh. Initial inventory is exogenous; final inventory is reported without a monetary valuation.

The global identity includes PV, demand, imports/exports, initial/final storage and explicit losses. It is checked independently of internal trading payments.

09 Regulator budget and accounting boundary



Identical hourly inputs across scenarios. See summary.json for data sources and seed. A/B: 55 batteries. C/D: none. E/F: P2P priority. B/D/F: regulated.

Figure 8. Closing funds across the day. An hour's opening balance selects the reward tier before that hour's new grid fees are collected.

Scenario	Fees EUR	Rewards EUR	Closing fund EUR
B	128.165	14.140	114.025
D	143.400	21.037	122.363
F	125.773	18.071	107.702

Closing fund = opening fund + grid fees - eligible P2P rewards. Every movement has a payer and payee. Reservations, releases, reward payments and hourly fund histories are exported. The ledger reconciles with the regulator's fund after each hour.

Retained fees are a transfer from building meters to the regulator, not money destruction or an external resource cost. They can offset savings from better matching at the meter boundary. Accounts may pay for energy without a starting-cash restriction; only regulator guarantees are constrained by available funding.

No end-of-day rebate is assumed. Changes to fees, reward tiers or guidance require a separately recorded configuration and rerun. The mixed-building outcomes cannot be attributed solely to regulation by comparing them with the old, physically different residential community.

10 Verification, reproduction and limits

Recorded checks

The recorded full suite passed **69 tests** on 21 October 2026. All six saved scenarios passed independent energy, cash and blockchain verification. Tests include unchanged battery ownership, type allocation, one-roof sizing, increased block demand with floors, school weekend reduction, commercial night load, losses/SOC, rewards and forecast cutoff.

Maximum absolute community energy residual: 4.12e-12 kWh. Maximum financial residual: 4.55e-13 EUR. Numerical residuals are checked at explicit tolerances.

Run and rebuild

```
python -m pip install -r requirements.txt
python -m pytest -q
python main.py --include-priority
python scripts/verify_results.py
python -m pip install -r requirements-report.txt
python scripts/create_report.py
```

The simulator requires Python 3.11+ and was exercised on Python 3.14.7. PDF dependencies are optional. Use --config for JSON overrides, --output for separate experiment folders and --no-charts to skip visual exports. The historical residential model remains available through config/residential_baseline.json.

Scope and evidence

The model has no physical feeder limits, voltage/power-flow equations, land parcels, weather-sensitive HVAC, holiday/term calendar, battery aging or investment analysis. Hourly energy settlement and aggregate building meters are simplifying choices. A single synthetic day supports a demonstration, not a statistical or real-world performance claim. Presentations and ZIP packaging remain deferred.

Sources: supplied project brief and accepted building-meter revision; config/default.json; docs/building_model.md; results/comparison.json and saved chart data; docs/current_validation.json. The original residential comparison and report are preserved as a separate baseline.

Input SHA-256: 0d448af457d23a1206abf773826bbc61158501c6f65811dd56a36db7ef192d38

11 Team guide: how to read the simulation

The next pages explain **all 154 configurable values** in the recorded experiment. Values come from scenario A's saved configuration in results/comparison.json, not from a possibly edited live JSON file. Other scenarios reuse the same base inputs and differ in their recorded storage/regulation switches.

Read first	Purpose
Pages 1-5	Community, building types, physical models and trading rules.
Pages 6-10	Actual outcomes and numerical verification.
Pages 12-20	Exact parameter names, values, units and implemented effects.
Page 21	Worked shared-roof example and steps for a controlled team experiment.

Units and terms

Term	What it means in this simulator
kW	Power: an energy rate. A 3 kW charger can draw at most 3 kWh during one hour, before other limits.
kWh	Energy accumulated over a step or stored in a battery. Sum hourly energy to obtain a daily total.
EUR/kWh	Price per energy unit. Quantity x price gives the trading payment. EUR/MWh source data must be divided by 1000.
SOC	Stored energy / nominal battery capacity. 0.20 means 20%, not 0.20 kWh.
Building / meter	One trading participant. A block aggregates its flats at one meter and shares one roof.
Dwelling unit	One residential flat/home inside a building. It is not automatically a separate P2P participant.

Fixed properties versus dynamic values

Roof area, floors, flat count, PV capacity, offer factors and battery ownership are drawn once per experiment and stay fixed. Hourly PV, demand, SOC, trades, cash and regulator funds evolve through time. Shape weights redistribute a fixed daily energy baseline; they are not independently added kWh.

Synthetic inputs and sizing ranges are teaching assumptions. A valid conservation check proves accounting consistency, not empirical realism or a guarantee of better economics.

12 Parameters: community, time and randomness

JSON sections: simulation and buildings. Historical keys containing household now count building meters in the mixed model. A report value is not applied to new runs until it is saved in the chosen configuration.

Exact JSON key	Value used / units	Meaning and effect of changing it
simulation.household_count	100 (building meters)	Number of aggregate participants, not flats. More meters enlarge the community. Must divide evenly into group_count.
simulation.group_count	10 (groups)	Number of P2P neighborhoods. Group size = meter count / group count. Changes which meters can trade directly.
simulation.battery_household_count	55 (owners)	Exact number of battery-owning meters. IDs are selected with the seed and spread evenly across groups. C/D disable operation, not ownership.
simulation.hours	24 (one-hour steps)	Length of the run. 24 covers one day; 168 covers a week and exposes weekend effects. Longer runs do not add holiday logic.
simulation.timestep_hours	1 (hours per step)	This implementation supports exactly 1. Do not change it to 0.5: the hourly input generator rejects other durations.
simulation.random_seed	42 (integer)	Controls randomized ownership, type positions, building attributes, cloud factors, demand variation and encounter order through separate seeded streams.
simulation.log_level	INFO (logging level)	Console verbosity: DEBUG, INFO, WARNING, ERROR or CRITICAL. Does not change energy or prices.
buildings.enabled	true (boolean)	true selects the mixed-building model. false selects the original individual-house model; type geometry and type battery scales are then unused.
buildings.pv_density_kw_m2	0.2 (kW per usable m2)	Installed PV power per usable roof area. Higher density raises capacity until the type PV limit is reached. It does not multiply roof area by floors.

Constraints: equal neighborhood sizes; battery owners between zero and meter count; positive duration; currently one-hour steps only. Shares are rounded separately within each group, so small custom groups may not reproduce exact requested type percentages.

The seed is held fixed across scenarios. Changing it creates a different realization and should be recorded as a new experiment, rather than interpreted as the effect of one policy switch.

13 Parameters: building geometry and composition

Prefix: buildings.types.<type>., where type is small_house, apartment_block, supermarket or school. The four value columns show the actual settings used; H001-H100 are the resulting seeded realizations, not these range endpoints.

Key under each type	House	Block	Market	School	Units and meaning
share	0.5	0.3	0.1	0.1	fraction. Requested type fraction. All four shares must sum to 1. Counts use largest-remainder rounding separately in each neighborhood.
roof_min_m2	70	180	600	700	m2. Lower bound of the sampled single roof footprint; higher area permits more PV and increases the area-based commercial/school load basis.
roof_max_m2	150	360	1400	1600	m2. Upper bound of that roof draw. One roof per building, regardless of floor count.
floors_min	1	4	1	2	floors. Lower bound of the integer floor draw. Raises block dwelling counts and school floor area, without adding PV roofs.
floors_max	2	10	1	3	floors. Upper floor-count bound. Total floor area = roof footprint x sampled floors.
units_per_floor_min	1	2	1	1	flats per floor. Lower integer bound, used to calculate block flats. Small houses always have one dwelling; schools/shops have zero residential dwellings.
units_per_floor_max	1	4	1	1	flats per floor. Upper bound for block flats per floor. More flats increase aggregate residential demand, not roof size.
roof_usable_fraction_min	0.35	0.35	0.35	0.35	fraction. Lower bound of the usable roof share for PV. Excludes the rest of the roof from installed-panel area.
roof_usable_fraction_max	0.65	0.65	0.65	0.65	fraction. Upper usable-share bound. Capacity = min(roof x usable share x density, pv_limit_kw).
pv_limit_kw	12	100	300	300	kW. Upper installed-PV limit for one building. Raising it matters only where the roof-based capacity would exceed the old limit.
battery_scale	1	4	10	6	multiplier. For owners, multiplies base storage capacity and both power limits. Does not change owner count, SOC fractions or efficiency.

Roof and floor area are different quantities. Type PV limits constrain the single roof; floors never create duplicate roofs. Battery scale changes equipment sizes only for existing owners, preserving the selected 55 owner IDs in this run.

14 Parameters: building demand and schedules

Prefix: buildings.types.<type>. Daily energy is drawn first, then distributed over 24 hours. The realized total may differ after weekend and per-date variation. Operating hours use the configured fixed local offset.

Key under each type	House	Block	Market	School	Units and meaning
daily_energy_min	8	8	0.5	0.08	basis-dependent. Lower base energy draw: kWh/dwelling/day for per_dwelling, or kWh/m2/day for per_floor_area. Before weekend/day multipliers.
daily_energy_max	24	20	1.1	0.18	basis-dependent. Upper energy draw. Multiply by dwelling count or total floor area to obtain the building weekday daily baseline.
energy_basis	per_dwelling	per_dwelling	per_floor_area	per_floor_area	enum. per_dwelling uses dwelling count; per_floor_area uses roof x floors. Keep houses/blocks on dwelling basis and nonresidential buildings on area basis.
profile	residential	residential	commercial	school	enum. residential uses morning/evening peaks. commercial and school use a base plus an opening-hour load. Type name alone does not override this field.
opening_hour	7	7	7	8	local hour. Start of operating activity, inclusive. Used by nonresidential profiles; ignored by residential profiles.
closing_hour	22	22	22	17	local hour. End of operating activity, exclusive. A school closing at 17 has no operating component in the 17:00-18:00 step.
base_load_weight	0.25	0.25	0.45	0.08	relative weight. Positive all-hour load weight. It sets profile shape relative to peaks/operation; hourly weights are normalized to the daily energy, so this is not a kW value.
operating_load_weight	1	1	1	1	relative weight. Additional weight while operating. Used by commercial/school profiles; ignored by residential profiles. Changes hourly distribution, not the daily baseline total.
weekend_multiplier	1.05	1.05	0.9	0.15	fraction/multiplier. Saturday/Sunday daily energy relative to the weekday baseline. 0.15 means 15%, not a 15% reduction. Daily random variation still applies.
weekend_open	true	true	true	false	boolean. Whether the nonresidential operating component remains active on weekends. false removes operating activity but does not remove the base load.
daily_variation_fraction	0.08	0.08	0.08	0.08	fraction. Seeded per-building, per-date variation. 0.08 samples a multiplier between 0.92 and 1.08, shared by all hours of that building's day.

Example: a school's weekday baseline of 400 kWh becomes a 60 kWh weekend baseline at multiplier 0.15, then receives its seeded daily factor. This is an illustration of the rule, not an observed or reported school measurement.

15 Parameters: batteries and energy losses

Prefix: simulation.battery. Type battery_scale multiplies the three sizing values; fractions and strategy are not scaled. Storage cannot use purchased electricity or discharge beyond owner demand.

Exact JSON key	Value used / units	Meaning and effect of changing it
simulation.battery.capacity_kwh	10 (kWh)	Base nominal stored-energy capacity. Each owning building multiplies this by its battery_scale.
simulation.battery.max_charge_power_kw	3 (kW)	Base AC charging power limit. Maximum step energy = scaled power x hours, also limited by PV surplus and SOC headroom.
simulation.battery.max_discharge_power_kw	3 (kW)	Base AC power delivered from storage. Also limited by owner demand and stored energy above minimum SOC.
simulation.battery.charge_efficiency	0.95 (fraction)	Fraction of AC charging energy retained in storage. 0.95 stores 0.95 kWh for every 1 kWh entering; the remainder is a loss.
simulation.battery.discharge_efficiency	0.95 (fraction)	Fraction of removed stored energy delivered to demand. Delivering 1 kWh removes 1 / efficiency kWh from storage.
simulation.battery.initial_soc	0.2 (fraction of capacity)	Starting inventory, not a charging transaction. 0.20 starts at 20% of each building's scaled nominal capacity.
simulation.battery.min_soc	0.1 (fraction of capacity)	Lower stored-energy reserve. Raising it reduces energy available for discharge.
simulation.battery.max_soc	0.9 (fraction of capacity)	Upper stored-energy bound. Lowering it reduces charging room. min <= initial <= max is required.
simulation.battery.strategy	self_consumption_first (enum)	Engine default: self_consumption_first or p2p_priority. Named experiments override it: A/B select the first; E/F select the second. C/D disable storage.

Equipment multipliers used: small_house: x1, apartment_block: x4, supermarket: x10, school: x6. Min/initial/max SOC must be ordered and efficiencies must lie in (0,1]. Named A-F scenarios override the engine strategy field as shown on page 1.

Worked AC-side example

If headroom and surplus allow a 3 kWh charge, storage gains 2.850 kWh and loses 0.150 kWh. Delivering 1 kWh to demand removes 1.0526 kWh from storage, with 0.0526 kWh lost. Power and SOC limits may reduce these illustrative quantities.

16 Parameters: weather, prices and input files

Prefix: forecast. CSV paths replace only the corresponding synthetic input. null means use the fallback. All input types remain explicitly labeled in hourly_inputs.csv.

Exact JSON key	Value used / units	Meaning and effect of changing it
forecast.start_timestamp	2026-06-15T00:00:00+02:00 (ISO datetime + offset)	First hour of the run and the strict historical-price cutoff. Its weekday chooses school/weekend demand behavior. Offset is fixed; no named-zone DST calendar.
forecast.sunrise_hour	6 (local hour)	Start boundary of synthetic daylight. Generation is zero at and before this hour; configure for the modeled season.
forecast.sunset_hour	20 (local hour)	End boundary of synthetic daylight. Generation is zero at and after this hour; supplied weather is checked against these bounds.
forecast.peak_irradiance_w_m2	900 (W per m2)	Peak of the synthetic daylight curve before cloud scaling. Higher values raise PV energy, not installed PV capacity.
forecast.performance_factor	0.85 (fraction)	Converts irradiance and installed power to PV output, representing aggregate system losses. Applied to both synthetic and CSV weather.
forecast.cloud_factor_min	0.65 (fraction)	Lower synthetic hourly multiplier on clear-day irradiance. Unused when weather_csv is supplied.
forecast.cloud_factor_max	1 (fraction)	Upper synthetic cloud multiplier. Both cloud factors lie between 0 and 1; the default never exceeds the clear-day curve.
forecast.historical_days	14 (days)	Number of synthetic pre-start price days. Unused when a historical price CSV is supplied; not a rolling actual-data update during simulation.
forecast.price_base_eur_kwh	0.17 (EUR per kWh)	Level of synthetic historical prices before the hourly sine component and random noise. Unused with a price CSV.
forecast.price_amplitude_eur_kwh	0.045 (EUR per kWh)	Amplitude of the synthetic hourly price pattern around its base. The forecast then averages earlier observations by clock hour.
forecast.historical_price_noise_eur_kwh	0.01 (EUR per kWh)	Symmetric +/- noise for synthetic historical prices. A seeded draw, not a measured forecast error or uncertainty interval.
forecast.weather_csv	null (path or null)	Optional timestamp,irradiance_w_m2 forecast file. null uses synthetic weather. Must cover the run and represent information available at issuance.
forecast.demand_csv	null (path or null)	Optional timestamp,household_id,demand_kwh file covering every meter/hour. Replaces all synthetic load shapes, calendar and daily variation.
forecast.historical_prices_csv	null (path or null)	Optional timestamp,price_eur_kwh file. Only observations strictly before start can affect hourly averages; all 24 clock hours need earlier coverage.

Past-price forecasting requires earlier observations for every clock hour. Never insert future actual data into a weather/demand file and call it an available forecast. The code cannot infer that provenance from column names alone.

17 Parameters: offers and residential profile shape

Prefix: households, retained for compatibility. Offer factors apply to all building meters. Morning/evening shape parameters apply only to residential profiles. A single building's bid/ask factors stay fixed while reference prices vary hourly.

Exact JSON key	Value used / units	Meaning and effect of changing it
households.bid_multiplier_min	0.7 (multiplier)	Lower household-specific bid-factor draw. Original maximum willingness to pay = reference forecast x drawn bid factor, clipped to market offer bounds.
households.bid_multiplier_max	1.15 (multiplier)	Upper bid-factor bound. Higher bids can accept more asks, but do not create shortage or available generation.
households.ask_multiplier_min	0.9 (multiplier)	Lower seller ask-factor draw applied to the reference forecast before offer clipping. Lower asks can improve compatibility.
households.ask_multiplier_max	1.35 (multiplier)	Upper ask-factor bound. A higher range can make offers incompatible with buyers; prices are still limited by market bounds.
households.morning_peak_weigh t	0.65 (relative weight)	Height of the residential morning peak relative to base/evening load. Normalized to daily energy, not an extra daily kWh allowance.
households.morning_peak_hour	7 (local hour)	Center of the residential morning Gaussian peak before each building's seeded timing shift.
households.morning_peak_width _hours	2 (hours)	Width in exp(-((hour-center)/width)^2). Larger values spread the same normalized daily energy across a broader morning peak.
households.evening_peak_weight	1.1 (relative weight)	Relative height of the residential evening peak. Higher weight reallocates energy toward evening after normalization.
households.evening_peak_hour	19 (local hour)	Center of the residential evening peak before the building timing shift.
households.evening_peak_width_ hours	3 (hours)	Width of the evening Gaussian profile component. Does not change the configured daily energy draw.
households.profile_shift_max_ho urs	1 (hours)	Maximum +/- building timing shift for residential peaks. A shift is drawn for other profiles but is not used by their fixed opening schedule.
households.profile_noise_fraction	0.25 (fraction)	Seeded hourly weight variation. 0.25 multiplies weights by draws from 0.75 to 1.25, then renormalizes the daily total.

For residential weights, the code combines type base_load_weight with Gaussian morning/evening components, multiplies hourly noise weights, then normalizes to the drawn daily energy. A larger peak weight shifts energy toward that peak; it does not raise the configured daily total.

18 Parameters: grid prices and offer bounds

Prefix: market. These prices set the outside option and restrict bids/asks. P2P transactions pay the seller ask; aggregator transactions pay the bid-ask midpoint. Buying and selling are limited by remaining energy, not only by prices.

Exact JSON key	Value used / units	Meaning and effect of changing it
market.grid_import_tariff_eur_kwh	0.3 (EUR per kWh)	Price paid to the external grid for residual shortages, before a regulated grid fee.
market.grid_export_tariff_eur_kwh	0.06 (EUR per kWh)	Revenue from the grid for residual surplus, before the export-side regulated fee.
market.minimum_offer_eur_kwh	0.06 (EUR per kWh)	Lower bound for original/guided offers. It must be at least the export tariff. Guidance leaves headroom for a guaranteed reward discount.
market.maximum_offer_eur_kwh	0.3 (EUR per kWh)	Upper offer bound, at most the import tariff. Import >= maximum >= minimum >= export is required.

Worked original-offer example

Illustration: reference price EUR 0.20/kWh, buyer factor 1.10 and seller factor 1.00 produce a bid of EUR 0.22 and ask of EUR 0.20 before guidance. With sufficient energy, a 2 kWh P2P transaction costs EUR 0.40 at the seller ask. An aggregator match at those offers instead uses EUR 0.21/kWh, costing EUR 0.42.

Costs need an accounting boundary

Meter net cost includes grid and internal purchases minus sales, plus fees minus rewards. Internal trading payments cancel over all meters. Regulator fees/rewards also cancel when the regulator is included. Therefore meters-plus-regulator net cost equals net external-grid payments, while meter-only cost can move differently.

Changing import/export tariffs changes grid settlement. Changing offer bounds changes compatibility in internal markets as well. A high PV surplus alone does not imply P2P trade: an eligible buyer must have demand and a compatible bid in the same group.

19 Parameters: regulator guidance and funding

Prefix: regulator. All rules apply only when regulation is enabled by the selected scenario. The opening balance chooses one tier for the hour; the remaining fund still constrains each guarantee.

Exact JSON key	Value used / units	Meaning and effect of changing it
regulator.initial_budget_eur	0 (EUR)	Opening reward fund, recorded as external initial funding if nonzero. It is not fee revenue. Defaults to zero.
regulator.grid_fee_eur_kwh	0.01 (EUR per kWh)	Fee on each grid import and export when regulated, collected after trading. No fee is charged on internal trades.
regulator.lower_tier_budget_eur	1 (EUR)	Opening-fund threshold for the lower positive reward tier. At exactly this threshold the lower rate applies.
regulator.upper_tier_budget_eur	5 (EUR)	Opening-fund threshold for the upper reward tier. At exactly this threshold the upper rate applies.
regulator.lower_reward_eur_kwh	0.01 (EUR per P2P kWh)	Reward to successful P2P sellers in the lower tier, conditional on full funding of the proposed trade quantity.
regulator.upper_reward_eur_kwh	0.02 (EUR per P2P kWh)	Upper-tier reward. The rate remains fixed for the hour, but reservations cannot exceed remaining available funds.
regulator.reward_discount_fraction	0.5 (fraction of rate)	Share of the guaranteed reward rate subtracted from guided ask. 0.50 gives buyers half the rate as a price reduction; sellers still receive the full reward.
regulator.guidance_strength	0.65 (fraction)	Blend weight: guided = (1-strength) x original + strength x target, then clipped. Zero removes the blend, but leaves reward rules active.
regulator.guided_bid_multiplier	1.04 (multiplier)	Buyer guidance target = reference forecast x this value. Higher targets can make bids more compatible.
regulator.guided_ask_multiplier	0.96 (multiplier)	Seller guidance target = reference forecast x this value. Lower targets can make asks more compatible.

Worked funded-reward example

Illustration: opening fund EUR 5, guided ask EUR 0.20/kWh, trade 2 kWh and reward rate EUR 0.02/kWh. Reserve EUR 0.04. Adjusted ask is EUR 0.19/kWh. The buyer pays EUR 0.38; the seller also receives EUR 0.04 from the fund. The full reward must be affordable before the discount is guaranteed.

Below the lower budget threshold there is no reward, but guided/ordinary trading can still occur. Fees collected at hour end cannot retroactively finance that hour's quotes.

20 Parameters: blockchain and legacy-only fields

The first three fields configure the transaction record, independently of energy matching. The remaining fields are deliberately retained for the original house model and have no sizing effect in the mixed-building model.

Exact JSON key	Value used / units	Meaning and effect of changing it
blockchain.miner_count	10 (simulated miners)	Number of round-robin nonce-search participants in one process. No physical servers, network or miner compensation are modeled.
blockchain.hash_prefix	000 (hexadecimal text)	Required hash beginning. A longer prefix increases expected mining work; it does not change trades, prices or energy balances.
blockchain.max_nonce_attempts	5000000 (attempts per block)	Guard against unbounded mining. If exhausted, mining raises an error rather than appending an invalid block.
households.pv_capacity_min_kw	2 (kW; legacy only)	Lower per-house PV draw only when buildings.enabled=false. It does not control roof-based PV in the mixed model.
households.pv_capacity_max_kw	8 (kW; legacy only)	Upper legacy PV draw. Edit buildings geometry, usable fractions, density or limits for the mixed model instead.
households.daily_demand_min_kwh	8 (kWh/day; legacy only)	Lower daily demand draw in the old house model. Mixed-model baselines use each type's daily_energy_min/max and energy_basis.
households.daily_demand_max_kwh	24 (kWh/day; legacy only)	Upper daily demand draw in the old model. No effect on mixed-building daily energy.
households.base_demand_weight	0.25 (weight; legacy only)	Base hourly profile weight in the old model. Mixed profiles use buildings.types.<type>.base_load_weight instead.

Use buildings geometry and type energy parameters for current experiments. Setting households.pv_capacity_max_kw while buildings.enabled=true does not alter installed PV. Use config/residential_baseline.json when intentionally reproducing the old model.

Proof-of-work difficulty is computational work, not a reward paid to miners or an electrical load in the community. Miner count does not represent the number of neighborhoods, even though both happen to be 10 in the current defaults.

21 Team workflow and controlled experiments

1. Start from a recorded baseline

Keep the default saved result and record the scientific question. Change one mechanism at a time when estimating its effect. Compare policies on the same buildings, weather, demand, price inputs and seeds. For sensitivity to seed, use several separately recorded realizations rather than selecting a favorable one.

2. Save a partial JSON override

Example for a seven-day school-weekend experiment, saved as config/team_experiment.json:

```
{
"simulation": {"hours": 168},
"buildings": {"types": {
"school": {"weekend_multiplier": 0.10}
}}
}
```

Partial overrides retain unspecified defaults. Type shares must still sum to 1, and base battery fields remain under simulation.battery. There is no --hours command-line option: duration is changed in JSON.

3. Run, inspect and preserve separate outputs

```
python main.py --config config/team_experiment.json
--include-priority --output results/team_experiment
python scripts/verify_results.py results/team_experiment
```

The simulation command above is shown across two lines for readability: enter it as one command. A-F retain their named scenario rules. --no-charts skips graphs; --scenario B runs only B. The PDF builder requires all six scenarios and chart files, and warns if the saved validation record uses a different input hash.

Shared-roof sizing example

Illustration: one block has a 250 m2 roof, usable share 0.50 and density 0.20 kW/m2. PV capacity is 25 kW if its type limit permits. At 4 floors and 3 flats per floor it has 12 flats; at 8 floors it has 24. At an illustrative 10 kWh per flat/day, baseline demand rises from 120 to 240 kWh/day while PV remains 25 kW. These are example values, not extra measurements.

4. Read the outputs before drawing conclusions

Check comparison.csv for P2P kWh, its surplus denominator, imports/exports, costs at both boundaries, fees, rewards, closing funds and final storage. Join household_hourly.csv with inputs/households.csv by meter ID for type-specific behavior. Keep the exact saved configuration and input hash; a new community is not a pure policy comparison.