

P-101 Equipment Manual — Demonstration Extract

Document Information

Document ID: MAN-P101-001

Equipment: Pump P-101

Revision: 3.0

Status: Controlled demonstration document

Equipment Description

P-101 is a centrifugal process pump. The drive arrangement includes Motor M-101. Sensor S-101 provides vibration monitoring for the pump assembly.

Normal Monitoring

Operators should monitor vibration, bearing temperature, unusual noise, leakage, and changes from established operating conditions.

A persistent increase in vibration should trigger review of maintenance history and an engineering inspection.

Bearing Symptoms

Possible indicators of bearing degradation include increasing vibration, abnormal bearing noise, and rising bearing temperature. These indicators require inspection and should not be interpreted as a definitive diagnosis by themselves.

Safety Note

The manual does not authorize an AI system to directly control process equipment. Any critical operational action must follow the organization's approved human-controlled procedure.