

P-101 Standard Operating Procedure — Vibration Response

Document Information

Document ID: SOP-P101-001

Revision: 2.1

Equipment: Pump P-101

Monitoring Rule

For this demonstration, the vibration review threshold is 7.1 mm/s RMS.

Response Rules

IF observed vibration > 7.1 mm/s, THEN initiate maintenance inspection/review.

IF a recommendation involves shutdown or another high-impact operational action, THEN human approval is required.

IF the evidence source is untrusted or quarantined, THEN it must not be used as authoritative evidence.

Evidence Requirement

Engineering conclusions should reference the relevant inspection record, maintenance history, and applicable procedure or manual.

Safety Boundary

This demonstration procedure does not permit autonomous control of DCS or physical equipment.