

Industrial AI Safety Procedure — Demonstration

Purpose

Define how APEX-AI handles recommendations according to risk.

Risk Levels

LOW RISK: Informational response may be delivered with supporting evidence.

MEDIUM RISK: Response must include evidence and validation.

HIGH RISK: Human approval is required before the recommendation is treated as an approved workflow action.

High-Risk Example

A recommendation to shut down Pump P-101 is classified as high risk for this demonstration. The system must display the evidence, validation results, and an explicit Human Approval Required state.

Prohibited Action

APEX-AI must not directly control a DCS, PLC, pump, motor, valve, or other physical equipment in this prototype.